

Amendment- I**Annexure-I**

“Construction of North Eastern Institute of Ayurveda and Homeopathy (NEIAH) at NEIGRIHMS, Shillong, Meghalaya” :- Clarifications / amendments to queries raised by the bidders related to Electrical works.

Item No	Existing Item	Volume No/Page No	Amended Item/
1.01 at E-1	Approved makes for 11 KV VCB	Volume IV/E-100 R0	In addition to the specified ‘Approved Makes’, 11 KV VCB of Crompton is also acceptable
	CT. ratio to be mentioned for VCB		CT ratio will be as per ratings of Transformer.
1.03 at E-3	Approved makes for Transformer	Volume IV/E-100 R0	In addition to the specified ‘Approved Makes’, Transformer of Kirloskar is also acceptable.
	SLD of entire power distribution board including the bus coupler connection should be given for studying the load distribution.		Shall be given to successful bidder only
2.01 & 2.02	Breaking capacity for all MCCB to be mentioned	Volume V/ E-6 & E-11 R1	Breaking capacity of MCCB mentioned in technical specification, Pg No E-28 R0, clause 5.02.04. However, MCCB of Main LT Panel shall be 50 KA fault level.
2.03	Capacitor Panel : CT ratio to be mentioned.	Volume V/ E-17 R1	CT ratio will be as per current rating of capacitor panel.
3.01	<u>DG SET</u> : Exhaust pipe length of suitable size to be mentioned	Volume V/ E-19 R1	As per norms of Pollution Control Board
4.03	<u>TAP OFF BOX</u> : MCCB ampere rating to be mentioned.	Volume V/ E-24 R1	Rating will be as per BOQ item No 4.03

All other terms & conditions of the bid documents shall remain unchanged.