

LIST OF VOLUMES

VOLUME I : PREQUALIFICATION DOCUMENT

VOLUME II : GENERAL CONDITIONS OF CONTRACT

VOLUME III : INSTRUCTIONS TO BIDDERS
SPECIFIC CONDITIONS OF CONTRACT

VOLUME IV : TECHNICAL SPECIFICATIONS

Air Conditioning Works

VOLUME V BILL OF QUANTITIES AND FORM OF BID

Air Conditioning Works

**CENTRAL FOOD & DRUG TESTING
LABORATORY MUMBAI**

**TENDER
FOR**

**HVAC, CLEAN ROOM AND ALLIED WORKS
FOR MICROBIOLOGY LAB FOR FOOD &
DRUG TESTING LABORATORY MUMBAI**

VOLUME - I

**PRE-QUALIFICATION DOCUMENT
DECEMBER 2008**

HSCC (INDIA) LTD.

(Consultants & Engineers for Mega Hospitals & Laboratories)
E - 6 (A), Sector - I, NOIDA (U.P.) - 201 301 (INDIA)

PHONE : 91-2542436, 2542440 FAX : 91-11-91-2542447
91-2542443, 2542445 E- mail : hsccltd @hsccltd.co.in

Tender No **HSCC/139/PM/-HVAC-F&D Mumbai/2008**

HSCC (India) Limited.

(Consultants & Engineers for Mega Hospitals & Laboratories)
Plot No.6(A), Block-E, Sector-1,NOIDA - 201301 (U.P.)

No. HSCC/139/PM/FUR-HVAC-F&D Mumbai//2008

Dated : 03.12.2008

NOTICE INVITING TENDER

1. HSCC (India) Ltd. provides Comprehensive services from concept to commissioning in the Health Care sector ranging from feasibility studies, planning, design and detailed engineering, project management, procurement and commissioning of medical equipments and procurement of drugs.
2. On behalf of Ministry of Health & Family Welfare Govt of India, **HSCC (India) Ltd.** invites sealed tenders in two bid system from the Suppliers/contractors/firms for the following works:

Sl. No.	Name of Work	Estimated Cost (Rs.)	Bid Security (Rs.)	Cost of document (Rs.)	Period of Copletion
1	“Supply of Office and Laboratory Furniture for Food & drug Testing Laboratory Mumbai.	105 lakhs	2.10 lakh	5000.00	2.5 Months
2	HVAC, Clean room and allied works for Microbiology lab for Food & drug Testing Laboratory Mumbai.	45 Lakhs	90,000/-	3000.00	2.5 Months

3. Eligibility Criteria :

- (a) Average annual financial turnover during the last three years [2005-2006, 2006-2007 & 2007-2008] of 252 Lakh for work at S.No 1 and Rs 65 Lakh for work at S.No 2.
 - (b) The experience of having successfully completed similar works during last 7 years ending last day of month previous to the one in which applications are invited should be either of the following: -
 - i) Three similar completed works each costing not less than the amount equal to 40% of estimated cost.
 - ii) Two similar completed works each costing not less than the amount equal to 50% of estimated cost.
 - iii) One similar completed work costing not less than the amount equal to 80% of estimated cost.
 - (c) Minimum solvency certificate from banker for the sum of Rs 105 Lakh for work at S.No 1 and Rs 45 lakh for work at S.No 2.
 - (d) The firm should be profit making & have positive net worth in last three financial years.
- 4 Applicants may obtain the tender documents on any working day between **10.00 AM** and **4.00 PM** from 04.12.2008 to 18.12.2008 on written request from HSCC at the above address against a non refundable fee as specified above for above stated works separately payable in cash or in the form of Demand Draft/ Banker's Cheque in favour of **HSCC (INDIA) Limited** from any nationalised bank/ scheduled bank payable at **NOIDA / DELHI**. The applicant may collect the documents in person with authorization letter or on request, HSCC will promptly dispatch the documents by courier on payment of an extra amount of **Rs. 500/-** over & above the said document fee as indicated above, but under no circumstances HSCC will be held responsible for late delivery or loss of the documents so mailed.
 5. Pre-bid meeting shall be held on 12.12.08 at 12.00 hrs and 14.00 hrs 14.00 hrs for works listed at S.No 1 and at 2 respectively at Food & drug Testing Laboratory Mumbai.
 6. Tender complete in all respect must be submitted in sealed envelopes, which must be either delivered by hand or by registered mail to **HSCC** at the above address so as to reach not later than **15.00 hours** on **19/12/2008**. (Under no circumstances HSCC will be held responsible for late delivery or loss of the documents so mailed).Tender shall be opened on **19/12/2008 at 15.30 hours**.
 7. HSCC reserves the right to accept or reject any/all bids without assigning any reason.
 8. Copy of tender document is available for viewing on our website, www.hsccltd.co.in

Executive Director (Proc & PG-1)

INSTRUCTIONS TO APPLICANTS

NAME OF PROJECT : “HVAC, Clean room and allied works for Microbiology lab for Food & drug Testing Laboratory Mumbai.”

EMPLOYER / PRINCIPAL EMPLOYER : **Director Food & Drug Testing Laboratory Mumbai.**

1.0 Scope of Bid :

For & on behalf of “Ministry of Health & Family Welfare Nirman Bhavan, New Delhi” (The Employer/Principal Employer), **HSCC (India) Ltd.** (the Consultant) intends to pre-qualify contractors/firms for the following works.

Sl. No.	Name of Work	Estimated Cost (Rs.)	Bid Security (Rs.)	Cost of document (Rs.)	Period of Completion
1	“HVAC, Clean room and allied works for Microbiology lab for Food & drug Testing Laboratory Mumbai”	45 lakhs	90000/-	3000.00	2.5 Months

1.1 **The Scope of work relates to** “HVAC, Clean room and allied works for Microbiology lab for Food & drug Testing Laboratory Mumbai and their maintenance during defect liability period and obtaining local statutory approvals if any from the concerned authorities.

1.2 Prequalification is open to all firms having sound background and specialization in carrying out similar works.

2.0 Submission of Applications:

2.1 Application for prequalification complete in all respect must be submitted in sealed envelopes, which must be either delivered by hand or by registered mail to **HSCC (India) Ltd**, Plot 6A, Block-E, Sector-1, Noida-201301, so as to reach not later than 15.00 hours on 13.06.2007.

2.2 The name and mailing address of the Applicant should be clearly marked on the envelope.

2.3 Failure to provide information in the stipulated format enclosed or to provide timely clarification or substantiation of the information supplied (considered essential to evaluate the Applicant's qualifications) may result in disqualification of the Applicant.

3. Pre-qualification Criteria:

3.1 Pre-qualification will be based on meeting the following criteria regarding the Applicant's work experience, personnel and equipment capabilities, and financial position, as demonstrated by the Applicant's responses in the forms attached to the Letter of Application.

3.2 The Applicant should meet the following minimum criteria for pre-qualification:

- (a) Average annual turnover during the last three years [2005-2006, 2006-2007, 2007-2008 of Rs. 65 lakhs.
 - (b) The experience of having successfully completed similar works during last 7 years ending last day of month previous to the one in which applications are invited should be either of the following: -
 - i) Three similar completed works each costing not less than the amount equal to 18 Lakh.
 - ii) Two similar completed works each costing not less than the amount equal to 22.50 Lakh. .
 - iii) One similar completed work costing not less than the amount equal to 36 Lakh.
 - (c) Minimum solvency certificate from banker for the sum of Rs 45 Lakh.
 - (e) The firm should have positive net worth in last three financial years.
- 3.3 Personnel Capabilities: The Applicant must have suitably qualified personnel to execute the contract.(Applicant to fill enclosed ANNEXURE - III).
- 3.4 Equipment Capabilities: The Applicant should own, or have assured access to (through hire, lease, purchase agreement or other means) equipment to successfully execute the contract.(Applicant to fill enclosed ANNEXURE -IV).
- 3.5 Financial Capabilities: The Audited Balance Sheets for the last three years (2005-06, 2006-07 & 2007-08,) should be submitted and must demonstrate the soundness of the Applicant's financial position. Where necessary, the Consultant (HSCC) on behalf of Employer will make inquiries with the Applicant's bankers (Applicant to fill enclosed ANNEXURE-V).
- 3.6 The bidder shall submit the supporting documents regarding the information given in the ANNEXURE - I to ANNEXURE - V.
- 3.7 Even though the applicants meet the above criteria, they are subject to be disqualified if they have:
- (a) made misleading or false representation in the form, statements and attachments submitted; in proof of the qualification requirements, and for
 - (b) record of poor performance such as abandoning the work, not properly completing the contract, inordinate delays in completion, litigation history, or financial failures, etc. and/or

The applicants are also subject to be disqualified, if they are found black listed.

- 3.8 The applicants are advised to visit the site to get first hand information as regards its approach, accessibility, working conditions, site conditions, availability of labour and material etc. and other matters affecting cost and work. All costs incurred in connection with submission of the pre qualification bid shall be borne by the applicant irrespective of the outcome.

4.0 **General :**

- 4.1 Only contractor/firms, whose bid is found to be generally in order, meets the pre qualification criteria and substantially responsive shall be opened either at the Bid opening or at a subsequent date to be intimated in advance to such eligible Bidders.

4.2 The Consultant reserves the right to:

- (a) accept or reject any Bid including the lowest and to annul the Bidding process and reject all Bids, at any time prior to Award of Contract, without thereby incurring any liability to the affected Bidder or Bidders or any obligations to inform the affected Bidder or Bidders of the grounds for the Employer's/Engineer's action.

The Employer/ Consultant shall neither be liable for any such actions nor be under any obligation to inform the Applicants.

LETTER OF APPLICATION

[NOTE : On the letterhead of the Applicant including full postal address, telephone no., fax no., telex no., and cable address]

Date:

To

The General Manager (PG-1)
HSCC (India) Ltd
Plot No 6(A) , Block E, Sector - 1
NOIDA (U.P.)

Sirs,

1. Being duly authorised to represent and act on behalf of
(hereinafter referred to as "the Applicant"), and having reviewed and fully understood all the pre-qualification information provided, the undersigned hereby apply to be pre-qualified by yourselves as a bidder for the **"HVAC, Clean room and allied works for Microbiology lab for Food & drug Testing Laboratory Mumbai "**.

Tender Number	Client name
HSCC/139/PM/-HVAC-F&D Mumbai/2008	"HVAC, Clean room and allied works for Microbiology lab for Food & drug Testing Laboratory Mumbai".

2. Attached to this letter are copies or original documents defining:

- (a) the Applicant's legal status;
- (b) the principle place of business; and
- (c) the place of incorporation (for applicants who are corporations); or the place of registration and the nationality of the owners (for applicants who are partnerships or individually-owned firms).
- (d) Application form no.1 to 8.
- (e) Copies of orders & Clients certificates for successful & timely completion in respect of minimum pre qualification criteria clauses 3.2(b) & 3.2(c).

3. Your agency and its authorized representatives are hereby authorized to conduct any inquiries or investigations to verify the statements, documents, and information submitted in connection with this application and to seek clarification from our bankers and clients regarding any financial and technical aspects. This Letter of Application will also serve as authorization to any individual or authorized representative or any institution referred to in the supporting information, to provide such information deemed necessary and requested by yourselves to verify statements and information provided in this application, or with regard to the resources, experience, and competence of the Applicant.

4. Your Agency and its authorized representatives may contact the following persons for further information:

General, Personnel, Technical and Financial Enquiries	
Contact 1 :	Telephone 1 :
Contact 2 :	Telephone 2 :

5. This application is made in the full understanding that :

- (a) bids submitted by applicants will be subject to verification of all information submitted for pre-qualification;
 - (b) HSCC reserves the right to :
 - (i) amend the scope and value of the contract/bid under this project; in such event, bids will only be called from pre-qualified bidders who meet the revised requirements; and
 - (ii) Reject or accept any application, cancel the pre-qualification / tender process, and reject all applications without assigning any reason thereof; and
 - (c) HSCC shall not be liable for any such actions and shall be under no obligation to inform the Applicant.
6. Appended to this application, details of participation of each party, including capital contribution and profit/loss agreements, to the joint venture or association. We also specify the financial commitment in terms of the percentage of the value of the contract, and the responsibilities for execution of the contract.
7. The undersigned declare that statements made and the information provided in the duly completed application are complete, true, and correct in every detail.

Signed :
Name :
For and on behalf of :

Application Form No. 1

GENERAL INFORMATION

All individual firms applying for tender are requested to complete the information required for pre qualification in this form. Information to be provided for all owners or applicants who are partnerships or individually-owned firms:

1.	Name of firm:
2.	Head office address:
3.	Telephone : Contact person :
4.	Fax : Telex :
5.	Place of incorporation/ Registration : Year of incorporation/ registration :

Signed :
Name :
For and on behalf of :

Application Form no. 2

STRUCTURE AND ORGANIZATION

1. The applicant is _____
(a) an individual
(b) a proprietor firm
(c) a firm in partnership
(d) a Limited Company or Corporation.

2. Attach the Organization Chart showing the structure of the organization, including the names of the Directors and position of officers. _____

3. Have you ever left any work awarded to you incomplete? _____
(If so, give name of project and reasons for not completing the work.)

Signed :
Name :
For and on behalf of :

Application Form No. 3

ANNUAL TURN OVER

Year	Annual Turn Over in Indian Rs. as per Audited Balance Sheet or CA certificate
2005-06	Rs.
2006-07	Rs.
2007-08	Rs.
Average Annual Turn Over during the above last three years	Rs.

NOTE : The above data is to be supported by Audited Balance Sheets. in case, the Audited Balance Sheet is not available, the provisional Balance Sheet duly certified by Chartered Accountant is to be submitted.

Application Form No. 4

DETAILS OF COMPLETED WORKS OF SIMILAR NATURE AND COMPLEXITY

(During last Seven years i.e, 2001-2002, 2002-2003, 2003-2004, 2004-2005, 2005-2006, 2006-2007 & 2007-2008)

Sl. No.	Project Name	Name of Employer	Brief description of the work. Contract No. & Value of the project	Date of issue of work order	Date of Completion as per contract	Date of actual Completion	Reasons for delay
1.							
2.							
3.							
4.							
5.							

NOTE :

- 1 Please attach supporting documents for the above information and satisfactory completion certificates from clients.**
- 2 If the completion time/Project value is more than requirement, pro-rata value shall be considered for evaluation.**

Application Form No. 5

PERSONNEL CAPABILITIES

Sl. No.	Name	Qualifications	Date of Employment	Position	Years of experience in the proposed position

Application Form No. 6

EQUIPMENT CAPABILITIES

Sl. No.	Particulars of Equipments, Machineries, Tools and Plant etc. owned by applicant	Quantity	Approximate Value
1	2	3	4
1.			
2.			
3.			
4.			
5.			
6.			
7.			
8.			
9.			
10.			

Application Form No. 7**FINANCIAL CAPABILITIES**

Financial Information in Rs. equivalent	For year 2005-06	For year 2006-07	For year 2007-08
1. Total Assets			
2. Current Assets			
3. Total Liabilities			
4. Current Liabilities			
5. Profit before Tax			
6. Profit after Tax			
7. Net Worth			
8. Liquid Assets			
9. Solvency Certificate from Banker			

- 1. Attach audited balance sheets for all last three years (2005-06,2006-07, 2007-08).**
- 2. Attach recent Solvency Certificate from Banker not older than 12 months.**

Application Form No. 8

Information on Litigation history in which the bidder is involved:

Sl. No.	Other parties	Employer	Course of dispute	Amount involved
1	2	3	4	5
1.				
2.				
3.				
4.				
5.				
6.				
7.				
8.				
9.				
10.				

**CENTRAL FOOD & DRUG TESTING LABORATORY
MUMBAI**

**TENDER
FOR**

**HVAC, CLEAN ROOM AND ALLIED WORKS FOR
MICROBIOLOGY LAB FOR FOOD & DRUG
TESTING LABORATORY MUMBAI**

VOLUME - II

**GENERAL CONDITIONS OF CONTRACT
December 2008**

HSCC (INDIA) LTD.

(Consultants & Engineers for Mega Hospitals & Laboratories)
E - 6 (A), Sector - I, NOIDA (U.P.) - 201 301 (INDIA)

PHONE : 91-2542436, 2542440
91-2542443, 2542445

FAX : 91-11-91-2542447
E- mail : hsccltd @hsccltd.co.in

Tender No **HSCC/139/PM/-HVAC-F&D Mumbai/2008**

INDEX

GENERAL CONDITIONS OF CONTRACT

Clause No.	Descriptions
Definitions and Interpretation	
1.1	Definitions
1.2	Headings and Marginal Notes
1.3	Interpretation
1.4	Singular and Plural
1.5	Notices, Consents, Approvals, Certificates and Determinations
Engineer and Engineer's Representative	
2.1	Engineer's Duties and Authority
2.2	Engineer's Representative
2.3	Communication Given by Engineer's Representative
2.4	Appointment of Assistants
2.5	Instructions in writing
2.6	Engineer to Act Impartially
Assignment and Subcontracting	
3.1	Assignment of Contract
4.1	Subcontracting
Contract Documents	
5.1	Language/s and Law
5.2	Priority of Contract Documents
6.1	Custody and Supply of Drawings and Documents
6.2	One Copy of Drawings to be kept on Site
6.3	Disruption of Progress
6.4	Delays and Cost of Delay of Drawings
6.5	Failure by Contractor to Submit Drawings

Clause No.	Descriptions
7.1	Supplementary Drawings and Instructions
7.2	Permanent Works Designed by Contractor
7.3	Responsibility Unaffected by Approval
General Obligations	
8.1	Contractor's General Responsibilities
8.2	Site Operations and Methods of Construction
9.1	Contract Agreement
10.1	Performance Security
10.2	Period of Validity of Performance Security
10.3	Cost of securities
11.1	Inspection of Site
12.1	Sufficiency of Tender
12.2	Adverse Physical Obstructions or Conditions
13.1	Work to be in Accordance with Contract
14.1	Programme to be Submitted
14.2	Revised programme
14.3	Cash Flow Estimate to be Submitted
14.4	Contractor not Relieved of Duties or Responsibilities
15.1	Contractor's Superintendence
16.1	Contractor's Employees
16.2	Engineer at Liberty to Object
17.1	Setting - out
18.1	Boreholes and Exploratory Excavation
19.1	Safety, Security and Protection of the Environment
20.1	Care of Works
20.2	Responsibility to Rectify Loss or Damage
20.3	Loss or Damage Due to Employer's Risks
20.4	Employer's Risks

Clause No.	Descriptions
21.1	Insurance of Works and Contractor's Equipment
21.2	Scope of Cover
21.3	Responsibility for Amounts not Recovered
21.4	Exclusions
22.1	Damage to Persons and Property
22.2	Exceptions
22.3	Indemnity by Employer
23.1	Third party Insurance (including Employer's Property)
23.2	Minimum Amount of Insurance
23.3	Cross Liabilities
24.1	Accident or Injury to Workmen
24.2	Insurance Against Accident to Workmen
25.1	Evidence and Terms of Insurance
25.2	Adequacy of Insurance
25.3	Remedy on Contractor's Failure to Insure
25.4	Compliance with Policy Conditions
26.1	Compliance with Statutes, Regulations
27.1	Fossils
28.1	Patent Rights
28.2	Royalties
29.1	Interference with Traffic and Adjoining Properties
30.1	Avoidance of Damage to Roads
30.2	Transport of Contractor's Equipment or Temporary Works
30.3	Transport of Materials or Plant
30.4	Waterborne Traffic
31.1	Opportunities for other contractors
31.2	Facilities for other Contractors
32.1	Contractor to Keep Site Clear
33.1	Clearance of Site on Completion
34.1	Labour

Clause No.	Descriptions
35.1	Returns of Labour, etc. Materials, Plant and Workmanship
36.1	Quality of Materials, Plant and Workmanship
36.2	Cost of Samples
36.3	Cost of Test
36.4	Cost of Tests not Provided for
36.5	Engineer's Determination where Tests not Provided for
37.1	Inspection of Operations
37.2	Inspection and Testing
37.3	Dates for Inspection and Testing
37.4	Rejection
37.5	Independent Inspection
38.1	Examination of Work before Covering up
38.2	Uncovering and Making Openings
39.1	Removal of Improper Work, Materials or Plant
39.2	Default of Contractor in Compliance
	Suspension
40.1	Suspension of work
40.2	Engineer's Determination following Suspension
40.3	Suspension lasting more than 84 days
	Commencement and Delays
41.1	Commencement of Works
42.1	Possession of Site and Access Thereto
42.2	Failure to Give Possession
42.3	Wayleaves and Facilities
43.1	Time for Completion
44.1	Extension of Time for Completion
44.2	Contractor to Provide Notification and Detailed Particulars
44.3	Interim Determination of Extension

Clause No.	Descriptions
-------------------	---------------------

- 45.1 Restriction on Working Hours
- 46.1 Rate of Progress
- 47.1 Liquidated Damages for Delay
- 47.2 Reduction of Liquidated Damages
- 48.1 Taking over Certificate
- 48.2 Taking over of Sections or Parts
- 48.3 Substantial Completion of Parts
- 48.4 Surfaces Requiring Reinstatement

Defects Liability

- 49.1 Defects Liability Period
- 49.2 Completion of Outstanding Work and Remedying Defects
- 49.3 Cost of Remedying Defects
- 49.4 Contractor's Failure to Carry Out Instructions
- 50.1 Contractor to Search

Alterations, Additions and Omissions

- 51.1 Variations
- 51.2 Instructions for Variations
- 52.1 Valuation of Variations
- 52.2 Power of Engineer to Fix Rate
- 52.3 Variations Exceeding 25 percent
- 52.4 Daywork

Procedure for Claims

- 53.1 Notice of Claims
- 53.2 Contemporary Records
- 53.3 Substantiation of Claims
- 53.4 Failure to Comply
- 53.5 Payment of Claims

Clause No.	Descriptions
------------	--------------

Contractor's Equipment, Temporary Works and Materials

54.1	Contractor's Equipment, Temporary Works and Materials; Exclusive Use for the Works
54.2	Employer not Liable for Damage
54.3	Customs Clearance
54.4	Re-export of Contractor's Equipment
54.5	Conditions of Hire Contractor's Equipment
54.6	Costs for the purpose of clause - 63.1 to 63.4
54.7	Corporation of Clause in subcontracts
54.8	Approval of Materials not Implied

Measurement

55.1	Quantities
56.1	Works to be Measured
57.1	Method of Measurement
57.2	Breakdown of Lump Sum Items

Provisional Sums

58.1	Definition of "Provisional Sum"
58.2	Use of Provisional Sums
58.3	Production of Vouchers

Nominated Subcontractors

59.1	Definition of "Nominated Subcontractors"
59.2	Nominated Subcontractors; Objection to Nomination
59.3	Design Requirements to be Expressly Stated
59.4	Payments to Nominated Subcontractors
59.5	Certification of Payments to Nominated Subcontractors

Certificates and Payment

60.1	Monthly Statements
60.2	Monthly Payments
60.3	Materials and plant for the permanent works

Clause No.	Descriptions
-------------------	---------------------

60.4	Place of payment
60.5	Retention money
60.6	Payment of retention money
60.7	Advance payment
60.8	Time of payment
60.9	Correction of Certificates
60.10	Statement of completion
60.11	Final Statement
60.12	Discharge
60.13	Final Certificate
60.14	Cessation of Employer's Liability

61.1 Defects Liability Certificate

62.1 Unfulfilled Obligations

Remedies

63.1	Default of Contractor
63.2	Valuation at Date of Expulsion
63.3	Payments after Expulsion
63.4	Assignment of Benefit of Agreement

64.1 Urgent Remedial Works

Special Risks

65.1	No Liability for Special Risks
65.2	Special Risks
65.3	Damage to Works by Special Risks
65.4	Projectile, Missile
65.5	Increased Costs arising from Special Risks
65.6	Outbreak of War
65.7	Removal of Contractor's Equipment on Termination
65.8	Payment if Contract Terminated

Release from Performance

66.1 Payment in Event of Release from Performance

Clause No.**Descriptions**

Settlement of Disputes

- 67.1 Engineer's Decision
- 67.2 Conciliation
- 67.3 Arbitration
- 67.4 Failure to Comply with Engineer's Decision

Notices

- 68.1 Notice to Contractor
- 68.2 Notice to Employer and Engineer
- 68.3 Change of Address

Default of Employer

- 69.1 Default of Employer
- 69.2 Removal of Contractor's Equipment
- 69.3 Payment on Termination
- 69.4 Contractor's Entitlement to Suspend Works

Changes in Cost and Legislation

- 70.1 Increase or Decrease of Cost
- 70.2 Subsequent Legislation
- 70.3 Other Changes in Cost

- 71.1 Engineer's Authority to Correct Errors

ANNEXURE - A Proforma of Indenture for Secured Advance or Credit

ANNEXURE - B Appendix to Tender

GENERAL CONDITIONS OF CONTRACT

Definitions and Interpretation

1.1 Definitions

In the Contract (as hereinafter defined) the following words and expressions shall have the meanings hereby assigned to them except where the context otherwise requires:

- (a) i. "Employer" means the person named as such in Volume - III of these Conditions and the legal successors in title to such person, but not (except with the consent of the Contractor) any assignee of such person.
- ii. "Consultant" means the HSCC (India) Ltd. known as Chairman-Cum- Managing Director, HSCC, and his successors in office and assignees acting for and on behalf of the employer.
- iii. "Engineer" means the person appointed by HSCC to act as Engineer for the purposes of the contract and named as such in Part III of these Conditions.
- iv. "Engineer's Representative" means a person appointed from time to time by the Engineer under Sub-Clause 2.2.
- v. "Contractor" means an individual or firms (proprietary or partnership) whether incorporated or not, that has entered into contract (with the employer) and shall include his / its heirs, legal representatives, successors and assigns, successors in interest of individuals or persons. Composing such firms or successors of such firms or the permitted assigns of such individual or firms. Changes in the constitution of the firm, if any shall be immediately notified to the employer, in writing and approval obtained for continued performance of the contract.
- vi. "Subcontractor" means any person named in the Contract as a Subcontractor for a part of the Works or any person to whom a part of the Works has been subcontracted by the contractor with the consent of the Engineer and the legal successors in title to such person, but not any assignee of any such person.

- (b)
 - i. "Contract" means these conditions (Volume II and III), the Specification, the Drawings, the Bill of Quantities, the Tender, the Letter of Acceptance, the Contract Agreement (if completed) and such further documents as may be expressly incorporated in the Letter of Acceptance or Contract Agreement (if completed).
 - ii. "Specification" means the specification of the Works included in the Contract and any modification thereof or addition thereto made under Clause 51.1 & 51.2 or submitted by the Contractor and approved by the Engineer.
 - iii. "Drawings" means all drawings, calculations and technical information of a like nature provided by the Engineer to the Contractor under the Contract and all drawings, calculations, samples, patterns, models, operation and maintenance manuals and other technical information of a like nature submitted by the Contractor and approved by the Engineer.
 - iv. "Bill of Quantities" means the priced and completed bill of quantities forming part of the Tender.
 - v. "Tender" means the Contractor's priced offer to the Employer for the execution and completion of the Works and the remedying of any defects therein in accordance with the provisions of the Contract, as accepted by the Letter of Acceptance. The word Tender is synonymous with "Bid" and the words "Tender Documents" with "Bidding Documents".
 - vi. "Letter of Acceptance" means the formal acceptance by the HSCC of the Tender.
 - vii. "Contract Agreement" means the contract agreement (if any) referred to in Sub-Clause 9.1.
 - viii. "Appendix to Tender" means the appendix comprised in the form of Tender annexed to these Conditions.
- (c)
 - i. "Commencement Date" means the date upon which the Contractor receives the notice to commence the works as issued by the Engineer pursuant to Clause 41.1.

- ii. "Time for Completion" means the time for completing the execution of and passing the Tests on Completion of the Works or any Section or part thereof as stated in the Contract (or as extended under Clause 44.1, 44.2 & 44.3) calculated from the Commencement Date.
- (d)
 - i. "Tests on Completion" means the tests specified in the Contract or otherwise agreed by the Engineer and the Contractor which are to be made by the Contractor before the Works or any Section or part thereof are taken over by the employer.
 - ii. "Taking-Over Certificate" means a certificate issued pursuant to Clause 48.1 to 48.4.
- (e)
 - i. "Contract Price" means the sum stated in the Letter of Acceptance as payable to the Contractor for the execution and completion of the Works and the remedying of any defects therein in accordance with the provisions of the Contract.
 - ii. "Retention Money" means the aggregate of all monies retained by the Employer pursuant to Sub-Clause 60.1 (h) or 60.5.
- (f)
 - i. "Works" means the Permanent Works and the Temporary Works or either of them to be executed in accordance with the contract .
 - ii. "Permanent Works" means the permanent works to be executed (including Plant) in accordance with the Contract.
 - iii. "Temporary Works" means all temporary works of every kind (other than Contractor's Equipment) required in or about the execution and completion of the Works and the remedying of any defects therein.
 - iv. "Plant" means machinery, apparatus and the like intended to form or forming part of the Permanent Works.
 - v. "Contractor's Equipment" means all appliances and things of whatsoever nature (other than Temporary Works) required for the execution and completion of the Works and the remedying of any defects therein, but does not include Plant, materials or other things intended to form or forming part of the Permanent Works.

- vi. "Section" means a part of the Works specifically identified in the Contract as a Section.
 - vii. "Site" means the places provided by the Employer where the Works are to be executed and any other places as may be specifically designated in the Contract as forming part of the Site.
- (g) i. "Cost" means all expenditure properly incurred or to be incurred, whether on or off the Site, including over head and other charges properly allowable there but does not include any allowance for profit.

1.2 Heading and Marginal Notes

The headings and marginal notes in these Conditions shall not be deemed part thereof or be taken into consideration in the interpretation or construction thereof or of the Contract.

1.3 Interpretation

Words importing persons or parties shall include firms and corporations and any organisation having legal capacity.

1.4 Singular and Plural

Words importing the singular only also include the plural and vice versa where the context requires.

1.5 Notices, Consents, Approvals, Certificates and Determinations.

Wherever in the Contract provision is made for the giving or issue of any notice, consent, approval, certificate or determination by any person, unless otherwise specified such notice, consent, approval, certificate or determination shall be in writing and the words "notify", "certify" or "determine" shall be construed accordingly.

ENGINEER AND ENGINEER'S REPRESENTATIVE

2.1 Engineer's Duties and Authority

- (a) The Engineer shall carry out the duties specified in the Contract.
- (b) The Engineer may exercise the authority specified in or necessarily to be implied from the Contract, provided, however,

that if the Engineer is required, under the terms of his appointment by the Employer, to obtain the specific approval of the Employer before exercising any such authority particulars of such requirement shall be set out in part II of these Conditions. Provided further that any requisite approval shall be deemed to have been given by the Employer for any such authority exercised by the Engineer.

2.2 Engineer's Representative

- (a) The Engineer's Representative shall be appointed by and be responsible to the Engineer and shall carry out such duties and exercise such authority as may be delegated to him by the Engineer under Sub-Clause 2.2 (b).

Engineer's Authority to Delegate

- (b) The Engineer may from time to time delegate to the Engineer's Representative any of the duties and authorities vested in the Engineer and he may at any time revoke such delegation. Any such delegation or revocation shall be in writing and shall not take effect until a copy thereof has been delivered to the Contractor.

2.3 Communication Given by Engineer's Representative

Any communication given by the Engineer's Representative to the Contractor in accordance with such delegation shall have the same effect as though it had been given by the Engineer. Provided that :

- (a) any failure of the Engineer's Representative to disapprove any work, materials or Plant shall not prejudice the authority of the Engineer to disapprove such work, materials or Plant and to give instructions for the rectification thereof;
- (b) if the Contractor questions any communications of the Engineer's Representative he may refer the matter to the Engineer who shall confirm, reverse or vary the contents of such communication.

2.4 Appointment of Assistants

The Engineer or the Engineer's Representative may appoint any number of persons to assist the Engineer's Representative in the carrying out of his duties under Sub-Clause 2.2. He shall notify to the Contractor the names, duties and scope of authority of such persons. Such assistants shall have no authority to issue any instructions to the Contractor save in so far as such instructions may be necessary to enable them to carry out their duties and to secure their acceptance of materials, Plant or

workmanship as being in accordance with the Contract, and any instructions given by any of them for those purposes shall be deemed to have been by the Engineer's Representative.

2.5 Instructions in Writing

Instructions given by the Engineer shall be in writing, provided that if for any reason the Engineer considers it necessary to give any such instruction orally, the Contractor shall comply with such instruction. Confirmation in writing of such oral instruction given by the Engineer, whether before or after carrying out of the instruction shall be deemed to be an instruction, within the meaning of this Sub-Clause. Provided further that if the Contractor, within 7 days, confirms in writing to the Engineer any oral instruction of the Engineer and such confirmation is not contradicted in writing within 7 days by the Engineer, it shall be deemed to be an instruction of the Engineer.

The provisions of this Sub-Clause shall equally apply to instructions given by the Engineer's Representative and any assistants of the Engineer or the Engineer's Representative appointed pursuant to Sub-Clause 2.4.

2.6 Engineer to Act Impartiality

Wherever, under the Contract, the Engineer is required to exercise his discretion by:

- (a) giving his decision, opinion or consent, or
- (b) expressing his satisfaction or approval, or
- (c) determining value, or
- (d) otherwise taking action which may affect the rights and obligations of the Employer or the Contractor he shall exercise such discretion impartially within the terms of the Contract and having regard to all the circumstances. Any such decision, opinion, consent, expression of satisfaction, or approval, determination of value or action may be opened up, reviewed or revised as provided in Clause 67.1 to 67.4.

ASSIGNMENT AND SUBCONTRACTING

3.1 Assignment of Contract

The Contractor shall not, without the prior consent of the Consultant (which consent, shall be at the sole discretion of the Consultant), assign the Contract or any part thereof, or any benefit or interest therein or thereunder, otherwise than by:

- (a) a charge in favour of the Contractor's bankers of any monies due or to become due under the Contract, or
- (b) assignment to the Contractor's insurers (in cases where the insurers have discharged the Contractor's loss or liability) of the Contractor's right to obtain relief against any other party liable. The provision of labour as piece work basis shall not be deemed to be subcontracting under this clause.

4.1 Sub-Contracting

The Contractor shall not subcontract the total project Work to any sub contractor. The Contractor may subcontract only part of the works with the prior consent of the Engineer (which consent shall be at the sole discretion of the Engineer). While subcontracting, the contractor will consider the parties / agencies depending upon their capabilities and get the works implemented under his own overall supervision. However this shall not relieve the Contractor from any liability or obligation under the Contract and he shall be responsible for the acts, defaults and neglects of a Subcontractor, his agents, servants or workmen as if they were the acts, defaults or neglects of the Contractor, his agents, servants or workmen.

Provided that the Contractor shall not be required to obtain such consent for:

- (a) the provision of labour,
- (b) the purchase of materials which are in accordance with the standards specified in the Contract.

CONTRACT DOCUMENTS

5.1 Language/s and Law

- (a) The language in which the Contract documents shall be drawn up, is English.

- (b) The country the law of which shall apply to the Contract and according to which the Contract shall be construed is India.

5.2 Priority of Contract Documents

The Bill of Quantities is to be read in conjunction with the Tender drawings, Conditions of Contract, specifications, as these documents are jointly explanatory and descriptive of the works included in the Contract. In case of discrepancy between the schedule of quantities, the specifications and or the drawings, the following order of preference shall be followed:

- (1) Description of Schedule of Quantities
- (2) Particular specification and special condition, if any
- (3) Drawings
- (4) C.P.W.D Specifications
- (5) Indian Standard specifications of B.I.S

6.1 Custody and Supply of Drawings and Documents

The Drawings shall remain in the sole custody of the Engineer, but two copies thereof shall be provided to the Contractor free of charge. The Contractor shall make at his own cost any further copies required by him. Unless it is strictly necessary for the purposes of the Contract, the Drawings, Specification and other documents provided by the Employer or the Engineer shall not, without the consent of the Engineer, be used or communicated to a third party by the Contractor. Upon issue of the Defects Liability Certificate (Clause 62.1), the Contractor shall return to the Engineer all Drawings, Specifications and other documents provided under the Contract.

The Contractor shall supply to the Engineer four copies of all Drawings, Specifications and other documents submitted by the Contractor and approved by the Engineer in accordance with Clause 7.1 to 7.3, together with a reproducible copy of any material which cannot be reproduced to an equal standard by photocopying. In addition the Contractor shall supply such further copies of such Drawings, Specification and other documents as the Engineer may request in writing for the use of the Employer, who shall pay the cost thereof.

6.2 One Copy of Drawings to be kept on Site

One copy of the Drawings, provided to or supplied by the Contractor as

aforesaid, shall be kept by the Contractor on the Site and the same shall at all reasonable times be available for inspection and use by the Engineer and by any other person authorised by the Engineer in writing.

6.3 Disruption of Progress

The Contractor shall give notice to the Engineer, whenever planning or execution of the Works is likely to be delayed or disrupted unless any further drawing or instruction is issued by the Engineer within 60 days or such other reasonable time as may be decided by the Engineer. The notice shall include details of the drawing or instruction required and of why and by when it is required and of any delay or disruption likely to be suffered if it is late.

6.4 Delay and Cost of Delay of Drawings

If, by reason of any failure or inability of the Engineer to issue, within a time reasonable in all the circumstances, any drawing or instruction for which notice has been given by the Contractor in accordance with Sub-Clause 6.3, the Contractor suffers delay then the Engineer shall, after due consultation with the Employer and the Contractor, determine any extension of time to which the Contractor is entitled under Clause 44.1 to 44.3 .

6.5 Failure by Contractor to Submit Drawings

If the failure or inability of the Engineer to issue any drawings or instructions is caused in whole or in part by the failure of the Contractor to submit Drawings, Specification or other documents which he is required to submit under the Contract, the Engineer shall take such failure by the Contractor into account when making his determination pursuant to Sub-Clause 6.4.

7.1 Supplementary Drawings and Instructions

The Engineer shall have authority to issue to the Contractor, from time to time, such supplementary Drawings and instructions as shall be necessary for the purpose of the proper and adequate execution and completion of the Works and the remedying of any defects therein. The Contractor shall carry out and be bound by the same.

7.2 Permanent Works Designed by Contractor

Where the Contract expressly provides that part of the Permanent Works shall be designed by the Contractor, he shall submit to the Engineer, for approval:

- (a) such drawings, specifications, calculations and other information as shall be necessary to satisfy the Engineer as to the suitability and adequacy of that design, and
- (b) Operation and maintenance manuals together with drawings of the relevant part of the Permanent Works as completed, in sufficient detail to enable the Employer to operate, maintain, dismantle, reassemble and adjust the Permanent Works incorporating that design. The Works shall not be considered to be completed for the purposes of taking over in accordance with Clause 48.1 to 48.4 until such operation and maintenance manuals, together with drawings on completion, have been submitted to and approved by the Engineer.

7.3 Responsibility Unaffected by Approval

Approval by the Engineer, in accordance with Sub-Clause 7.2, shall not relieve the Contractor of any of his responsibilities under the Contract.

GENERAL OBLIGATIONS

8.1 Contractor's General Responsibilities

The Contractor shall, with due care and diligence, design (to the extent provided for by the Contract), execute and complete the Works and remedy any defects therein in accordance with the provisions of the Contract. The Contractor shall provide all superintendence, labour, materials, Plant, Contractor's Equipment and all other things, whether of a temporary or permanent nature, required in and for such design, execution, completion and remedying of any defects, so far as the necessity for providing the same is specified in or is reasonably to be inferred from the Contract. The contractor shall promptly notify the Employer and the Engineer of any error, omission, fault or any other defect in the design of or specifications for the works which he discovers when reviewing the contract documents or in the process of execution of the works.

8.2 Site Operations and Methods of Construction

The Contractor shall take full responsibility for the adequacy, stability and safety of all Site operations and methods of construction. Provided that the Contractor shall not be responsible (except as stated hereunder or as may be otherwise agreed) for the design or specification of Permanent Works, or for the design or specification of any Temporary Works not prepared by the Contractor. Where the Contract expressly provides that part of the Permanent Works shall be designed by the Contractor, he shall be fully responsible for that part of such Works, notwithstanding any

approval by the Engineer.

9.1 Contract Agreement

The Contractor shall, if called upon so to do, enter into and execute the Contract Agreement, to be prepared and completed at the cost of the Contractor, in the form annexed to these Conditions with such modification as may be necessary.

10.1 Performance Security

The Contractor shall provide security for his proper performance of the Contract to the Employer within 7 days after the receipt of the Letter of Acceptance. The performance security shall be in the form of bank guarantee. The amount of the bank guarantee shall be 5 percent of the Contract Price. It shall be issued by a Nationalised bank/scheduled bank. When providing such security to the Employer, the Contractor shall notify the Engineer of so doing.

Without limitation to the provisions of the preceding paragraph, whenever the Engineer determines an addition to the Contract Price as a result of a change in cost and/or legislation or as a result of a variation amounting to more than 25 percent of the Contract Price, the Contractor, at the Engineer's written request, shall promptly increase the value of the performance security by an equal percentage.

Failure of the successful bidder to lodge the required bank guarantee shall constitute sufficient grounds for the annulment of the award and forfeiture of the bid security, in which event the Engineer may make the award to the next lowest evaluated bidder or, if there are no other bidders, call for new bids.

10.2 Period of Validity of Performance Security

The performance security shall be valid until the Contractor has executed and completed the Works and remedied any defects therein in accordance with the Contract. No claim shall be made against such security after the issue of the Defects Liability Certificate in accordance with Sub-Clause 62.1 and such security shall be returned to the Contractor within 14 days of the issue of the said Defects Liability Certificate.

10.3 Costs of Securities

The cost of complying with the requirements of this clause shall be borne by the Contractor.

11.1 Inspection of Site

The Contractor shall be deemed to have inspected and examined the Site and its surroundings and information available in connection therewith and to have satisfied himself (so far as is practicable, having regard to considerations of cost and time) before submitting his Tender, as to:

- (a) the extent and nature of work and materials necessary for the execution and completion of the Works and the remedying of any defects therein, and
- (b) the means of access to the Site and the accommodation he may require.

And in general, shall be deemed to have obtained all necessary information, subject as above mentioned, as to risks, contingencies and all other circumstances which may influence or affect his Tender.

12.1 Sufficiency of Tender

The Contractor shall be deemed to have based his Tender on the data made available by the Consultant and on his own inspection and examination, all as aforementioned.

The Contractor shall be deemed to have satisfied himself as to the correctness and sufficiency of the Tender and of the rates and prices stated in the Bill of Quantities, all of which shall, except insofar as it is otherwise provided in the Contract, cover all his obligations under the Contract (including those in respect of the supply of goods, materials, Plant or services or of contingencies for which there is a Provisional Sum) and all matters and things necessary for the proper execution and completion of the Works and the remedying of any defects therein.

12.2 Adverse Physical Obstructions or Conditions

If, however, during the execution of the Works the Contractor encounters physical obstructions or physical conditions, other than climatic conditions on the Site, which obstructions or conditions were, in his reasonable opinion, not foreseeable by an experienced contractor, the Contractor shall forthwith give notice thereof to the Engineer. On receipt of such notice, the Engineer shall, if in his opinion such obstructions or conditions could not have been reasonably foreseen by an experienced contractor, after due consultation with the Contractor, determine:

- (a) any extension of time to which the Contractor is entitled under Clause 44.1 to 44.3 and

- (b) the amount of any costs which may have been incurred by the Contractor by reason of such obstructions or conditions having been encountered, which shall be added to the Contract Price.

And shall notify the Contractor accordingly. Such determinations shall take account of any instruction, which the Engineer may issue to the Contractor in connection therewith, and any proper and reasonable measures acceptable to the Engineer, which the Contractor may take in the absence of specific instructions from the Engineer.

13.1 Work to be in Accordance with Contract

Unless it is legally or physically impossible, the Contractor shall execute and complete the Works and remedy any defects therein in strict accordance with the Contract to the satisfaction of the Engineer. The Contractor shall comply with and adhere strictly to the Engineer's instructions on any matter, whether mentioned in the Contract or not, touching or concerning the Works. The Contractor shall take instructions only from the Engineer or subject to the provisions of Clause 2.1 to 2.6, from the Engineer's Representative.

14.1 Programme to be Submitted

The Contractor shall, within 7 days after the date of the Letter of Acceptance, submit to the Engineer for his consent a programme in PERT & CPM method including labour & material resources, in such form and detail as the Engineer shall reasonably prescribe, for the execution of the Works. The Contractor shall, whenever required by the Engineer, also provide in writing for his information a general description of the arrangements and methods which the Contractor proposes to adopt for the execution of the Works.

14.2 Revised Programme

If at any time it should appear to the Engineer that the actual progress of the Works does not conform to the programme to which consent has been given under Sub-Clause 14.1 the Contractor shall produce, at the request of the Engineer, a revised programme showing the modifications to such programme necessary to ensure completion of the Works within the Time for Completion.

14.3 Cash Flow Estimate to be Submitted

The Contractor shall, within 7 days after the date of the Letter of Award, provide to the Engineer for his information a detailed cash flow estimate,

in quarterly periods, of all payments to which the Contractor will be entitled under the Contract and the Contractor shall subsequently supply revised cash flow estimates at quarterly intervals, if required to do so by the Engineer.

14.4 Contractor not Relieved of Duties or Responsibilities

The submission to and consent by the Engineer to such programs or the provision of such general descriptions or cash flow estimates shall not relieve the Contractor of any of his duties or responsibilities under the Contract.

15.1 Contractor's Superintendence

The Contractor shall provide all necessary superintendence during the execution of the Works and as long thereafter as the Engineer may consider necessary for the proper fulfilling of the Contractor's obligations under the Contract. The Contractor, or a competent and authorised representative approved of by the Engineer, which approval may at any time be withdrawn, shall give his whole time to the superintendence of the Works. Such authorised representative shall receive, on behalf of the Contractor, instructions from the Engineer or, subject to the provisions of Clause 2.1 to 2.6, the Engineer's Representative.

16.1 Contractor's Employees

The Contractor shall provide on the Site in connection with the execution and completion of the Works and the remedying of any defects therein :

- (a) only such technical assistants as are skilled and experienced in their respective callings and such foremen and leading hands as are competent to give proper superintendence of the Works, and
- (b) such skilled, semi-skilled and un-skilled labour as is necessary for the proper and timely fulfilling of the Contractor's obligations under the Contract.

16.2 Engineer at Liberty to Object

The Engineer shall be at liberty to object to and require the Contractor to remove forthwith from the Works any person provided by the Contractor who, in the opinion of the Engineer, misconducts himself, or is incompetent or negligent in the proper performance of his duties, or whose presence on Site is otherwise considered by the Engineer to be undesirable, and such person shall not be again allowed upon the Works without the consent of the Engineer. Any person so removed from the Works shall be replaced as soon as possible.

17.1 Setting-out

The Contractor shall be responsible for :

- (a) the accurate setting-out of the Works in relation to existing facilities, original points, lines and levels of reference given by the Engineer in writing,
- (b) the correctness, subject as above mentioned, of the position, levels dimensions and alignment of all parts of the Works, and
- (c) the provision of all necessary instruments, appliances and labour in connection with the foregoing responsibilities.

The checking of any setting-out or of any line or level by the Engineer shall not in any way relieve the Contractor of his responsibility for the accuracy thereof.

The Contractor shall give to the Engineer not less than 72(seventy two) hours notice of his intention to set out or give levels for any part of the Works so that timely arrangement may be made for checking or issuing instructions. He shall indicate therein by which date the information, if any is required by him.

18.1 Boreholes and Exploratory Excavation

Deleted

19.1 Safety, Security and Protection of the Environment

The Contractor shall, throughout the execution and completion of the Works and the remedying of any defects therein:

- (a) have full regard for the safety of all persons entitled to be upon the Site and keep the Site (so far as the same is under his control) and the Works (so far as the same are not completed or occupied by the Employer) in an orderly state appropriate to the avoidance of danger to such persons, and
- (b) provide and maintain at his own cost all lights, guards, fencing, warning signs and watching, when and where necessary or required by the Engineer or by any duly constituted authority, for the protection of the Works or for the safety and convenience of the public or others, and
- (c) take all reasonable steps to protect the environment on and off the

Site and to avoid damage or nuisance to persons or to property of the public or others resulting from pollution, noise or other causes arising as a consequence of his methods or operation.

20.1 Care of Works

The Contractor shall take full responsibility for the care of the Works and materials and Plant for incorporation therein from the Commencement Date until the date of issue of the Taking-Over Certificate for the whole of the Works, when the responsibility for the said care shall subject to clause 20.1(b) pass to the Employer, Provided that:

- (a) if the Engineer issues a Taking-Over Certificate for any Section or part of the Permanent Works the Contractor shall cease to be liable for the care of that Section or part from the date of issue of the Taking-Over Certificate, when the responsibility for the care of that Section or part shall pass to the Employer, and
- (b) the Contractor shall take full responsibility for the care of any outstanding Works and materials and Plant for incorporation therein which he undertakes to or is otherwise required to finish during the Defects Liability Period until such outstanding Works have been completed pursuant to Clause 49.1 to 49.4.

20.2 Responsibility to Rectify Loss or Damage

If any loss or damage happens to the Works, or any part thereof, or materials or Plant for incorporation therein, during the period for which the Contractor is responsible for the care thereof, from any cause whatsoever, other than the risks defined in Sub-Clause 20.4, the Contractor shall, at his own cost, rectify such loss or damage so that the Permanent Works conform in every respect with the provisions of the Contract to the satisfaction of the Engineer. The Contractor shall also be liable for any loss or damage to the Works occasioned by him in the course of any operations carried out by him for the purpose of complying with his obligations under Clause 49.1 to 49.4 and 50.1.

20.3 Loss or Damage Due to Employer's Risk

In the event of any such loss or damage happening from any of the risks defined in Sub-Clause 20.4, or in combination with other risks, the Contractor shall, if and to the extent required by the Engineer, rectify the loss or damage and the Engineer shall determine an addition to the Contract Price in accordance with Clause 52.1 to 52.4 and shall notify the Contractor accordingly. In the case of combination of risks causing loss or damage any such determination shall take into account the proportional responsibility of the Contractor and the Employer.

20.4 Employer's Risks

The Employer's risks are :

- (a) (i) war, hostilities (whether war be declared or not), invasion, act of foreign enemies,
- (ii) rebellion, revolution, insurrection, or military or usurped power, or civil war,
- (iii) ionising radiations, or contamination by radio-activity from any nuclear fuel, or from any nuclear waste from the combustion of nuclear fuel, radio-active toxic explosive, or other hazardous properties of any explosive nuclear assembly or nuclear component thereof,
- (iv) pressure waves caused by aircraft or other aerial devices travelling at sonic or supersonic speed,
- (b) loss or damage due to the use or occupation by the Employer of any Section or part of the Permanent Works, except as may be provided for in the Contract,
- (c) loss or damage to the extent that it is due to the design of the Works, other than any part of the design provided by the Contractor or for which the Contractor is responsible, and
- (d) any operation of the forces of nature (insofar as it occurs on the site) which an experienced contractor:
 - (i) could not have reasonably foreseen, or
 - (ii) could reasonably have foreseen, but against which he could not reasonably have taken at least one of the following measures:
 - (A) prevent loss or damage to physical property from occurring by taking appropriate measures, or
 - (B) insure against.

21.1 Insurance of Works and Contractor's Equipment

The Contractor shall, without limiting his or the Employer's obligations and responsibilities under Clause 20.1 to 20.4, insure:

- (a) the Works, together with materials and Plant for incorporation therein, to the full replacement cost and it being understood that such insurance shall provide for compensation to be payable to rectify the loss or damage incurred.
- (b) an additional sum of 15 percent of such replacement cost, or as may be specified in Part III of these Conditions, to cover any additional costs of and incidental to the rectification of loss or damage including professional fees and the cost of demolishing and removing any part of the Works and of removing debris of whatsoever nature, and it being understood that such insurance shall provide for compensation to be payable to rectify the loss or damage incurred.
- (c) the Contractor's Equipment and other things brought onto the Site by the Contractor, for a sum sufficient to provide for their replacement at the Site.

The insurance under clause 21.1 shall be issued by an insurance company which has been determined by the contractor to be acceptable to the Consultant.

21.2 Scope of Cover

The insurance in paragraphs (a) and (b) of Sub-Clause 21.1 shall be in the joint names of the Contractor and the Employer and shall cover:

- (a) the Employer and the Contractor against all loss or damage from whatsoever cause arising (including natural calamities, earthquake, subsidence, landslide, rock slide, flood, storm, cyclone, fire, theft, burglary, strike, riot, sabotage, terrorism), other than as provided in Sub- Clause 21.4, from the commencement date until the date of issue of the relevant Taking-Over Certificate in respect of the Works or any Section or part thereof as the case may be, and
- (b) **the Contractor for his liability:**
 - (i) during the Defects Liability Period for loss or damage arising from a cause occurring prior to the commencement of the Defects Liability Period, and
 - (ii) for loss or damage occasioned by the Contractor in the course of any operations carried out by him for the purpose of complying with his obligations under Clauses 49.1 to 49.4 and 50.1.

It shall be the responsibility of contractor to notify the Insurance Company of any change in the nature and extent of the works and to ensure the adequacy of the Insurance cover at all times during the period of contract.

21.3 Responsibility for Amounts not recovered

Any amounts not insured or not recovered from the insurers shall be borne by the Employer or the Contractor in accordance with their responsibilities under Clause 20.1 to 20.4.

21.4 Exclusions

There shall be no obligation for the insurance in Sub-Clause 21.1 to include loss or damage caused by the risks listed under sub clause 20.4 para a (i) to (iv).

If the Contractor receives instructions from the Employer to insure against War Risk, such insurance if normally available shall be effected, at the cost of the Employer, with an Insurance Company acceptable to the Consultant and shall be in the joint names of the contractor and the Employer.

22.1 Damage to Persons and Property

The Contractor shall, except if and so far as the Contract provides otherwise, indemnify the Employer against all losses and claims in respect of:

- (a) death of or injury to any person, or
- (b) loss or damage to any property (other than the Works) :

Which may arise out of or in consequence of the execution and completion of the Works and the remedying of any defects therein, and against all claims, proceedings, damages, costs, charges and expenses whatsoever in respect thereof or in relation thereto, subject to the exceptions defined in Sub-Clause-22.2.

22.2 Exceptions

The "exceptions" referred to in Sub-Clause 22.1 are:

- (a) the permanent use or occupation of land by the Works, or any part thereof,

- (b) the right of the Employer to execute the Works, or any part thereof, on, over, under, in or through any land,
- (c) damage to property which is the unavoidable result of the execution and completion of the Works, or the remedying of any defects therein, in accordance with the Contract.
- (d) death of or injury to persons or loss of or damage to property resulting from any action or neglect of the Employer, his agents, servants or other contractors, not being employed by the Contractor, or in respect of any claims, proceedings, damages, costs, charges and expenses in respect thereof or in relation thereto or, where the injury or damage was contributed to by the Contractor, his servants or agents, such part of the said injury or damage as may be just and equitable having regard to the extent of the responsibility of the Employer, his servants or agents or other contractors for the injury or damage.

22.3 Indemnity by Employer

The Employer shall indemnify the Contractor against all claims, proceedings, damages, costs, charges and expenses in respect of the matters referred to in the exceptions defined in Sub-Clause 22.2.

23.1 Third Party Insurance (Including Employer's Property)

The Contractor shall, without limiting his or the Employer's obligations and responsibilities under Clause 22.1 to 22.3, insure, in the joint names of the Contractor and the Employer, against liabilities for death of or injury to any person (other than as provided in Clause 24.1 to 24.2 or loss of or damage to any property (other than the Works) arising out of the performance of the Contract other than the exceptions defined in paragraphs (a), (b) and (c) of Sub-Clause 22.2.

23.2 Minimum Amount of Insurance

Such insurance shall be for at least the amount stated in Appendix to Tender.

23.3 Cross Liabilities

The insurance policy shall include a cross liability clause such that the insurance shall apply to the Contractor and to the Employer as separate insured.

24.1 Accident or Injury to Workmen

The Employer shall not be liable for or in respect of any damages or compensation payable to any workman other than for death or injury resulting from any act or default of the Employer, his agents or servants. The Contractor shall indemnify and keep indemnified the Employer against all such damages and compensation, other than those for which the Employer is liable as aforesaid, and against all claims, proceedings, damages, costs, charges, and expenses whatsoever in respect thereof or in relation thereto.

24.2 Insurance Against Accident to Workmen

The Contractor shall insure against such liability and shall continue such insurance during the whole of the time that any persons are employed by him on the Works. Provided that, in respect of any persons employed by any Subcontractor, the Contractor's obligations to insure as aforesaid under this Sub-Clause shall be satisfied if the Subcontractor shall have insured against the liability in respect of such persons in such manner that the Employer is indemnified under the policy, but the Contractor shall require such Subcontractor to produce to the Consultant, when required, such policy of insurance and the receipt for the payment for current premium.

25.1 Evidence and Terms of Insurance

The Contractor shall provide evidence to the Consultant as soon as practicable after the respective insurance have been taken out but in any case prior to the start of work at the Site that insurance required under the Contract have been effected and shall, within 84 days of the Commencement Date, provide the insurance policies to the Employer. When providing such evidence and such policies to the Employer, the Contractor shall notify the Engineer of so doing. Such insurance policies shall be consistent with the general terms agreed prior to the issue of the Letter of Acceptance. The Contractor shall effect all insurance for which he is responsible with insurers and in terms approved by the Consultant.

25.2 Adequacy of Insurance

The Contractor shall notify the insurers of changes in the nature, extent or programme for the execution of the Works and ensure the adequacy of the insurance at all times in accordance with the terms of the Contract and shall, when required, produce to the Consultant the insurance policies in force and the receipts for payment of the current premiums.

25.3 Remedy on Contractor's Failure to Insure

If the Contractor fails to effect and keep in force any of the insurance required under the Contract, or fails to provide the policies to Consultant

within the period required by Sub-Clause 25.1, then and in any such case the Employer may effect and keep in force any such insurance and pay any premium as may be necessary for that purpose and from time to time deduct the amount so paid from any monies due or to become due to the Contractor, or recover the same as a debt due from the Contractor.

25.4 Compliance with Policy Conditions

In the event that the Contractor or the Employer fails to comply with conditions imposed by the insurance policies effected pursuant to the Contract, each shall indemnify the other against all losses and claims arising from such failure.

The Contractor shall be entitled to place all insurance relating to the Contract (including, but not limited to, the insurance referred to in Clauses 21.1 to 21.4, 23.1 to 23.3 and 24.1 to 24.2) with insurers from India.

26.1 Compliance with Statutes, Regulations

The Contractor shall conform in all respects, including by the giving of all notices and the paying of all fees, with the provision of :

- (a) any National or State Statute, Ordinance, or other Law, or any regulation, or bye-law of any local or other duly constituted authority in relation to the execution and completion of the Works and the remedying of any defects therein, and
- (b) the rules and regulations of all public bodies and companies whose property or rights are affected or may be affected in any way by the Works, and the Contractor shall keep the Employer indemnified against all penalties and liability of every kind for breach of any such provision.

Provided always that the Employer shall be responsible for obtaining any planning, zoning or other similar permission required for the Works to proceed and shall indemnify the Contractor in accordance with Sub-Clause 22.3.

27.1 Fossils

Deleted

28.1 Patent Rights

The Contractor shall save harmless and indemnify the Employer from and against all claims and proceeding for or on account of infringement of any

patent right, design trademark or name or other protected rights in respect of any Contractor's Equipment, materials or Plant used for or in connection with or for incorporation in the Works and from and against all damages, costs, charges and expenses whatsoever in respect thereof or in relation thereto, except where such infringement results from compliance with the design or Specification provided by the Engineer.

28.2 Royalties

Except where otherwise stated, the Contractor shall pay all tonnage and other royalties, rent and other payments or compensation, if any, for getting stone, sand, gravel, clay or other materials required for the Works. Proof of such payments shall be produced on demand failing which it shall be deducted from the running bill / any payment due to the contractor for onward submission of the same to concerned authorities.

29.1 Interference with Traffic and Adjoining Properties

All operation necessary for the execution and completion of the Works and the remedying of any defects therein shall, so far as compliance with the requirements of the Contract permits, be carried on so as not to interfere unnecessarily or improperly with:

- (a) the convenience of the public, or
- (b) the access to, use and occupation of public or private road, railway and any other right of way and footpaths to or of properties whether in the possession of the Employer or of any other person.

The Contractor shall save harmless and indemnify the Employer in respect of all claims, proceedings, arising out of, or in relation to any such matters insofar as the Contractor is responsible therefor.

If any plant (floating or otherwise) belonging to or hired by the Contractor or any sub-contractor or any person employed by the Contractor or by any sub-contractor or any materials or things therein or there from sink from any cause whatsoever, it shall immediately be reported by the Contractor to the competent authorities and the Engineer's Representative, and Contractor shall forthwith, at his cost raise and remove any such plant, materials or things or otherwise deal with the same as the Engineer may direct.

The fact that such sunken plant, materials or things are insured or have been declared a total loss or do not represent any further value shall not absolve the Contractor from his obligations under this Clause to raise and remove the same.

Until such sunken plant or materials or things have been raised and

removed, the Contractor shall set such buoys and display at night such lights and do all such things for the safety as may be required by the competent authorities or by the Engineer's Representative.

In the event of the Contractor not carrying out the obligations imposed on him by this Clause, the Employer may cause to set buoy and display at night light on such plant and raise and remove the same without prejudice to the right of the Employer to hold the Contractor liable and all expenses and consequences thereon and incidental thereto shall be borne by the Contractor and shall be recoverable from him as a debt by the Employer or may be deducted by the Employer from any moneys due or which may become due to the Contractor.

30.1 Avoidance of Damage to Roads

Deleted.

30.2 Transport of Contractor's Equipment or Temporary Works

Save insofar as the Contract otherwise provides, the Contractor shall be responsible for and shall pay the cost of strengthening any bridges or altering or improving any road communicating with or on the routes to the Site to facilitate the movement of Contractor's Equipment or Temporary Works and the Contractor shall indemnify and keep indemnified the Employer against all claims for damage to any such road or bridge caused by such movement, including such claims as may be made directly against the Employer, and shall negotiate and pay all claims arising out of such damage.

If it is found necessary for the Contractor to move one or more loads of heavy constructional plant and equipment, materials or preconstructed units or parts of units of work over roads, highways, bridges on which such oversized and overweight items are not normally allowed to be moved, the Contractor shall obtain prior permission from the concerned authorities. Payments for complying with the requirements, if any, for protection of or strengthening of the roads, highways or bridges shall be made by the Contractor and such expenses shall be deemed to be included in his contract price.

30.3 Transport of Materials or Plant

If, notwithstanding Sub-Clause 30.1, any damage occurs to any bridge or road communicating with or on the routes to the Site arising from the transport of materials or Plant, the Contractor shall notify the Engineer, as soon as he becomes aware of such damage or as soon as he receives any claim from the authority entitled to make such claim. Where under

any law or regulation the hauler of such materials or Plant is required to indemnify the road authority against damage the Employer shall not be liable for any costs, charges or expenses in respect thereof or in relation thereto. In other cases the Employer shall negotiate the settlement of and pay all sums due in respect of such claim and shall indemnify the Contractor in respect thereof and in respect of all claims, proceedings, damages, costs charges and expenses in relation thereto. Provided that if and so far as any such claim or part thereof is, in the opinion of the Engineer, due to any failure on the part of the Contractor to observe and perform his obligations under Sub-Clause 30.1, then the amount, determined by the Engineer, due to any failure on the part of the Contractor to observe and perform his obligations under Sub-Clause 30.1, then the amount, determined by the Engineer, after due consultation with the Employer and the Contractor, to be due to such failure shall be recoverable from the Contractor by the Employer and may be deducted by the Employer from any monies due or to become due to the Contractor and the Engineer shall notify the Contractor accordingly. Provided also that the Employer shall notify the Contractor whenever a settlement is to be negotiated and, where any amount may be due from the Contractor, the Employer shall consult with the Contractor before such settlement is agreed.

30.4 Water borne Traffic

Where the nature of the Works is such as to require the use by the Contractor of water borne transport the foregoing provisions of this Clause shall be construed as through "road included a lock, dock, sea wall or other structure related to a waterway and "vehicle" included craft, and shall have effect accordingly.

31.1 Opportunities for other Contractors

The Contractor shall, in accordance with the requirements of the Engineer, afford all reasonable opportunities for carrying out their work to:

- (a) any other contractors employed by the employer and their workmen,
- (b) the workmen of Employer, and
- (c) the workmen of any duly constituted authorities who may be employed in the execution on or near the Site of any work not included in the Contract or of any contract which the employer may enter into in connection with or ancillary to the Works.

31.2 Facilities for other Contractors

If, however, pursuant to Sub-Clause 31.1 the Contractor shall, on the written request of the Engineer:

- (a) make available to any such other contractor, or to the Employer or any such authority, any roads or ways for the maintenance of which the Contractor is responsible, or
- (b) permit the use, by any such, of Temporary Works or Contractor's Equipment on the Site,
- (c) provide any other service of whatsoever nature for any such, the Engineer shall determine an addition to the Contract Price in accordance with Clause 52.1 to 52.4 and shall notify the Contractor accordingly.

32.1 Contractor to keep Site Clear

During the execution of the Works the Contractor shall keep the Site reasonably free from all unnecessary obstruction and shall store or depose of any Contractor's Equipment and surplus materials and clear away and remove from the Site any wreckage, rubbish or Temporary Works no longer required.

33.1 Clearance of Site on Completion

Before the issue of any Taking-Over Certificate the Contractor shall clear away and remove from that part of the Site to which such Taking-Over Certificate relates all Contractor's Equipment, surplus material rubbish and Temporary Works of every kind, and leave such part of the Site and Works clean and in a workmanlike condition to the satisfaction of the Engineer. Provided that the Contractor shall be entitled to retain on Site, until the end of the Defects Liability Period, such materials, Contractor's Equipment and Temporary Works as are required by him for the purpose of fulfilling his obligations during the Defects Liability Period.

34.1 Labour

The contractor shall make his own local or other arrangement for the engagement of all labour local or other.

The Contractor and his sub contractors shall abide by the local laws and regulations governing labour applicable from time to time.

Safety Provisions

The Contractor shall comply with all the precautions as required for the safety of the workman by the I.L.O Convention (NO.62) as far as they are

applicable to the Contract. The Contractor shall provide all necessary safety appliances, gears like goggles, helmets, masks, etc. to the workmen and the staff.

The Contractor shall be responsible for observance by his sub-Contractors of the foregoing provisions.

35.1 Returns of Labour, etc.

The Contractor shall, if required by the Engineer, deliver to the Engineer's Representative, or at his office, a return in detail in such form and at such intervals as the Engineer may prescribe showing the supervisory staff and the number of the several classes of labour from time to time employed by the Contractor on the site and such information respecting constructional plant as the Engineer's Representative may require.

The Contractor shall file all labour returns in detail to the respective authorities / statutory bodies as prescribed under law applicable at the work site and inform the Employer / Engineer with copies of such returns directly filed.

MATERIALS, PLANTS AND WORKMANSHIP

36.1 Quality of Materials, Plant and Workmanship

All materials Plant and workmanship shall be

- (a) of the Respective kinds described in the Contract and in accordance with the Engineer's instructions, and
- (b) subjected from time to time to such tests as the Engineer may require at the place of manufacture, fabrication or preparation, or on the Site or at such other place or places as may be specified in the Contract, or at all or any of such places.

The Contractor shall provide such assistance, labour, electricity, fuels, stores, apparatus and instruments as are normally required for examining, measuring and testing any materials or plant and shall supply samples of materials, before incorporation in the Works, for testing as may be selected and required by the Engineer.

36.2 Cost of Samples

All samples shall be supplied by the Contractor at his own cost if the supply thereof is clearly intended by or provided for in the Contract.

36.3 Cost of Test

The cost of making any test shall be borne by the Contractor if such test is

- (a) clearly intended by or provided for in the Contract, or
- (b) particularised in the Contract (in cases only of a test under load or of a test to ascertain whether the design of any finished or partially finished work is appropriate for the purposes which it was intended to fulfil) in sufficient detail to enable the Contractor to price or allow for the same in his Tender.

36.4 Costs of Tests not provided for

If any test required by the Engineer which is

- (a) not so intended by or provided for, or
- (b) (in the cases above mentioned) not so particularised, or
- (c) though so intended or provided for, required by the Engineer to be carried out at any place other than the Site local test house or the place of manufacture, fabrication or preparation of the materials or Plant tested.

Shows the materials, Plant or workmanship not to be in accordance with the provision of the Contract to the satisfaction of the Engineer, then the cost of such test shall be borne by the Contractor, but in any other case Sub- Clause 36.5 shall apply.

36.5 Engineer's Determination Where Tests not provided for

Where, pursuant to Sub-Clause 36.4, this Sub-Clause applies the Engineer shall, after due consultation with the Contractor, determine:

- (a) any extension of time to which the Contractor is entitled under Clause 44.1 to 44.3, and shall notify the Contractor accordingly.

37.1 Inspection of Operations

The Engineer, and any person authorised by him, shall at all reasonable times have access to the Site and to all workshops and places where materials or Plant are being manufactured, fabricated or prepared for the Works and the Contractor shall afford every facility for and every assistance in obtaining the right to such access.

37.2 Inspection and Testing

The Engineer shall be entitled, during manufacture, fabrication or preparation to inspect and test the materials and Plant to be supplied under the Contract. If materials or Plant are being manufactured, fabricated or prepared in workshops or places other than those of the Contractor, the Contractor shall obtain permission for the Engineer to carry out such inspection and testing in those workshops or places. Such inspection or testing shall not release the Contractor from any obligation under the Contract.

37.3 Dates for Inspection and Testing

The Contractor shall agree with the Engineer on the time and place for inspection or testing of any materials or Plant as provided in the Contract. The Engineer shall give the Contractor not less than 24 hours notice of his intention to carry out the inspection or to attend the tests. If the Engineer, or his duly authorised representative, does not attend on the date agreed, the Contractor may, unless otherwise instructed by the Engineer, proceed with the tests, which shall be deemed to have been made in the presence of the Engineer. The Contractor shall forthwith forward to the Engineer duly certified copies of the test readings. If the Engineer has not attended the tests, he shall accept the said readings as accurate or instruct the tests to be repeated at the Employer's cost to enable him to decide.

37.4 Rejection

If at the time and place agreed in accordance with Sub-Clause 37.3, the materials or Plant are not ready for inspection or testing or if, as result of the inspection or testing referred to in this Clause, the Engineer determines that the materials or Plant are defective or otherwise not in accordance with the Contract, he may reject the materials or Plant and shall notify the Contractor thereof immediately. The notice shall state the Engineer's objections with reasons. The Contractor shall then promptly make good the defect or ensure that rejected materials or Plant comply with the Contract. If the engineer so request, the test of rejected materials or Plant shall be made or repeated under the same terms and conditions. All costs incurred by the Employer by the repetition of the tests shall, after due consultation with the Employer and the Contractor, be determined by the Engineer and shall be recoverable from the Contractor by the Employee and may be deducted from any monies due or to become due to the Contractor and the Engineer shall notify the Contractor accordingly, with a copy to the Employer.

37.5 Independent Inspection

The Engineer may delegate inspection and testing of materials or Plant to

an independent inspector. Any such delegation shall be effected in accordance with Sub- Clause 2.4 and for this purpose such independent inspector shall be considered as an assistant of the Engineer. Notice of such appointment (not being less than 14 days) shall be given by the Engineer to the Contractor.

38.1 Examination of Work before Covering up

No part of the Work shall be covered up or put out of view without the approval of the Engineer and the Contractor shall afford full opportunity for the Engineer to examine and measure any such part of the Works which is about to be covered up or put out of view and to examine foundations before any part of the work is placed thereon. The Contractor shall give notice to the Engineer whenever any such part of the Works or foundations is or are ready or about to be ready for examination and the engineer shall unless he considers it unnecessary and advises the Contractor accordingly, attend for the purpose of examining and measuring such part of the Works or of examining such foundations.

38.2 Uncovering and Making Opening

The Contractor shall uncover any part of the Works or make opening in or through the same as the Engineer may from time to time instruct and shall reinstate and make good such part. If any such part has been covered up or put out of view after compliance with the requirement of Sub-Clause 38.1 and is found to be executed in accordance with the Contract, the Engineer shall, after due consultation with the Contractor, determine the amount of reinstating and making good the same, which shall be added to the Contract Price, and shall notify the Contractor accordingly. In any other case all costs shall be borne by the Contractor.

39.1 Removal of Improper Work, Materials or Plant

The Engineer shall have authority to issue instructions from time to time, for :

- (a) The removal from the Site, within such time or times as may be specified in the instruction, of any materials or Plant which, in the opinion of the Engineer, are not accordance with the Contract,
- (b) The substitution of proper and suitable materials or Plant, and
- (c) The removal and proper re-execution, notwithstanding any previous test thereof or interim payment therefor, of any work which, in respect of

- (i) materials, Plant or workmanship, or
- (ii) design by the Contractor or for which he is responsible, is not, in the opinion of the Engineer, in accordance with the Contract.

39.2 Default of Contractor in Compliance

In case of default on the Contractor in carrying out such instruction within the time specified therein or, if none, within a reasonable time, the Employer shall be entitled to employ and pay other persons to carry out the same and all costs consequent thereon or incidental thereto shall, after due consultation with the Contractor, be determined by the Engineer and shall be recoverable from the Contractor by the Employer, and may be deducted by the Employer from any monies due or to become due to the Contractor and the Engineer shall notify the Contractor accordingly.

SUSPENSION

40.1 Suspension of Work

The Contractor shall, on the instructions of the Engineer, suspend the progress of the Works or any part thereof for such time and in such manner as the Engineer may consider necessary and shall, during such suspension, properly protect and secure the Works or such part thereof so far as is necessary in the opinion of the Engineer. Unless such suspension is

- (a) otherwise provided for in the Contract, or
- (b) necessary by reason of some default of or breach of contract by the Contractor or for which he is responsible, or
- (c) necessary by reason of extra-ordinary climatic conditions on the Site, or
- (d) necessary for the proper execution of the Works or for the safety of the Works or any part thereof (save to the extent that such necessity arises from any act or default by the Engineer or the Employer or from any of the risks defined in Sub-Clause 20.4), Sub- Clause 40.2 shall apply.

40.2 Engineer's Determination following Suspension

Where, pursuant to Sub-Clause 40.1, this Sub- Clause applies the Engineer shall, after due consultation with the Contractor determine

- (a) any extension of time to which the Contractor is entitled under Clause 44.1 to 44.3, and
- (b) the amount, which shall be added to the Contract Price, in respect of the cost incurred by the Contractor by reason of such suspension.

And shall notify the Contractor accordingly.

40.3 Suspension lasting more than 84 Days

If the progress of the Works or any part thereof is suspended on the written instructions of the Engineer and if permission to resume work is not given by the Engineer within a period of 84 days from the date of suspension then, unless such suspension is within paragraph (a), (b), (c) or (d) of Sub-Clause 40.1, the Contractor may give notice to the Engineer requesting permission, within 28 days from the receipt thereof, to proceed with the Works or that part thereof in regard to which progress is suspended. If, within the said time, such permission is not granted, the Contractor may, but is not bound to, elect to treat the suspension, where it affects part only of the Works, as an omission of such part under Clause 51.1 to 51.2 by giving a further notice to the Engineer to that effect, or, where it affects the whole of the Works, treat the suspension as an event of default by the Employer and terminate his employment under the Contract in accordance with the provisions of Sub- Clause 69.1, whereupon the provisions of Sub-Clause 69.2 and 69.3 shall apply.

COMMENCEMENT AND DELAYS

41.1 Commencement of Works

The Contractor shall commence the Works within one weeks from the date of receipt of notice by him to this effect from the Engineer to proceed with the works with due expedition and without delay.

42.1 Possession of Site and Access Thereto

Save insofar as the Contract may prescribe:

- (a) the extent of portions of the Site of which the Contractor is to be given possession from time to time, and
- (b) the order in which such portions shall be made available to the Contractor and subject to any requirement in the Contract as to the order in which the Works shall be executed,

The Employer will, with the Engineer's notice to commence the Works, give to the Contractor possession of

- (c) so much of the Site, and
- (d) such access as, in accordance with the Contract, is to be provided by the Employer,

as may be required to enable the Contractor to commence and proceed with the execution of the Works in accordance with the programme referred to in Clause 14.1 to 14.4, if any, and otherwise in accordance with such reasonable proposals as the Contractor shall, by notice to the Engineer make. The Employer will, from time to time as the Works proceed, give to the Contractor possession of such further portions of the Site as may be required to enable the Contractor to proceed with the execution of the Works with due dispatch in accordance with such programme or proposals, as the case may be.

- (e) All water including rainwater, which may accumulate on the site during the progress of the works or in trenches or excavations, shall be removed promptly from the site to the satisfaction of engineer and at the cost of contractor.

42.2 Failure to Give Possession

If the Contractor suffers delay and/or incurs costs from failure on the part of the Employer to give possession in accordance with the terms of Sub-Clause 42.1, the Engineer shall, on the request of the contractor and submission of the details and documentary proof, determine:

- (a) any extension of time to which the Contractor is entitled under Clause 44.1 to 44.3, and
- (b) the amount of such costs, which shall be added to the Contract Price, and shall notify the Contractor accordingly.

42.3 Way leaves and Facilities

The Contractor shall bear all costs and charges for special or temporary way leaves required by him in connection with access to Site. The Contractor shall also provide at his own cost any additional facilities outside the Site required by him for the purposes of the Works.

43.1 Time for Completion

The whole of the Works and, if applicable, any Section required to be

completed within a particular time as stated in the Appendix to Tender, shall be completed, in accordance with the provisions of Clause 48.1 to 48.4, within the time stated in the Appendix to Tender for completion of the whole of the Works or the Section (as the case may be), calculated from the Commencement Date, or such extended time as may be allowed under Clause 44.1 to 44.3.

44.1 Extension of Time for Completion

In the event of

- (a) the amount or nature of extra or additional work, or
- (b) any cause of delay referred to in these Conditions by reference to clause 44.1 to 44.3, or
- (c) exceptionally adverse climatic conditions, or
- (d) any delay, impediment or prevention by the Employer, or
- (e) other special circumstances which may occur, other than through a default of or breach of contract by the Contractor or for which he is responsible,

being such as fairly to entitle the contractor to extension of time for completion of the works or any section or part thereof, the Engineer shall after due consultation with the contractor, and subject to clause 44.2 determine the amount of such extension and shall notify the contractor accordingly.

44.2 Contractor to Provide Notification and Detailed/ Particulars

The Engineer is not bound to make any determination under clause 44.1 unless the Contractor has

- (a) within 28 days after such event has arisen notified the Engineer, and
- (b) within 28 days, or such other reasonable time as may be agreed by the Engineer, after such notification submitted to the Engineer detailed particulars of any extension of time to which he may consider himself entitled in order that such submission may be investigated at the time.

44.3 Interim Determination of Extension

Provided also that where an event has continuing effect such that it is not

practicable for the Contractor to submit detailed particulars within the period of 28 days referred to in Sub-Clause 44.2 (a), he shall nevertheless be entitled to an extension of time provided that he has submitted to the Engineer interim particulars at intervals of not more than 28 days and final particulars within 28 days of the end of the effects resulting from the event. On receipt of such interim particulars, the Engineer shall, without undue delay, make an interim determination of extension of time and on receipt of the final particulars the Engineer shall review the circumstances and shall determine an overall extension of time in regard to the event in consultation with the Contractor and shall notify the Contractor of the determination. No final review shall result in a decrease of any extension of time already determined by the Engineer.

45.1 Restriction Working Hours

Subject to any provision to the contrary contained in the Contract, none of the Works shall save as hereinafter provided, be carried on during the night or on locally recognised days of rest without the consent of the Engineer, except when work is unavoidable or absolutely necessary for the saving of life or property or for the safety of the Works, in which case the Contractor shall immediately advise the Engineer. Provided that the provisions of this Clause shall not be applicable in the case of any work which it is customary to carry out by multiple shift.

46.1 Rate of Progress

If for any reason, which does not entitle the Contractor to an extension of time, the rate of progress of the Works or any Section is at any time, in the opinion of the Engineer, too slow to enable the contractor to complete the execution of and passing the tests on completion of the Works or such section by the time for completion, the Engineer shall so notify the Contractor who shall thereupon take such steps as are necessary, subject to the consent of the Engineer, to expedite progress so as complete the execution of and passing the tests on completion of the Works or such section by the time for completion. The Contractor shall not be entitled to any additional payment for taking such steps. If, as a result of any notice given by the Engineer under this Clause, the Contractor considers that it is necessary to do any work at night or on locally recognised days of rest, he shall be entitled to seek the consent of the Engineer so to do. Provided that if any steps, taken by the Contractor in meeting his obligations under this Clause, involve the employer in additional supervision costs, such costs shall, after due consultation with the Contractor, be determined by the Engineer and shall be recoverable from the Contractor by the Employer, and may be deducted by the Employer from any monies due or to become to the Contractor and the Engineer shall notify the Contractor accordingly.

47.1 Liquidated Damages for Delay

If the Contractor fails to complete the execution of and passing the test on completion of the works or any section by the time for completion, in accordance with Clause 48.1 to 48.4, within the relevant time prescribed by Clause 43.1, then the Contractor shall pay to the Employer the relevant sum stated in the Appendix to Tender (Appendix - B) as liquidated damages for such default and not as a penalty (which sum shall be the only monies due from the Contractor for such default) for every day or part of a day which shall elapse between the relevant Time for Completion and the date stated in a Taking-Over Certificate of the whole of the Works or the relevant Section, subject to the applicable limit stated in the Appendix to Tender (Annexure - B). The Employer may, without prejudice to any other method of recovery, deduct the amount of such damages from any monies due or to become due to the Contractor. The payment or deduction of such damages shall not relieve the Contractor from his obligation to complete the Works, or from any other of his obligations and liabilities under the contract.

47.2 Reduction of Liquidated Damages

If, before the Time for Completion of the whole of the Works or, if applicable, any Section, a Taking-Over Certificate has been issued for any part of the Works or of a Section, the liquidated damages for delay in completion of the remainder of the Works or of that Section shall, for any period of delay after date stated in such Taking-Over Certificate, and in the absence of alternative provisions in the Contract, be reduced in the proportion which the value of the part so certified bears to the value of the whole of the Works or Section, as applicable. The Provisions of this Sub-Clause shall only apply to the rate of liquidated damages and shall not affect the limit thereof.

48.1 Taking-Over Certificate

When the whole of the Works have been substantially completed and have satisfactorily passed any Tests on Completion prescribed by the Contract, the Contractor may give a notice to that effect to the Engineer, accompanied by a written undertaking to finish with due expedition any outstanding work during the Defects Liability Period. Such notice and undertaking shall be deemed to be a request by the Contractor for the Engineer to issue a Taking-Over Certificate in respect of the Works. The Engineer shall, within 21 days of the date of delivery of such notice, either issue to the Contractor, a Taking-Over Certificate, stating the date on which, in his opinion, the Works were substantially completed in accordance with the Contract, or give instructions in writing to the Contractor specifying all the work which in the Engineer's opinion, is

required to be done by the Contractor before the issue of such Certificate. The Engineer shall also notify the Contractor of any defects in the Works affecting substantial completion that may appear after such instructions and before completion of the Works specified therein. The Contractor shall be entitled to receive such Taking-Over Certificate within 21 days of completion, to the satisfaction of the Engineer, of the Works so specified and remedying any defects so notified.

48.2 Taking-Over of Sections or Parts

Similarly, in accordance with the procedure set out in Sub-Clause 48.1, the Contractor may request and the Engineer shall issue a Taking-Over Certificate in respect of :

- (a) any Section in respect of which a separate Time for Completion is provided in the Appendix to Tender, or
- (b) any substantial part of the Permanent Works which has been both completed to the satisfaction of the Engineer and, otherwise than as provided for in the Contract, occupied or used by the Employer, or
- (c) any part of the Permanent Works which the Employer has elected to occupy or use prior to completion (where such prior occupation or use is not provided for in the Contract or has not been agreed by the Contractor as a temporary measure).

48.3 Substantial Completion of Parts

If any part of the Permanent Works has been substantially completed and has satisfactorily passed any Tests on Completion prescribed by the Contract, the engineer may issue a Taking-Over Certificate in respect of that part of the Permanent Works before completion of the whole of the Works and, upon the issue of such Certificate, the Contractor shall be deemed to have undertaken to complete with due expedition any outstanding work in that part of the permanent Works during the Defects Liability Period.

48.4 Surfaces Requiring Reinstatement

Provided that a Taking-Over Certificate given in respect of any Section or part of the Permanent Works before completion of the whole of the Works shall not be deemed to certify completion of any ground or surfaces requiring reinstatement, unless such Taking- Over certificate shall expressly so state.

If the Contractor is prevented from carrying out the Tests on Completion by a cause for which the employer or the Engineer or other contractors employed by the Employer are responsible, the employer shall subject to clause 7.2 (b) be deemed to have taken over the Works on the date when the Tests on Completion would have been completed but for such prevention. The Engineer shall issue a Taking-Over Certificate accordingly. Provided always that the Works shall not be deemed to have been taken over if they are not substantially in accordance with the Contract.

If the Works are taken over under this Sub-Clause the Contractor shall nevertheless carry out the Tests on Completion during the Defects Liability Period. The Engineer shall require the Tests to be carried out by giving 14 days notice.

Any additional costs to which the Contractor may be put, in making the Tests on Completion during the Defects Liability Period, shall be added to the Contract Price.

DEFECTS LIABILITY

49.1 Defects Liability Period

In these Conditions the expression "Defects Liability Period" shall mean the defects liability period named in the Appendix to Tender, calculated from:

- (a) the date of completion of the Works certified by the Engineer in accordance with Clause 48.1 to 48.4 or clause 63.1; or
- (b) in the event of more than one certificate having been issued by the Engineer under Clause 48.1 to 48.4, the respective dates so certified.

49.2 Completion of Outstanding Work and Remedying Defects

To the intent that the Works shall, at or as soon as practicable after the expiration of the Defects Liability Period, be delivered to the Employer in the condition required by the Contract, fair wear and tear excepted, to the satisfaction of the Engineer, the Contractor shall:

- (a) complete the work, if any, outstanding on the date stated in Taking-Over Certificate as soon as practicable after such date and
- (b) execute all such work of amendment, reconstruction, and remedying defects, shrinkages or other faults as the Engineer

may, during the Defects Liability Period or within 14 days after its expiration, as a result of an inspection made by or on behalf of the Engineer prior to its expiration, instruct the Contractor to execute.

49.3 Cost of Remedying Defects

All work referred to in Sub-Clause 49.2 (b) shall be executed by the Contractor at his own cost if the necessity thereof is, in the opinion of the engineer, due to:

- (a) the use of materials, Plant or workmanship not in accordance with the Contract, or
- (b) where the Contractor is responsible for the design of part of the Permanent Works, any fault in such design, or
- (c) the neglect or failure on the part of the Contractor to comply with any obligation, expressed or implied, on the Contractor's part under the Contract.

If, in the opinion of the Engineer, such necessity is due to any other cause, he shall determine an addition to the Contract Price in accordance with Clause 52.1 to 52.4 and shall notify the Contractor accordingly, with a copy to the Consultant.

49.4 Contractor's Failure to Carry out Instructions

In case of default on the part of the Contractor in carrying out such instruction within a reasonable time, the consultant shall be entitled to employ and pay other persons to carry out the same and if such work, in the opinion of the Engineer, the Contractor was liable to do at his own cost under the Contract, then all costs consequent thereon or incidental thereto shall, after due consultation with the Contractor, be determined by the Engineer and shall be recoverable from the Contractor by the Employer, and may be deducted by the Employer from any monies due or to become due to the Contractor and the Engineer shall notify the Contractor accordingly.

The Provisions of this Clause shall apply to all replacements or renewals of Plant carried out by the Contractor to remedy defects and damages as if the replacements and renewals had been taken over on the date they were completed.

The Defects Liability Period for the Works shall be extended by a period equal to the period during which the Works cannot be used by reason of a defect or damage. If only part of the Works is affected the Defects Liability Period shall be extended only for that part. In neither case shall

the Defects Liability Period extend beyond 2 years from the date of taking over.

When the progress in respect of Plant has been suspended under clause 40.1 to 40.3, the Contractor's obligations under this Clause shall not apply to any defects occurring more than one year after the Time for Completion established on the date of the Letter of Acceptance.

50.1 Contractor to Search

If any defects, shrinkage or other fault in the Works appears at any time prior to the end of the Defects Liability Period, the Engineer may instruct the Contractor, to search under the directions of the Engineer for the cause thereof. Unless such defect, shrinkage or other fault is one for which the Contractor is liable under the Contract, the Engineer shall, after due consultation with the Contractor, determine the amount in respect of the costs of such search incurred by the Contractor, which shall be added to the Contract Price and shall notify the Contractor accordingly. If such defect, shrinkage or other fault is one for which the Contractor is liable, the cost of the work carried out in searching as aforesaid shall be borne by the Contractor and he shall in such case remedy such defect, shrinkage or other fault at his own cost in accordance with the provisions of Clause 49.1 to 49.4.

ALTERATIONS, ADDITIONS AND OMISSIONS

51.1 Variations

The Engineer shall make any variation of the form, or quantity of the Works or any part thereof that may, in his opinion, be necessary and for that purpose, or if for any other reason it shall, in his opinion, be appropriate, he shall have the authority to instruct the Contractor to do and the Contractor shall do any of the following:

- (a) change the character or quality or kind of any such work.
- (b) change the levels, lines, position and dimensions of any part of the Works,
- (c) execute additional work of any kind necessary for the completion of the Works
- (d) change any specified sequence or timing of construction of any part of the Works.

No such variation shall in any way vitiate or invalidate the Contract, but the effect, if any, of all such variations shall be valued in accordance with

Clause 52.1 to 52.4. Provided that where the issue of an instruction to vary the Works is necessitated by some default of or breach of contract by the contractor or for which he is responsible, any additional cost attributable to such default shall be borne by the contractor.

51.2 Instructions for Variations

The Contractor shall not make any such variation without an instruction of the Engineer. Provided that no instruction shall be required for increase or decrease in the quantity of any work where such increase or decrease is not the result of an instruction given under this Clause, but is the result of the quantities exceeding or being less than those stated in the Bill of Quantities as per approved drawings issued for construction.

52.1 Valuation of Variations

All variations referred to in Clause 51.1 to 51.2 and any additions to the Contract Price which are required to be determined in accordance with Clause 52.1 to 52.4 (for the purposes of this Clause referred to as "varied works"), shall be valued at the rates and prices set out in the Contract if, in the opinion of the Engineer, the same shall be applicable. If the contract does not contain any rates or prices applicable to the varied work, the rates and prices in the Contract shall be used as the basis for valuation so far as may be reasonable, failing which, after due consultation by the Engineer with the Contractor, suitable rates or prices shall be agreed upon between the Engineer and the Contractor. In the event of disagreement the Engineer shall fix such rates or prices as are, in his opinion, appropriate based on CPWD norms and shall notify the Contractor accordingly. Until such time as rates or prices are agreed or fixed, the Engineer shall determine provisional rates or prices to enable on-account payments to be included in certificates issued in accordance with Clause 60.1 to 60.14.

52.2 Power of Engineer to Fix Rates

Provided that if the nature or amount of any varied work relative to the nature or amount of the whole of the Works or to any part thereof, is such that, in the opinion of the Engineer, the rate or price contained in the Contract for any item of the Works is, by reason of such varied work, rendered inappropriate or inapplicable, then after due consultation by the Engineer with the Contractor, a suitable rate or price shall be agreed upon between the Engineer and the Contractor. In the event of disagreement the Engineer shall fix such other rate or price as is, in his opinion, appropriate and shall notify the Contractor accordingly. Until such time as rates or prices are agreed or fixed, the Engineer shall determine provisional rates or prices to enable on-account payments to

be included in certificates issued in accordance with Clause 60.1 to 60.14.

The quoted rates for all the items shall be firm, fixed and binding on the contractor. However if the total value of quantities of BOQ items actually executed varies beyond $\pm 25\%$ of the Contract value, then the item rates of only those items whose individual quantities varies beyond $\pm 25\%$ of the quantities mentioned in the Contract shall be considered for change in rates. The rates \pm for such items shall be worked out on the basis of market rate analysis based on CPWD norms / (Market rate based in case it is not available in CPWD) and only applicable to the quantities beyond $\pm 25\%$ of the quantities mentioned in the Contract. In the event of disagreement between the Engineer and the Contractor on these rates, the Engineer shall fix such rates and prices as are in his opinion appropriate and shall notify the Contractor accordingly. Provided also that no varied work instructed to be done by the Engineer pursuant to Clause 51.1 to 51.2 shall be valued under Sub-Clause 52.1, or under this Sub-Clause unless, within 14 days of the date of such instruction and, other

Than in the case of omitted work, before the commencement of the varied work, notice shall have been given either:

- (a) by the Contractor to the Engineer of his intention to claim extra payment or a varied rate or price, or
- (b) by the Engineer to the Contractor of his intention to vary a rate or price.

52.3 Variations Exceeding 25 percent

If, on the issue of the Taking-Over Certificate for the whole of the Works, it is found that as a result of :

- (a) all varied work valued under Sub-Clause 52.1 and 52.2, and
- (b) all adjustments upon measurement of the estimated quantities set out in the Bill of Quantities, excluding Provisional Sums, dayworks and adjustments of price made under Clause 70.1 to 70.3,

but not from any other cause, there have been additions to or deductions from the Contract Price which taken together are in excess of 25 percent of the "Effective Contract Price" (which for the purposes of this Sub-Clause shall mean the Contract Price, excluding Provisional Sums and allowance for day works, if any) then and in such event (subject to any action already taken under any other Sub-Clause of this Clause), after due consultation by the

Engineer with the Employer and the Contractor, there shall be added to or deducted from the Contract Price such further sum as may be agreed between the Contractor and the Engineer or, failing agreement, determined by the Engineer as being fair and reasonable having regard to the Contractor's Site and general overhead costs of the Contract. The Engineer shall notify the Contractor of any determination made under this Sub-Clause. Such sum shall be based only on the amount by which such additions or deductions shall be in excess of 25 per cent of the Effective Contract Price.

52.4 Daywork

The Engineer may, if in his opinion it is necessary or desirable, issue an instruction that any varied work shall be executed on a daywork basis. The Contractor shall then be paid for such varied work under the terms set out in daywork schedule which shall be the minimum wages applicable in Delhi to the category of workers employed as on the day the work is carried out.

The Contractor shall furnish to the Engineer such receipts or other vouchers as may be necessary to prove the amounts paid and, before ordering materials, shall submit to the Engineer quotations for the same for his approval.

In respect of such of the Works executed on a daywork basis, the Contractor shall, during the continuance of such work, deliver each day to the Engineer an exact list in duplicate of the names, occupation and time of all workmen employed on such work and a statement, also in duplicate, showing the description and quantity of all materials and Contractor's Equipment used thereon or therefor other than Contractor's Equipment which is included in the percentage addition in accordance with such daywork schedule. One copy of each list and statement will, if correct, or when agreed, be signed by the Engineer and returned to the Contractor.

At the end of each month the Contractor shall deliver to the Engineer a priced statement of the labour, materials and Contractor's Equipment, except as aforesaid, used and the Contractor shall not be entitled to any payment unless such lists and statements have been fully and punctually rendered. Provided always that if the Engineer considers that for any reason the sending of such lists or statements by the Contractor, in accordance with the foregoing provision, was impracticable he shall nevertheless be entitled to authorise payment for such work, either as daywork, or being satisfied as to the time employed and the labour, materials and Contractor's Equipment used on such work, or at such value therefor as shall, in his opinion, be fair and reasonable.

PROCEDURE FOR CLAIMS

53.1 Notice of Claims

Notwithstanding any other provision of the Contract, if the Contractor intends to claim any additional payment pursuant to any clause of these Conditions or otherwise, he shall give notice of his intention to the Engineer, within 28 days after the event giving rise to the claim has first arisen.

53.2 Contemporary Records

Upon the happening of the event referred to in Sub-Clause 53.1, the Contractor shall keep such contemporary records as may reasonable be necessary to support any claim he may subsequently wish to make. Without necessarily admitting the Employer's liability, the Engineer shall, on receipt of a notice under Sub-Clause 53.1, inspect such contemporary records and may instruct the Contractor to keep any further contemporary records as are reasonable and may be material to the claim of which notice has been given. The Contractor shall permit the Engineer to inspect all records kept pursuant to this Sub-Clause and shall supply him with copies thereof as and when the Engineer so instructs.

53.3 Substantiation of Claims

Within 28 days, or such other reasonable time as may be agreed by the Engineer, of giving notice under Sub-Clause 53.1, the Contractor shall send to the Engineer an account giving detailed particulars of the amount claimed and the grounds upon which the claim is based. Where the event giving rise to the claim has a continuing effect, such account shall be considered to be an interim account and the Contractor shall, at such intervals as the Engineer may reasonable require, send further interim accounts giving the accumulated amount of the claim and any further grounds upon which it is based. In cases where interim accounts are sent to the Engineer, the Contractor shall send a final account within 28 days of the end of the effect resulting from the event. The Contractor shall, if required by the Engineer so to do, copy to the Employer all accounts sent to the Engineer pursuant to this Sub- Clause.

53.4 Failure to Comply

If the Contractor fails to comply with any of the provisions of this Clause in respect of any claim which he seeks to make, his entitlement to payment in respect thereof shall not exceed such amount as the Engineer or any arbitrator or arbitrators appointed pursuant to Sub-Clause 67.3 assessing the claim considers to be verified by contemporary records (whether or

not such records were brought to the Engineer's notice as required under Sub-Clause 53.2 and 53.3).

53.5 Payment of Claims

The Contractor shall be entitled to have included in any interim payment certified by the Engineer pursuant to Clause 60.1 to 60.14 such amount in respect of any claim as the Engineer, after due consultation with the Contractor, may consider due to the Contractor provide that the Contractor has supplied sufficient particulars to enable the Engineer to determine the amount due. If such particulars are insufficient particulars to substantiate the whole of the claim, the Contractor shall be entitled to payment in respect of such part of the claim as such particulars may substantiate to the satisfaction of the Engineer. The Engineer shall notify the Contractor for any determination made under this Sub-Clause.

CONTRACTOR'S EQUIPMENT, TEMPORARY WORKS AND MATERIALS

54.1 Contractor's Equipment, Temporary Works and Materials, Exclusive use for the Works

All Contractor's Equipment Temporary Works and materials by the Contractor shall when brought on to the site, be deemed to be exclusively intended for the execution of the works and the contractor shall not remove the same or any part thereof, except for the purpose of moving it from one part of the Site to another, without the consent of the Engineer. provided that consent shall not be required for vehicles engaged in transporting any staff labour, contractor's equipment, temporary works, plant or materials to or from the site.

54.2 Employer Not Liable for Damage

The Employer shall not at any time be liable, save as mentioned in Clauses 20.1 to 20.4 and 65.1 to 65.8, for the loss of or damage to any of the said Contractor's Equipment, Temporary Works or materials.

54.3 Customs Clearance

The Employer will use his best endeavours in assisting the Contractor, where required, in obtaining clearance through the Customs of Contractor's Equipment, materials and other things required for the Works.

54.4 Re-export of Contractor's Equipment

In respect of any Contractor's Equipment which the Contractor has imported for the purposes of the Works, the Employer will use his best endeavours to assist the Contractor, where required, in procuring any necessary Government consent to the re-export of such Contractor's Equipment by the Contractor upon the removal thereof pursuant to the terms of the Contract.

54.5 Conditions of Hire Contractor's Equipment

With a view to securing, in the event of termination under Clause 63.1 to 63.4, the continued availability, for the purpose of executing the Works, of any hired Contractor's Equipment, the Contractor shall not bring on to the Site any hired Contractor's Equipment unless there is an agreement for the hire thereof (which agreement shall be deemed not to include an agreement for hire purchase) which contains a provision that the owner thereof will, on request in writing made by the Employer within 7 days after the date on which any termination has become effective, and on the Employer undertaking to pay all hire charges in respect thereof from such date, hire such Contractor's Equipment to the Employer on the same terms in all respects as the same was hired to the Contractor save that the Employer shall be entitled to permit the use thereof by any other contractor employed by him for the purpose of execution and completion the Works and remedying any defects therein, under the terms of the said Clause 63.1 to 63.4.

54.6 Costs for the Purpose of Clause - 63.1 to 63.4

In the event of the employer entering into any agreement for the hire of contractor's equipment pursuant to Sub-Clause 54.5, all sums properly paid by the employer under the provisions of any such agreement and all costs incurred by him (Including stamps duties) in entering into such agreement shall be deemed, for the purpose of clause 63.1 to 63.4, to be part of the cost of executing and completing the works and the remedying of any defects therein.

54.7 Corporation of Clause in Sub-contracts

The contractor shall, where entering into any subcontract for execution of any part of the works, incorporate in such subcontract (by reference or other wise) the provisions of this Clause in relation to Contractor's Equipment, Temporary Works or Materials brought on to the Site by the Subcontractor.

54.8 Approval of Material not Implied

The operation of this clause shall not be deemed to imply any approval by the engineer of the materials or other matters referred to therein nor shall

it prevent the rejection of any materials at any time by the Engineer.

MEASUREMENT

55.1 Quantities

The quantities set out in the Bill of Quantities are the estimated quantities for the Works, and they are not to be taken as the actual and correct quantities of the Works to be executed by the Contractor in fulfilment of his obligations under the Contract.

56.1 Works to be Measured

The Engineer shall, except as otherwise stated, ascertain and determine by measurement the value of the works in accordance with the Contract and the Contractor shall be paid that value in accordance with clause 60.1 to 60.14. The Engineer shall, when he requires any part of the Works to be measured, give reasonable notice to the Contractor's agent, who shall :

- (a) forthwith attend or send a qualified representative to assist the Engineer in making such measurement, and
- (b) supply all particulars required by the Engineer

Should the Contractor not attend, or neglect or omit to send such representative, then the measurement made by the Engineer or approved by him shall be taken to be the correct measurement of such part of the Works. For the purpose of measuring such Permanent Works as are to be measured by records and drawings, the Engineer shall prepare records and drawings as the work proceeds and the Contractor, as and when called upon to do so in writing, shall, within 14 days, attend to examine and agree such records and drawings with the Engineer and shall sign the same when so agreed. If the Contractor does not attend to examine such records and drawings and the Contractor does not agree such records and drawings, they shall be taken to be Correct. If, after examination of such records and drawings, the Contractor does not agree the same or does not sign the same as agreed, they shall nevertheless be taken to be correct, unless the Contractor, within 14 days of such examination, lodges with the Engineer notice of the respects in which such records and drawings are claimed by him to be incorrect. On receipt of such notice, the Engineer shall review the records and drawings and either confirm or vary them.

57.1 Method of Measurement

The Works shall be measured net, notwithstanding any general or local custom, except where otherwise provided for in the Contract.

57.2 Breakdown of Lumpsum Items

For the purposes of statements submitted in accordance with Sub-Clause 60.1, the Contractor shall submit to the Engineer, within 28 days after the receipt of the Letter of Acceptance, a breakdown for each of the lump sum items contained in the Tender. Such breakdowns shall subject to the approval of the Engineer.

PROVISIONAL SUMS

58.1 Definition of "Provisional Sum"

"Provisional Sums" means a sum included in the Contract and so designated in the Bill of Quantities for the execution of any part of the Works or for the supply of goods, materials, Plant or services, or for contingencies, which sum may be used, in whole or in part, or not at all, on the instruction of the Engineer. The Contractor shall be entitled to only such amounts in respect of the work, supply or contingencies to which such Provisional Sums relate as the Engineer shall determine in accordance with the Clause. The Engineer shall notify the Contractor of any determination made under this Sub-clause.

58.2 Use of Provisional Sums

In respect of every Provisional Sum the Engineer shall have authority to issue instructions for the execution of works or for the supply of goods, materials, Plant or services by :

- (a) the Contractor, in which case the Contractor shall be entitled to an amount equal to the value thereof determined in accordance with Clause 52.1 to 52.4.
- (b) a nominated Subcontractor, as hereinafter defined, in which case the sum to be paid to the Contractor therefor shall be determined and paid in accordance with Sub-Clause 59.4

58.3 Production of Vouchers

The Contractor shall produce to the Engineer all quotations, invoices, vouchers and accounts or receipts in connection with expenditure in respect of Provisional Sums, except where work is valued in accordance with rates or prices set out in the Tender.

NOMINATED SUBCONTRACTORS

59.1 Definition of "Nominated Subcontractors"

All specialists, merchants, tradesmen and others executing any work or supplying any goods, materials, Plant or services for which Provisional Sums are included in the Contract, who may have been or be nominated or selected or approved by the Engineer, and all persons to whom by virtue of the provisions of the Contract the Contractor is required to subcontract shall, in the execution of such work or the supply of such goods, materials, Plant or services, be deemed to be subcontractors to the Contractor and are referred to in the Contract as "nominated Subcontractors".

59.2 Nominated Subcontractors; Objection to Nomination

The Contractor shall not be required by the Employer or the Engineer, or be deemed to be under any obligation, to employ any nominated Subcontractor against whom the Contractor may raise reasonable objection, or who declines to enter into a subcontract with the Contractor containing provision:

- (a) that in respect of work, goods, materials, Plant or services the subject of the subcontract, the nominated Subcontractor will undertake towards the Contractor such obligations and liabilities as will enable the Contractor to discharge his own obligations and liabilities towards the Employer under the terms of the Contract and will save harmless and indemnify the Contractor from and against the same and from all claims, proceedings, damages, costs, charges and expenses whatsoever arising out of or in connection therewith, or arising out of or in connection with any failure to perform such obligations or to fulfil such liabilities; and
- (b) that the nominated Subcontractor will save harmless and indemnify the Contractor from and against any negligence by the nominated Subcontractor, his agents, workmen and servants and from and against any misuse by him or them of any Temporary Works provided by the Contractor for the Purpose of the Contract and from all claims as aforesaid; and
- (c) approved by the Engineer.

59.3 Design Requirements to be Expressly Stated

If in connection with any Provisional Sums the services to be provided include any matter of design or specification of any part of the Permanent Works or of any Plant to be incorporated therein, such requirement shall

be expressly stated in the Contract and shall be included in any nominated Subcontract. The nominated Subcontract shall specify that the nominated Subcontractor providing such services will save harmless and indemnify the Contractor from and against the same and from all claims, proceedings, damages, costs, charges and expenses whatsoever arising out of or in connection with any failure to perform such obligations or to fulfil such liabilities.

59.4 Payments to Nominated Subcontractors

For all work executed or goods, material, Plant or services supplied by any nominated Subcontractor, the contractor shall be entitled to :

- (a) the actual price paid or due to be paid by the Contractor, on the instructions of the Engineer, and in accordance with the Subcontract;
- (b) in respect of labour supplied by the Contractor, the sum if any, entered in the Bill of Quantities or, if instructed by the Engineer pursuant to paragraph (a) of Sub-clause 58.2, as may be determined in accordance with Clause 52.1 to 52.4;
- (c) in respect of all other charges and profit, a sum being a percentage rate of the actual price paid or due to be paid calculated, where provisions has been made in the Bill of Qualities for a rate to be set against the relevant Provisional Sum, at the rate inserted by the Contractor against that item or, where no such provision has been made, at the rate inserted by the Contractor in the Appendix to Tender and repeated where provision for such is made in a special item provided in the Bill of Quantities for such purpose.

59.5 Certificates of Payments to Nominated Subcontractors

Before issuing, under Clause 60.1 to 60.14, any certificate, which includes any payment in respect of work done or goods, materials, Plants or services supplied by any nominated Subcontractor, the Engineer shall be entitled to demand from the Contractor reasonable proof that all payments, less retentions, included in previous certificates in respect of the work or goods, materials, Plant or services of such nominated Subcontractor have been paid or discharged by the Contractor. If the Contractor fails to supply such proof then, unless the Contractor :

- (a) satisfies the Engineer in writing that he has reasonable cause for withholding or refusing to make such payments and
- (b) produces to the Engineer reasonable proof that he has so

informed such nominated Subcontractor in writing,

the Employer shall be entitled to pay to such nominated Subcontractor direct, upon the certificate of the Engineer, all payments, less retentions, provided for in the nominated Subcontractor and to deduct by way of set-off the amount so paid by the Employer from any sums due or to become due from the Employer to the Contractor.

Provided that, where the Engineer has certified and the Employer has paid direct as aforesaid, the Engineer shall, in issuing any further certificate in favour of the Contractor, deduct from the amount so paid, direct as aforesaid, but shall not withhold or delay the issue of the certificate itself when due to be issued under the terms of the Contract.

CERTIFICATES AND PAYMENTS

60.1 Monthly Statements

The Contractor shall submit a statement in 3 copies to the Engineer by 7th day of each month for the work executed upto the end of previous month in a tabulated form approved by the Engineer, showing the amounts to which the Contractor considers himself to be entitled. the statement shall include the following items, as applicable, which shall be taken into account in the sequence listed:

- (a) The value of the Temporary and Permanent Works executed up to the end of the month in question, at base unit rates and prices.
- (b) The actual value certified for payment for the Temporary and Permanent Works executed up to the end of the previous month, at base unit rates and prices.
- (c) The estimated contract value at base unit rates and prices of the Temporary and Permanent Works for the month in question, obtained by deducting (b) from (a);
- (d) The value of any variations executed up to the end of the month in question, less the amount certified in the previous Interim Payment Certificate, pursuant to Clause 52.1 to 52.4;
- (e) Amounts approved in respect of Daywork executed up to the end of the month in question, less the amount for Daywork certified in the previous Interim Payment Certificate determined from the Day work Schedule of the Bill of Quantities.

- (f) Amounts reflecting changes in cost and legislation, pursuant to Clause 70.1 to 70.3.
- (g) Any credit or debit for the month in question in respect of materials and Plant for the Permanent Works, under the conditions set forth in Sub-Clause 60.3;
- (h) Any amount to be withheld under the retention provisions of Sub-Clause 60.5, determined by applying the percentage set forth in Sub-Clause 60.5 to the amounts due under paragraphs 60.1(c), (e), (f) and (g);
- (i) Any amounts to be deducted as repayment of the Advance under the provisions of sub-Clause 60.7; and
- (j) Any other sum, to which the Contractor may be entitled under the contract.
- (k) 75% of the value of materials delivered to the site for permanent works on signing of the Indenture for secured advance format of which is enclosed at Annexure - A.
- (l) all statutory deductions like Income tax, Works Contract tax etc , as applicable from time to time, shall be deducted from the bills.

60.2 Monthly Payments

The said statement shall be approved / amended by the Engineer in such a way that, in his opinion, it reflects the amounts due to the Contractor in accordance with the Contract, after deduction, other than pursuant to Clause 47.1 to 47.2, of any sums which may have become due and payable by the Contractor to the Employer. In cases where there is a difference of opinion as to the value of any item, the Engineer's view shall prevail. Within the 7th day of the month following the receipt of the monthly statement referred to in Sub-Clause 60.1, the Engineer shall determine the amounts due to the Contractor and shall issue to the Contractor a certificate herein called "Interim Payment Certificate", certifying the amounts due to the contractor.

Notwithstanding the terms of this Clause or any other Clause of the Contract, no amount will be certified by the Engineer for payment until the performance security has been provided by the Contractor and approved by the consultant.

60.3 Materials and Plant for the Permanent Works

With respect to materials and Plant brought by the Contractor to the Site for incorporation in the Permanent Works, the Contractor shall (i) receive a credit in the month in which these materials and Plant are brought to the site and (ii) be charged a debit in the month in which they are

incorporated in the Permanent Works, both such credit and debit to be determined by the engineer in accordance with the following provisions:

- (a) no credit shall be given unless the following conditions shall have been met to the Engineer's satisfaction:
 - i) the materials and Plant are in accordance with specifications for the Works;
 - ii) the materials and Plant have been delivered to the Site and are properly stored and protected against loss, damage or deterioration;
 - iii) the Contractor's records of the requirements, order, receipts and use of materials and Plant are kept in a form approved by the engineer, and such records are available for inspection by the Engineer.
 - iv) the Contractor has submitted a statement of his cost of acquiring and delivering the materials and Plant to the site, together with such documents as may be required for the purpose of evidencing such cost; and
- (b) the amount to be credited to the Contractor shall be equivalent of 75 percent of the Contractor's reasonable cost of the materials and Plant delivered to the Site, as determined by the Engineer after review of the documents listed in paragraph (a) (iv) above, as determined by the Engineer;
- (c) the amount to be debited to the Contractor for any materials and Plant incorporated into the Permanent Works shall be equivalent to the credit previously granted to the contractor for such materials and Plant pursuant to Sub-Clause(b) above, as determined by the Engineer.

60.4 Place of Payments

Payments to the Contractor by the consultant shall be made in Indian Rupees into a bank account or accounts nominated by the Contractor or by account payee cheque.

60.5 Retention Money

- (a) Retention money @ 6% (Six) shall be deducted from each interim certificate subject to a maximum of 5% (Five) of the Contract price.

60.6 Payment of Retention Money

- (a) Upon the issue of the Taking-Over Certificate with respect to the whole of the Works, one half of the retention money deducted from running bills of Contractor may be released.
- (b) Upon the expiry of Defects Liability period for the works and rectification of defects therein the balance half of retention money deducted from running bills of Contractor may be released.

60.7 Advance Payment (Deleted)

60.8 Time of Payment

The amount due to the Contractor under any Interim Payment Certificate issued by the Engineer pursuant to this Clause, or to any other term of the Contract, shall, subject to Clause 47.1 to 47.2, be paid by the Employer to the Contractor within 60 days after the Contractor's monthly statement has been submitted to the Engineer for certification or, in the case of the Final Certificate pursuant to Sub-Clause 60.13, within 90 days after the agreed Final Statement and written discharge have been submitted to the Engineer for certification.

60.9 Correction of Certificates

The Engineer may by any Interim Payment Certificate make any correction or modification in any previous Interim payment Certificate which has been issued by him, and shall have authority, if any work is not being carried out to his satisfaction, to omit or reduce the value of such work in any Interim Payment Certificate.

60.10 Statement of Completion

Not later than 84 days after the issue of the Taking-Over Certificate in respect of the whole of the Works, the Contractor shall submit to the Engineer a Statement of Completion with supporting documents showing in detail, in the form approved by the Engineer.

- (a) the final value of all work done in accordance with the Contract up to the date stated in such Taking-Over Certificate;

- (b) any further sums which the Contractor considers to be due; and
- (c) an estimate of amounts which the Contractor considers will become due to him under the Contract.

Estimated amounts shall be shown separately in such Statement at Completion. The Engineer shall certify payment in accordance with Sub-Clause 60.2 as if the statement of completion were a statement submitted by the contractor under clause 60.1.

60.11 Final Statement

Not later than 56 days after the issue of the Defects Liability Certificate pursuant to Sub-Clause 62.1, the Contractor shall submit to the Engineer for consideration a draft final statement with supporting documents showing in detail, in the form approved by the Engineer.

- (a) the value of all work done in accordance with the Contract; and
- (b) any further sums which the Contractor considers to be due to him under the Contract.

If the Engineer disagrees with or cannot verify any part of the draft final statement, the Contractor shall submit such further information as the Engineer may reasonably require and shall make such changes in the draft as may be agreed between them. The Contractor shall then prepare and submit to the Engineer the final statement as agreed (for the purposes of these Conditions referred to as the "Final Statement").

If, following discussions between the Engineer and the Contractor and any changes to the draft final statement which may be agreed between them, it becomes evident that a dispute exists, the engineer shall issue an Interim Payment Certificate for those parts of the draft final statement which are not in dispute. The dispute shall then be settled in accordance with Clause 67.1 to 67.4. The Final Statement shall be agreed upon settlement of the dispute.

60.12 Discharge

Upon submission of the Final Statement, the Contractor shall give to the Employer, with a copy to the Engineer, a written discharge confirming that the total of the Final Statement represents full and final settlement of all monies due to the Contractor arising out of or in respect of the contract. Provided that such discharge shall become effective only after payment due under the Final Certificate issued pursuant to Sub-Clause 60.13 has

been made and the performance security referred to in Sub- Clause 10.1 has been returned to the Contractor.

60.13 Final Certificate

Within 28 days after receipt of the Final Statement, and the written discharge, the Engineer shall issue to the employer (with a copy to the Contractor) a Final Certificate stating:

- (a) the amount which, in the opinion of the Engineer, is finally due under the Contract, and
- (b) after giving credit to the Employer for all amounts previously paid by the Employer and for all sums to which the Employer is entitled under the Contract, other than Clause 47.1 to 47.2, the balance, if any, due from the Employer to the Contractor or from the Contractor to the Employer as the case may be.

60.14 Cessation of Employer's Liability

The Employer shall not be liable to the Contractor for any matter or thing arising out of or in connection with the Contract or execution of the Works, unless the Contractor shall have included a claim in respect thereof in his Final Statement and (except in respect of matters of things arising after the issue of the Taking-Over Certificate in respect of the whole of the Works) in the Statement at Completion referred to in Sub-Clause 60.10.

61.1 Defects Liability Certificate

The Contract shall not be considered as completed until a Defects Liability Certificate shall have been signed by the Engineer and delivered to the Employer, with a copy to the Contractor, stating the date on which the Contractor shall have completed his obligations to execute and complete Works and remedy any defects therein to the Engineer's satisfaction. The Defects Liability Certificate shall be given by the Engineer within 28 days after the expiration of the Defects Liability Period, or, if different defects liability periods shall become applicable to different sections or part of the Permanent Works, the expiration of the latest such period, or as soon thereafter as any works instructed, pursuant to Clause 49.1 to 49.4 and 50.1, have been completed to the satisfaction of the Engineer. Provided that the issue of the Defects Liability Certificate shall not be condition precedent to payment to the Contractor of the second portion of the Retention Money in accordance with the conditions set out in Sub-Clause 60.3.

62.1 Unfulfilled Obligations

Notwithstanding the issue of the Defects Liability Certificate the Contractor and the Employer shall remain liable for the fulfilment of any obligation incurred under the provisions of the Contract prior to the issue of the Defects Liability Certificate which remains unperformed at the time such Defects Liability Certificate is issued and, for the purpose of determining the nature and extent of any such obligation, the Contract shall be deemed to remain in force between the parties to the Contract.

REMEDIES

63.1 Default of Contractor

If the Contractor is deemed by law unable to pay his debts as they fall due, or enters in to voluntary or involuntary bankrupt, liquidation or dissolution (other than a voluntary liquidation for the purposes of amalgamation or reconstruction), or become insolvent, or makes an arrangement with, or assignment in favour of, his creditors or agrees to carry out the Contract under a committee of inspection of his creditors, or if a receiver, administrator, trustee or liquidator is appointed over any substantial part of his assets, or if, under any law or regulation relating to reorganisation, arrangement or readjustment of debts proceedings are, commenced against the Contractor or resolution passed in connection with dissolution or liquidation or, if any, step are taken to enforce any security interest over a substantial part of the assets of the Contractor, or if, any act is done or event occurs with respect to the Contractor or his assets which under any applicable law has a substantially similar effect to any of the foregoing acts or events, or if the Contractor has contravened Sub-Clause 3.1, or has an execution levied on his goods, or if the Engineer certifies to the Employer, with a copy to the Contractor, that, in his opinion the contractor

- (a) has repudiated the Contract, or
- (b) without reasonable excuse has failed
 - (i) to commence the work in accordance with Sub-Clause 41.1, or
 - (ii) to proceed with the Works, or any section thereof, within 28 days after receiving notice to pursuant to Sub-Clause 46.1, or
- (c) has failed to comply with a notice issued pursuant to Sub-Clause 37.4, or an instruction issued pursuant to Sub-Clause 39.1 within 28 days after receiving it, or

- (d) despite previous warning from the Engineer, in writing, is otherwise persistently or flagrantly neglecting to comply with any of the obligation under the Contract, or
- (e) has contravened Sub-clause 4.1 :

then for the avoidance of doubt the contractor shall be in default of its obligations under this contract and furthermore the Employer may, after giving fourteen days' notice to the Contractor, enter upon the Site and expel the Contractor there from without thereby voiding the Contract, or releasing the Contractor from any of his obligations or liabilities under the Contract, or affecting the rights and powers conferred on the employer or the Engineer by the Contract, and may himself complete the Works or may employ any other contractor to complete the Works. The Engineer shall certify such completion so as to give effect to clauses 49.1(a) and 63.3. The Employer or such other contractor may use for such completion so much of the Contractor's Equipment, Plant, Temporary Works and materials which have been deemed to be reserved exclusively for the execution of the Works, under provisions of the Contract, as he or they may think proper, and the Employer may, at any time, sell any of the said Contractor's Equipment, Temporary Works and unused Plant and materials and apply the proceeds of sale in or towards the satisfaction of any sums due or which may become due to him from the Contractor under the Contract.

63.2 Valuation at Date of Expulsion

The Engineer, as soon as may be practicable after any such entry and expulsion by the Employer, shall fix and determine ex parte, or by or after reference to the parties or after such investigation or enquiries as he may think fit to make or institute, and shall certify :

- (a) what amount (if any) had, at the time of such entry and expulsion, been reasonably earned by or would reasonably accrue to the Contractor in respect of work then actually done by him under the Contract, and
- (b) the value of any of the said unused or partially used materials, any Contractor's Equipment and any Temporary Works.

63.3 Payments after Expulsion

If the Employer shall enter upon the site and expel the Contractor there from under Clause 63.1, he shall not be liable to pay to the Contractor

any further amount (including damages) in respect of the Contract until the expiration of the Defects Liability Period and thereafter until the costs of execution completion and remedying of any defects, damages for delay in completion (if any) and all other expenses incurred by the Engineer have been ascertained and the amount thereof certified by the Engineer. The Contractor shall then be entitled to receive only such sum (if any) as the Engineer may certify would have been payable to him upon due completion by him after deducting the said amount. If such amount exceeds the sum which would have been payable to the Contractor on due completion by him, then the Contractor shall, upon demand, pay to the Employer the amount of such excess and it shall be deemed a debt due by the Contractor to the Employer and shall be recoverable accordingly.

63.4 Assignment of Benefit of Agreement

Unless prohibited by law, the Contractor shall, if so instructed by the Engineer within 14 days of such entry and expulsion referred to in Sub-Clause 63.1, assign to the Employer the benefit of any agreement for the supply of any goods or materials or services and/or for the execution of any work for the purpose of the Contract, which the Contractor may have entered into.

64.1 Urgent Remedial Works

If, by reason of any accident, or failure, or other event occurring to or in connection with the Works, or any part thereof, either during the execution of the Works, or during the Defects Liability Period, any remedial or other work is, in the opinion of the Engineer, urgently necessary for the safety or progress of the Works and the Contractor is unable or unwilling at once to do such work, the Employer shall be entitled to employ and pay other person to carry out such work as the Engineer may consider necessary. If the work or repair so done by the Employer is work which, in the opinion of the Engineer, the Contractor was liable to do at his own cost under the contract, then all costs consequent thereon or incidental thereto shall after due consultation with the Contractor, be determined by the Engineer and shall be recoverable from the Contractor by the Engineer, and may be deducted by the employer from any monies due or to become due to the Contractor and the Engineer shall notify the Contractor accordingly. Provided that the Engineer shall, as soon after the occurrence of any such emergency as may be reasonably practicable notify the Contractor thereof.

SPECIAL RISKS

65.1 No Liability for Special Risks

The Contractor shall be under no liability whatsoever in consequence of any of the special risks referred to in Sub-Clause 65.2 whether by way of indemnity or otherwise, for or in respect of :

- (a) destruction of or damage to the "Works", save to work condemned under the provisions of Clause 39.1 to 39.2 prior to the occurrence of any of the said special risks, or
- (b) destruction of or damage to property, whether of the employer or third parties, or
- (c) injury or loss of life.

65.2 Special Risks

The special risks are :

- (a) the risks defined under paragraphs (a) sub-para (i), (ii), (iii) and (iv) of Sub-Clause 20.4.

65.3 Damage to Works by Special Risks

If the Works or any materials or Plant on or near or in transit to the Site, or any of the Contractor's Equipment, sustain destruction or damage by reason of any of the said special risks, the Contractor shall be entitled to payment in accordance with the Contract for any Permanent Works duly executed and for any materials or Plant so destroyed or damaged and, so far as may be required by the Engineer or as may be necessary for the completion of the Works, to payment for;

- (a) rectifying any such destruction or damage to the Works, and
- (b) replacing or rectifying such materials or contractor's Equipment and the Engineer shall determine an addition to the Contract Price in accordance with Clause 52.1 to 52.4 (which shall be the case of the cost of replacement of Contractor's Equipment include the fair market value thereof as determined by the Engineer) and shall notify the Contractor accordingly, with a copy to the Employer.

65.4 Projectile, Missile

Destruction, damage, injury or loss of life caused by the explosion or impact, whenever and wherever occurring, or any mine, bomb, shell, grenade, or other projectile, missile, munition, or explosive of war, shall be deemed to be a consequence of the said special risks.

65.5 Increased Costs arising from Special Risks

Save to the extent that the Contractor is entitled to payment under any other provision of the Contract, the Employer shall repay to the Contractor any costs of the execution of the Works (other than such as may be attributable to the cost of reconstructing work condemned under the provisions of Clause 39.1 to 39.2 prior to the occurrence of any special risk) which are howsoever attributable to or consequent on or the result of or in any way whatsoever connected with the said special risks, subject however to the provisions in this Clause hereinafter contained in regard to outbreak of war, but the Contractor shall, as soon as any such cost comes to his knowledge, forthwith notify the Engineer thereof. The Engineer shall, after due consultation with the Contractor, determine the amount of the contractor's costs in respect thereof which shall be added to the Contract Price and shall notify the Contractor accordingly.

65.6 Outbreak of War

If, during the currency of the Contract, there is an outbreak of war, whether war is declared or not, in any part of the world which, whether financially or otherwise, materially affects the execution of the Works, the Contractor shall, unless and until the Contract is terminated under the provisions of this Clause, continue to use his best endeavours to complete the execution of the Works. Provided that the employer shall be entitled, at any time after such outbreak of war, to terminate the Contract by giving notice to the Contractor and, upon such notice being given, the Contract shall, except as to the rights of the parties under this Clause and to the operation of Clause 67.1 to 67.4, terminate, but without prejudice to the rights of either party in respect of any antecedent breach thereof

65.7 Removal of Contractor's Equipment on Termination

If the Contract is terminated under the provision of Sub-Clause 65.6, the Contractor shall with all reasonable dispatch, remove from the Site all Contractor's Equipment and shall give similar facilities to his Subcontractors to do so.

65.8 Payment if Contract Terminated

If the Contract is terminated as aforesaid, the Contractor shall be paid by the Employer insofar as such amounts or items have not already been covered by payments account made to the Contractor, for all work executed prior to the date of termination at the rates and prices provided in the contract and in addition:

- a) The amounts payable in respect of any preliminary items referred to in the Bill of Quantities, so far as the Work or service comprised therein has been partially carried out or performed.
- b) The cost of materials, plant or goods reasonably ordered for the Works which have been delivered to the Contractor or of which the Contractor is legally liable to accept delivery, such materials, Plant or goods becoming the property of the Employer upon such payments being made by him.
- c) A sum being the amount of any expenditure reasonably incurred by the Contractor in the expectation of completing the whole of the Works insofar as such expenditure has not been covered by any other payments referred to in this Sub-Clause.
- d) Any additional sum payable under the provisions of Sub-Clauses 65.3 and 65.5.
- e) Such proportion of the cost as may be reasonable, taking into account payments made or to be made, for work executed, or removal of contractor's equipment under Sub- Clause 65.7 and, if required by the Contractor, return thereof to the Contractor's main plant yard in his country of registration or to other destination, at no grater cost.
- f) The reasonable cost of repatriation of all the Contractor's staff and workmen employed on or in connection with the Works at the time of such termination.

Provided that against any payment due from the Employer under this Sub-Clause, the Employer shall be entitled to be credited with any outstanding balances due from the Contractor for advances in respect of Contractor's Equipment, materials and Plant and any other sums which, at the date of termination, were recoverable by the employer from the Contractor under the terms of the Contract. Any sums payable under this Sub- Clause shall, after due consultation with the Employer and the Contractor, be determined by the Engineer who shall notify the Contractor accordingly.

RELEASE FROM PERFORMANCE

66.1 Payment in Event of Release from Performance

If any circumstance outside the control of both parties arises after the issue of the Letter of Acceptance which renders it impossible or unlawful for either party to fulfil his contractual obligations, or under the law

governing the Contract the parties are released from further performance, then the sum payable by the employer to the Contractor in respect of the work executed shall be the same as that which would have been payable under Clause 65.8 if the Contract had been terminated under the provisions of Clause 65.6.

SETTLEMENT OF DISPUTES

67.1 Engineer's Decision

If a dispute of any kind whatsoever arise between the Employer and the Contractor in connection with, or arising out of, the Contract or the execution of the Works, whether during the execution of the Works or after their completion and whether before or after repudiation or other termination of the Contract, including any dispute as to any opinion, instruction, determination, certificate or valuation of the engineer, the matter in dispute shall, in the first place, be referred in writing to the Engineer, with a copy to the other party. Such reference shall state that it is made pursuant to this Clause. Not later than the eighty-fourth day after the day on which he received such reference the Engineer shall give notice of his decision to the Employer and the Contractor. Such decision shall state that it is made pursuant to this Clause.

Unless the Contract has already been repudiated or terminated, the Contractor shall, in every case, continue to proceed with the Work with all due diligence and the Contractor and the Employer shall give effect forthwith to every such decision of the Engineer unless and until the same shall be revised, as hereinafter provided in an amicable settlement or an arbitral award.

If either the Employer or the Contractor be dissatisfied with any decision of the Engineer, or if the Engineer fails to give notice of his decision on or before the eighty fourth day after the day on which he received the reference, then either the Employer or the Contractor may, on or before the seventieth day after the day on which he received notice of such decision, or on or before the seventieth day after the day on which the said period of 84 days expired, as the case may be give notice to the other party, with a copy for information to the Engineer of his intention to commence arbitration as hereinafter provided, as to the matter in dispute. Such notice shall establish the entitlement of the party giving the same to commence arbitration, as hereinafter provided, as to such dispute and, subject to Sub-Clause 67.4, no arbitration in respect thereof may be commenced unless such notice is given.

If the Engineer has given notice of his decision as to a matter in dispute to the Employer and the Contractor and no notice of intention to commence

arbitration as to such dispute has been given by either the Employer or the Contractor on or before the seventieth day after the day on which the parties received notice as to such decision from the Engineer, the said decision shall become final and binding upon the Employer and the Contractor.

67.2 Conciliation

Where notice of intention to commence arbitration as to dispute has been given in accordance with Sub Clause 67.1, arbitration of such dispute shall not be commenced unless, the parties have explored the possibility of conciliation as per the provisions of Part-III of the Arbitration and Conciliation Act, 1996. When such conciliation has failed, the parties shall adopt the following procedure for arbitration :-

67.3 Arbitration

67.3.1

Any dispute and differences relating to the meaning of the specifications, designs, drawings and instructions herein before mentioned and as to the quality of workmanship or materials used in the work or as to any other question, claim, right, matter or thing whatsoever in any way arising out of or relating to the contract, designs, drawings, specifications, estimates, instructions, or these conditions or otherwise concerning the works or the execution or failure to execute the same whether arising during the progress of the work or after the completion or abandonment thereof in respect of which :-

- a) the decision, if any, of the Engineer has not become final and binding pursuant to Sub Clause 67.1 and
- b) Conciliation has not been reached as per the provisions of Clause 67.2

Shall be referred to the Sole Arbitration of a person appointed by the Chairman and Managing Director (CMD) of HSCC (I) Ltd. from the panel of Arbitrators approved by MOH&FW/ Director Central Food Laboratory Mumbai. Such Arbitrator shall be appointed within 30 days of the receipt of letter of invocation of Arbitration duly satisfying the requirements of this clause.

67.3.2

If the Arbitrator so appointed resigns his appointment, is unable or unwilling to act due to any reason whatsoever, or dies, the Chairman and Managing Director aforesaid or in his absence the person discharging the duties of CMD of HSCC (I) Ltd. may appoint a new Arbitrator in accordance with these terms and conditions of the contract, to act in his place and the new Arbitrator so appointed may proceed from the stage at

which it was left by his predecessor.

- 67.3.3** It is a term of the contract that the party invoking the Arbitration shall specify the dispute/differences or questions to be referred to the arbitrator under this clause together with the amounts claimed in respect of each dispute.
- 67.3.4** The Arbitrator may proceed with the Arbitration ex-parte, if either party, in spite of a notice from the Arbitrator, fails to take part in the proceedings.
- 67.3.5** The work under the contract shall continue, if required, during the Arbitration proceedings.
- 67.3.6** The Arbitrator shall make speaking Award and give reasons for his decision in respect of each dispute/claim alongwith the sums awarded separately on each individual item of dispute or difference or claims. The Arbitrator shall make separate award on each reference made to him.
- 67.3.7** The award of the Arbitrator shall be final, conclusive and binding on both the parties.
- 67.3.8** Subject to the aforesaid, the provisions of the Arbitration & Conciliation Act, 1996 or any statutory modifications or re-enactment thereof and the Rules made thereunder and for the time being in force shall apply to the Arbitration proceedings and Arbitrator shall publish his Award accordingly.

67.4 Failure to Comply With Engineer's Decision

Where neither the Employer nor the contractor has given notice of intention to commence arbitration of a dispute within the period stated in Sub-Clause 67.1 and the related decision has become final and binding either party may, if the other party fails to comply with such decision, and without prejudice to any other rights it may have, refer the failure to arbitration in accordance with sub-Clause 67.3 as if the conditions specified in clauses 67.3(a) and (b) had been satisfied with respect to such dispute. The provisions of Sub-Clause 67.1 shall not apply to any such reference.

NOTICES

68.1 Notice to Contractor

All certificates, notices or instructions to be given to the Contractor by the Employer or the Engineer under the terms of the Contract shall be sent by post, cable, telex or facsimile transmission to or left at the Contractor's principal place of business or such other address as the Contractor shall nominate for the purpose.

68.2 Notice to Employer and Engineer

Any notice to be given to the Employer or to the Engineer under the terms of the Contract shall be sent by post, cable telex or facsimile transmission to or left at the respective addresses nominated for the purpose in part II of these Conditions.

68.3 Change of Address

Either party may change a nominated address to another address in the Country where the Works are being executed by prior notice to the other party, with a copy to the Engineer, and the Engineer may do so by prior notice to both parties.

DEFAULT OF EMPLOYER

69.1 Default of Employer

In the event of the Employer:

- a) becoming bankrupt or being a company, going into liquidation, other than for the purpose of a scheme of reconstruction or amalgamation, or
- b) giving notice to the Contractor that for unforeseen reasons, due to economic dislocation, it is impossible for him to continue to meet his contractual obligations, or
- c) if the contractor becomes entitled under Sub-Clause 40.3 to terminate his employment under the contract in accordance with the provisions of this Sub-Clause,

the Contractor shall be entitled to terminate his employment under the contract by giving notice to the Employer, with a copy to the Engineer. Such termination shall take effect 14 days after the giving of the notice.

69.2 Removal of Contractor's Equipment

Upon the expiry of the 14 days notice referred to in Sub-Clause 69.1 the Contractor shall notwithstanding the provisions of Sub-Clause 54.1, with all reasonable despatch, remove from the site all contractor's equipment brought by him thereon.

69.3 Payment on Termination

In the event of such termination the employer shall be under the same

obligations to the contractor in regard to payment as if the contract has been terminated under the provisions of clause 65.6, but, in addition to the payments specified in Sub- Clause 65.8 the Employer shall pay to the Contractor the amount of any loss or damage to the Contractor arising out of or in connection with or by consequence of such termination.

69.4 Contractor's Entitlement to suspend Works

Without prejudice to the Contractor's entitlement to interest under Sub-Clause 60.8 and to terminate under Sub-Clause 69.1, the Contractor may, if the Employer fails to pay the Contractor the amount due under any certificate of the Engineer within 28 days after the expiry of the time stated in Sub- Clause 60.8 within which payment is to be made, subject to any deduction that the Employer is entitled to make under the Contract, after giving 28 days' prior notice to the Employer, with a copy to the Engineer, suspend work or reduce the rate of work.

If the contractor suspends work or reduces the rate of work in accordance with the provisions of this Sub- Clause and thereby suffers delay or incurs cost the Engineer shall after due consultation with the Contractor, determine

- a) any extension of time to which the contractor is entitled under clause 44.1 to 44.3, and
- b) the amount of such costs, which shall be added to the contract price.

And shall notify the Contractor accordingly.

CHANGES IN COST AND LEGISLATION

70.1 Increase or Decrease of Cost

It shall be added to or deducted from the Contract price such sums in respect of rise or fall in the cost of labour and / or materials or any other matters affecting the cost of the execution of the works as may be determined in accordance with Clause 36.2 of SCC.

70.2 Subsequent Legislation

If, after the date 28 days prior to the latest date for submission of tenders for the Contract there occur in the country in which the works are being or are to be executed changes to any National or State Statute Ordinance Decree or other Law or any regulation or bye -law of any local or other duly constituted authority, or the introduction of any such State Statute,

Ordinance, Decree, Law, regulation or bye-law which causes additional or reduced cost to the contractor other than under sub-clause 70.1 in the execution of the Contract, such additional or reduced cost shall after due consultation with the employer and the Contractor be determined by the Engineer and shall be added to or deducted from the contract price and the engineer shall notify the Contractor accordingly.

70.3 Other Changes in Cost

To the extent that full compensation for any rise or fall in costs to the Contractor is not covered by the provisions of this or other Clauses in the Contract, the unit rates and prices included in the Contract shall be deemed to include amounts to cover the contingency of such other rise or fall of costs.

71.1 Engineer's Authority to Correct Errors

The Engineer shall at the request of either or both parties, or at his own initiative, subject to the provisions of this subclause and with retrospective effect from the date of this Contract have authority to make a determination correcting any manifest error (including for the avoidance of doubt and without prejudice to the generality of the Engineer's authority in this regard any error of spelling, grammar or punctuation and any omission, inclusion or misplacement of text) in any provision of this Contract Provided always that:

- (a) The Engineer before making such determination shall by notice to the Employer and the Contractor provide them with a draft thereof and give them a reasonable time in which to comment on the draft.
- (b) The Engineer shall in making such determination take into consideration the presumed intentions of the parties, the wording of any provision of the Conditions of Contract for use in connection with Works of Civil Engineering Construction Fifth Edition (June 1973) (Revised January 1979) ("the ICE Conditions of Contract") or of any other standard form of contract upon which the provision to be corrected has been based, and any comments received by the Employer and/or the Contractor on the draft determination provided to them under subclause (a) of this clause.
- (c) The Engineer shall provide the Employer and the Contractor with a copy of the determination made by him and
- (d) Clause 67.1 to 67.4 shall for the avoidance of doubt apply to any dispute between the Employer and the Contractor in connection with or arising out of the Engineer's determination.

- (e) The law which applies to the Contract is the law of Union of India, that of Delhi High Court. Arbitration procedure as per Arbitration and Reconciliation Act 1996.

Court Jurisdiction – New Delhi

Place where arbitration will take place - Noida

**CENTRAL FOOD & DRUG TESTING LABORATORY
MUMBAI**

**TENDER
FOR**

**HVAC, CLEAN ROOM AND ALLIED WORKS FOR
MICROBIOLOGY LAB FOR FOOD & DRUG
TESTING LABORATORY MUMBAI**

VOLUME - III

**INSTRUCTION TO BIDDERS
SPECIFIC CONDITIONS OF CONTRACT**

DECEMBER 2008

HSCC (INDIA) LTD.

(Consultants & Engineers for Mega Hospitals & Laboratories)
E - 6 (A), Sector - I, NOIDA (U.P.) - 201 301 (INDIA)

PHONE : 91-2542436, 2542440
91-2542443, 2542445

FAX : 91-11-91-2542447
E- mail : hsccltd @hsccltd.co.in

Tender No **HSCC/139/PM/-HVAC-F&D Mumbai/2008**

INDEX

SPECIFIC CONDITIONS OF CONTRACT

Clause No.	Descriptions
Instruction to Bidders	
1.1	Description of Works
1.2	The Employer
2.0	Information to be submitted
3.0	Cost of Bidding
4.0	Site Visit
Bid Documents	
5.0	Content of Bid Documents
6.0	Clarification on Bid Documents
7.0	Amendment of Bid Documents
Preparation of Bids	
8.0	Language of Bid
9.0	Documents Comprising the Bid
10.0	Bid Prices
11.0	Bid Validity
12.0 & 13.0	Bid Security
14.0	Format and Signing of Bid

Clause No.	Descriptions
-------------------	---------------------

Submission of Bid

15.0	Sealing, Marking & Submission
16.0	Deadline for Submission of Bids
17.0	Late Bids
18.0	Modification and Withdrawal of Bid

Bid Opening and Evaluation

19.0	Bid Opening
20.0	Process to be Confidential
21.0	Clarification of Bids
22.0	Determination of Eligibility & Responsiveness
23.0	Correction of Errors
24.0	Evaluation and Comparison of Bids

Award of Contract

25.0	Award Criteria
26.0	Engineer's Right to accept any bid, to reject any or all bids
27.0	Notification of Award
28.0	Signing of Agreement
29.0	Performance Security

Clause No.	Descriptions
-------------------	---------------------

Specific Conditions of Contract

30.0	Definitions
31.0 & 32.0	Insurance of Works
33.0	Certificates and Payments
34.0	Settlement of Disputes - Arbitration
35.0	Address
36.1	Labour
36.1.1	Engagement of Labour
36.1.2	Supply of Water
36.1.3	Fair Wages
36.1.4	Fair Wages
36.1.5,36.1.6.36.1.7	Wage Records
36.1.8 & 36.1.9	Inspection of Wage Records
36.2	Variation in Price (Deleted)
36.2.1	Subsequent Legislation
37.0	Taxation
38.0	Co-ordination Meeting
39.0	Special Applications
39.1	Site Information
39.2	Special Instruction

Clause No.	Descriptions
39.2.1	Contractors Working Area
39.2.2	Contractors Temporary Structures
39.2.3	Procurement of Various Materials
39.2.4	Water Supply & Power Supply
39.2.5	Telecommunications
39.2.6	Temporary Fencing
39.2.7	Testing of Materials
39.2.8	Approval of Samples prior to use
39.2.9	Bar Bending Schedule
39.3	Drawing to be supplied by Engineer
39.4	As Made Drawings
39.5	Progress Photographs
39.6	Programme of Work and Progress Report
39.7	Metric Units
39.8	Field Materials Testing Laboratory
40.0	Rates/Prices
41.0	Compliance for Statutory Obligations
42.0	Unpriced Bids

ADDITIONAL SPECIFIC CONDITIONS OF CONTRACT

AND

SPECIFICATIONS

Clause No.	Descriptions
	RELATING TO HVAC SYSTEMS
1.0	General
2.0	Scope of contract
3.0	Stores and materials
4.0	Supply of Equipment
5.0	Working Drawings etc.
6.0	Completion Drawings
7.0	Operation and Service Manuals
8.0	Inspection at Contractor's Premises
9.0	Sub - Contracting
10.0	Materials Submittals
11.0	Samples and Prototypes
12.0	Testing and Commissioning
13.0	Provisional Taking Over & Final performance & capacity test
14.0	Operation of Plant
15.0	Guarantee and Defects Liability Period
16.0	Measurement of Works
17.0	Variation in Quantities
18.0	Maintenance
19.0	Performance Guarantee
20.0	Painting

21.0 Safe Custody and Storage

22.0 Terms of Payment

23.0 Training of Personnel

ANNEXURE A Form of Agreement

ANNEXURE B Proforma for Performance Bank Guarantee

ANNEXURE C Proforma for Bid Security Bank Guarantee

ANNEXURE D Appendix to Tender

INDEX

SPECIFIC CONDITIONS OF CONTRACT

Clause No.	Descriptions
Instruction to Bidders	
1.1	Description of Works
1.2	The Employer
2.0	Information to be submitted
3.0	Cost of Bidding
4.0	Site Visit
Bid Documents	
5.0	Content of Bid Documents
6.0	Clarification on Bid Documents
7.0	Amendment of Bid Documents
Preparation of Bids	
8.0	Language of Bid
9.0	Documents Comprising the Bid
10.0	Bid Prices
11.0	Bid Validity
12.0 & 13.0	Bid Security
14.0	Format and Signing of Bid

Clause No.	Descriptions
-------------------	---------------------

Submission of Bid

15.0	Sealing, Marking & Submission
16.0	Deadline for Submission of Bids
17.0	Late Bids
18.0	Modification and Withdrawal of Bid

Bid Opening and Evaluation

19.0	Bid Opening
20.0	Process to be Confidential
21.0	Clarification of Bids
22.0	Determination of Eligibility & Responsiveness
23.0	Correction of Errors
24.0	Evaluation and Comparison of Bids

Award of Contract

25.0	Award Criteria
26.0	Engineer's Right to accept any bid, to reject any or all bids
27.0	Notification of Award
28.0	Signing of Agreement
29.0	Performance Security

Clause No.	Descriptions
-------------------	---------------------

Specific Conditions of Contract

30.0	Definitions
31.0 & 32.0	Insurance of Works
33.0	Certificates and Payments
34.0	Settlement of Disputes - Arbitration
35.0	Address
36.1	Labour
36.1.1	Engagement of Labour
36.1.2	Supply of Water
36.1.3	Fair Wages
36.1.4	Fair Wages
36.1.5,36.1.6.36.1.7	Wage Records
36.1.8 & 36.1.9	Inspection of Wage Records
36.2	Variation in Price (Deleted)
36.2.1	Subsequent Legislation
37.0	Taxation
38.0	Co-ordination Meeting
39.0	Special Applications
39.1	Site Information
39.2	Special Instruction

Clause No.	Descriptions
39.2.1	Contractors Working Area
39.2.2	Contractors Temporary Structures
39.2.3	Procurement of Various Materials
39.2.4	Water Supply & Power Supply
39.2.5	Telecommunications
39.2.6	Temporary Fencing
39.2.7	Testing of Materials
39.2.8	Approval of Samples prior to use
39.2.9	Bar Bending Schedule
39.3	Drawing to be supplied by Engineer
39.4	As Made Drawings
39.5	Progress Photographs
39.6	Programme of Work and Progress Report
39.7	Metric Units
39.8	Field Materials Testing Laboratory
40.0	Rates/Prices
41.0	Compliance for Statutory Obligations
42.0	Unpriced Bids

ADDITIONAL SPECIFIC CONDITIONS OF CONTRACT

AND

SPECIFICATIONS

Clause No.	Descriptions
	RELATING TO HVAC SYSTEMS
1.0	General
2.0	Scope of contract
3.0	Stores and materials
4.0	Supply of Equipment
5.0	Working Drawings etc.
6.0	Completion Drawings
7.0	Operation and Service Manuals
8.0	Inspection at Contractor's Premises
9.0	Sub - Contracting
10.0	Materials Submittals
11.0	Samples and Prototypes
12.0	Testing and Commissioning
13.0	Provisional Taking Over & Final performance & capacity test
14.0	Operation of Plant
15.0	Guarantee and Defects Liability Period
16.0	Measurement of Works
17.0	Variation in Quantities
18.0	Maintenance
19.0	Performance Guarantee
20.0	Painting

21.0 Safe Custody and Storage

22.0 Terms of Payment

23.0 Training of Personnel

ANNEXURE A Form of Agreement

ANNEXURE B Proforma for Performance Bank Guarantee

ANNEXURE C Proforma for Bid Security Bank Guarantee

ANNEXURE D Appendix to Tender

INSTRUCTIONS TO BIDDERS

A. GENERAL

1.0 Description of Works

1.1 “HVAC, Clean room and allied works for Microbiology lab for Food & Drug Testing Laboratory Mumbai .”.

The Scope of work relates to “HVAC, Clean room and allied works for Microbiology lab for Food & Drug Testing laboratory Mumbai”. and their maintenance during defect liability period.”

1.2 The Employer

Ministry of Health & Family Welfare represented by HSCC (India) Ltd, E 6A, Sector-1 Noida – 201301.

1.3 In these documents wherever the word tender/ tenderer/ tendering has been used, the same may be considered synonymous with bid/ bidder/ bidding.

1.4 Time for Completion

The successful bidder shall complete the works within 2.5 (Two and Half) calendar months from Engineer's order to commence the work.

2.0 Informations to be Submitted :

2.1 Bids submitted shall include the following information :

- (a) Copies of original documents defining the constitution, legal status, place of registration and principal place of business of the company or firm.
- (b) A work plan clearly bringing out how the bidder proposes to carry out the work to achieve the quality and the time schedule.

The work plan shall clearly spell out with specific details the following :

- i. Detailed programme in the form of a PERT/CPM network clearly bringing out details of start & completion of all important activities and also programme showing material & labour resources related to the above PERT/CPM network.

- ii. List of equipment along with details proposed to be used on the works.
- iii. List and bio data of Engineers and other important staff members proposed to be employed on the works.

3.0 Cost of Bidding

- 3.1 The bidder shall bear all costs associated with the preparation and submission of his bids and "The Employer" will in no case be responsible or liable for those costs, regardless of the conduct or outcome of the bidding process.

4.0 Site Visit

- 4.1 The bidder is advised to acquaint himself with the job involved, visit the Site & examine soil conditions, climatic conditions, labour, power, water, material availability, transport and communication facilities, environmental regulations, laws and bye-laws of statutory bodies, Government of Maharashtra and the Govt. of India and collect all information that will be necessary for preparing the bid and entering into a contract.

The cost of visiting the Site and collecting information for the purpose of submission of the bid shall be to the bidder's account.

- 4.2 The bidder and any of his personnel or agents will be granted permission by the Employer to enter upon the site for the purpose of such inspection, but only upon the express condition that the bidder, his personnel or agents will release and indemnify the Employer and Employer's Personnel and agents from and against all liability in respect thereof and will be responsible for personnel injury (Whether fatal or otherwise), loss of or damage to property and any other loss, damage, costs and expense however caused, which, but for the exercise of such permission would not have arisen.

B. BID DOCUMENTS

5.0 Content of Bid Documents

- 5.1 The Bid Documents comprise the following :-

Volume- I = Prequalification Document
Volume II = General Conditions of Contract
Volume III = Comprising :-

- Instructions to Bidders
- Specific Conditions of contract
- Technical Specifications
- Sample forms of Securities
- Sample form of Agreement

Volume IV = Bill of Quantities & Form of Bid

6.0 Clarification on Bid Documents

6.1 A prospective bidder requiring any clarifications on the Bid Documents may notify the Engineer in writing or by telex or cable at the Engineer's mailing address indicated in the Bid Documents. A meeting of the prospective bidders shall be held at which the Engineer will respond to any request for clarification, which he receives within two weeks of the first date of the issue of the tenders. Written copies of the Engineer's response (including an explanation of the query but without identifying the source of the inquiry) will be sent to all prospective bidders who have received the Bid Documents.

7.0 Amendment of Bid Documents

7.1 At any time prior to the dead line for submission of bids, the Engineer may for any reason, whether at his own initiative or in response to a clarification requested by the prospective bidder, modify the Bid Documents by amendment.

7.2 The amendment will be sent to all prospective bidders who have received the Bid documents, to arrive not later than 7 days prior to the original or extended deadline for submission of bids, in writing or by telex or cable and will be binding upon them. Prospective bidders should promptly acknowledge receipt thereof by telex or cable to the Engineer.

7.3 In order to afford prospective bidders reasonable time in which to take an amendment into account in preparing their bids, the Engineer may, at his discretion, extend the deadline for the submission of bids.

C. PREPARATION OF BIDS

8.0 Language of Bid

8.1 The bid prepared by the bidders and all correspondence and documents relating to the bid exchanged by the bidder and the Engineer shall be written in the English Language.

9.0 Documents comprising the Bid

9.1 The bid to be prepared by the bidder shall comprise the following: - the Bid and Appendix thereto, the Bid Security, the Bill of Quantities; the Schedules

of Supplementary information, and any other materials required to be completed and submitted in accordance with the instructions to Bidders embodied in these Bid Documents. The forms, bill of quantities and schedules provided in these Bid Documents shall be used without exception.

- 9.2 All documents issued for the purpose of bidding as described in Clause 5.1 and amendments issued in accordance with Clause 7, shall be deemed incorporated in the Bid, Bid Documents prepared and submitted in accordance with Clause 14 and 15 shall be returned by Bidders to the Employer along with the submission of the Bid.

10.0 Bid Prices

- 10.1 The bidder shall fill the rates against each item of BOQ both in words and figures in the blank spaces provided in the respective columns.

- 10.2 All duties, taxes, and other levies payable by the contractor under the contract including contractors profit and over heads etc. or for any other cost shall be included in the rates and prices and the total amount of bid submitted by the bidder and the evaluation and comparison of bids by the Engineer shall be made accordingly.

- 10.3 The rates and prices quoted by the bidder shall be fixed for items complete in all respect for the duration of the contract and not subject to adjustment on any account except as otherwise provided in the conditions of contract.

- 10.4 The bidder shall fill his most competitive rates in the first instance, as no negotiations shall be made after opening of the tenders except if required with the lowest bidder.

11.0 Bid Validity

- 11.1 The bid shall remain valid and open for acceptance for a period of 120 days from the last date fixed for receiving the same.

- 11.2 In exceptional circumstances prior to expiry of the original bid validity period, the Engineer may request the bidder for a specified extension in the period of validity. The request and the responses thereto shall be made in writing or by cable or telex. A bidder may refuse the request without forfeiting his bid security. A bidder agreeing to the request will neither be required nor permitted to modify his bid, but will be required to extend the validity of his bid security correspondingly.

12.0 Bid Security

- 12.1 The bidder shall furnish, as part of his bid, a bid security of the amount of Rs 90,000/- (Rupees Ninety Thousand Only). No deviation shall be permitted from this.
- 12.2 The bid security shall be in the form of a demand draft/pay order/bank guarantee in favour of M/s HSCC (INDIA) Ltd., Plot-6(A), Block-E, Sector-I, NOIDA, UP-201 301 from any Nationalised bank/Scheduled bank.
- 12.3 Any bid not accompanied by an acceptable bid security will be rejected by the Employer/Engineer as non-responsive.
- 12.4 The bid securities of unsuccessful bidders will be returned as promptly as possible but not later than 30 days after the expiration of the period of bid validity prescribed by the employer.
- 12.5 The bid security of the successful bidder will be returned upon the bidder executing the contract and furnishing the required performance security.
- 12.6 The bid security may be forfeited :
- a) If a bidder withdraws his bid during the period of bid validity.
 - b) In the case of successful bidder, if he does not :
 - i) enter into the contract, or
 - ii) furnish the necessary performance security
 - iii) agree to arithmetic corrections made as per terms of bid documents.
- 13.0 No interest will be payable by the engineer on the bid security amount cited above.

14.0 Format and Signing of Bid

- 14.1 The tender shall be filled & signed only by the firm/ corporation/joint venture in whose name the tenders have been issued. The bid shall be typed or written in indelible ink and duly signed by a person or persons duly authorised to being the bidder to the contract. Proof of authorization shall be furnished in the form of written Power of Attorney which shall accompany the bid.
- 14.2 All pages of bid shall be initialled and stamped by the person signing the bid where entries or amendments have been made.
- 14.3 The complete bid shall be without alterations interlining and erasures except those to accord with instruction issued by the Engineer or as necessary to

correct errors made by the bidder in which case such correction shall be initialled by person signing the bid.

15.0 Sealing, Marking & Submission

15.1 The bid shall be submitted in accordance with the procedure detailed herein. Specified documents shall be enclosed in envelope of appropriate size each of which shall be sealed.

(i) Envelope No. 1 : Envelope No. 1 : Shall contain the Bid Securities, Offer letter and other bids volume I, II & III duly signed and stamped with necessary documents as described in prequalification document including the following. Bids containing any conditions are liable to be rejected.

:

(a) Bid Security as indicated in Clause 12 of Instructions to bidders.

(b) Power of attorney of person authorised to sign the bid.

(c) Original bid documents (all pages) & drawing (Volume I, II & III) duly signed and stamped.

(d) Documents regarding constitution of bidder as indicated in Clause 2.1 of these Instructions to Bidders.

(e) Certificate of Registration.

(f) Proposed Supply Schedule.

(ii) Envelope No. 2 : Shall contain only the Bill of Quantities and rates/prices (Volume IV) duly filled in and signed and stamped without any conditions whatsoever on each page. Bids containing any conditions in Envelope No. 2 are liable to be summarily rejected.

The contractor must fill up price against each item of BOQ (Volume IV) both in words and figures in the blank spaces provided in the respective columns. The rates written in words shall prevail in case of any variation between the rates mentioned in figure and words.

Please note that the price should not be indicated in any of the documents enclosed in envelope 1. Non compliance shall entail rejection of the bid.

15.2 The bidder shall seal the bid.

15.3 All the above three envelopes shall be sealed in a fourth envelope and addressed to The General manager (PG-1) , HSCC (INDIA) Ltd., Plot - 6 (A), Block - E, Sector - I, Noida, Uttar Pradesh - 201 301.

15.4 All the above envelope shall bear the following identification.

Name of work: ““HVAC, Clean room and allied works for Microbiology lab for Central Food & drug Testing Laboratory Mumbai “, Tender number, due date and time.

15.5 All the envelopes shall indicate the name and address of the bidder to enable the bid to be returned unopened if required.

15.6 All recipients for the purpose of submitting a bid shall treat the contents of the documents as private and confidential.

16.0 Deadline for submission of bids

16.1 Bids must be received by the Engineer, HSCC (INDIA) Ltd , not later than 15.00 hours of the designated date.

16.2 The Engineer may, at his discretion, extend the deadline for submission of bids through the issuance of an amendment in accordance with Clause 7 in which case all rights and obligations of the Employer and the bidders previously subject to the deadlines shall thereafter be subject to the new deadline as extended.

17.0 Late Bids

17.1 Any bid received by the Employer/Engineer after the prescribed deadline for submission will liable to be rejected and will be returned unopened to the bidder.

18.0 Modification and Withdrawal of Bid

18.1 The bidder may modify or withdraw his bid after bid submission, provided that modification or notice of withdrawal is received in writing by the Engineer prior to the prescribed deadline for submission of bids.

18.2 The bidder's modification or notice of withdrawal shall be prepared, sealed, marked and despatched in accordance with the provisions for the submission of bids. Notice of withdrawal may also be sent by telex or cable but shall be followed by a signed confirmation copy, postmarked not later than the deadline for submission of bids.

- 18.3 No bid may be modified subsequent to the dead line for submission of bids.
- 18.4 No bid may be withdrawn in the interval between the deadline for submission of bids and the expiration of the period of validity of the bid specified. Withdrawal of a bid during this interval may result in the forfeiture of the bid security.
- 18.5 Subsequent to the expiration of the period of validity of bids prescribed in the bid documents, a successful bidder who has not been notified by the Engineer of the award of the contract may withdraw his bid without penalty.

E. BID OPENING AND EVALUATION

19.0 Bid Opening

- 19.1 Bids shall be opened in the office of HSCC at Plot - 6 (A), Block - E, Sector - I, Noida, Uttar Pradesh - 201 301, half an hour after the prescribed time for bid submission in presence of the bidders representative who may wish to be present.

Envelope No. 1 : Shall be opened first. If the Bid Security and prequalification application is not found as prescribed, the bid shall be summarily rejected. Bids of parties who do not accept the conditions laid above in the bid documents are also liable to be rejected.

Bids of parties who do not accept the conditions laid above in the bid documents are also liable to be rejected.

- 19.2. The Engineer will examine the bids to determine whether they are complete, whether they fulfil the prequalification criteria, whether the requisite bid securities have been furnished, whether the bids have been properly signed and stamped and whether the bids are generally in order.
- 19.3 Telegraphic/ Fax offer will be treated as defective, invalid and rejected. Only detailed complete bids received prior to the closing time and date of the bids will be taken as valid.
- 19.4 The bidder's names, general technical details, the presence of the requisite bid security and such other details as the Engineer, at his discretion may consider appropriate will be announced at the bid opening.

Envelope No. 2 : Contain the sealed price bid of parties whose bid is found to be generally in order, meets the prequalification criteria and substantially responsive shall be opened either at the bid opening or at a subsequent date to be intimated in advance to such eligible bidders

- 19.5 Only summary of prices quoted by the bidders will be read out.
- 19.6 The bid of any bidder who has not complied with any of the instructions contained herein may not be considered.

20.0 Process to be Confidential

- 20.1 After the public opening of bids, information relating to the examination, clarification, evaluation and comparisons of bids and recommendations concerning the award of contract shall not be disclosed to bidders or other persons not officially concerned with such process.
- 20.2 Any effort by the bidder to influence the Employer/ Engineer in the process of examination, clarification, evaluation and comparison of bids and decision concerning award of contract may result in the rejection of the bidder's bid.

21.0 Clarification of Bids

- 21.1 To assist in the examination, evaluation and comparison of bids, the Engineer may ask bidders individually for clarification of their bids, including breakdowns of unit prices. The request for clarification and the response shall be in writing or cable or telex, but no change in the price or substance of the bid shall be sought, offered or permitted except as required to confirm the correction or arithmetical errors discovered by the Engineer during the evaluation of the bids in accordance with Clause 24 hereof.

- 22.1 The Engineer will determine whether the bid is substantially responsive to the requirements of the Bid Documents.

For the purpose of this clause, a substantially responsive bid is one which conforms to all the terms, conditions and specifications of the bid documents without any deviation or reservation.

- 22.2 A bid which in relation to the cost estimate of the Engineer is unrealistically priced and which cannot be substantiated satisfactorily by the bidder may be rejected as non responsive.

23.0 Correction of Errors

- 23.1 Bids determined to be substantially responsive will be checked by the Engineer for any arithmetical errors in computation and summation. Errors will be dealt by the Engineer as follows :-

- a) Where there is discrepancy between rates indicated in figures and in words, rates in words will govern.
- b) Incorrectly added totals will be corrected.
- c) In case of any clerical error between the rates indicated in figures and words, the rate in words would prevail. In case there is any inconsistency between the rate and the value extended (after multiplication with the tender quantity), the rate quoted shall prevail.

23.2 If a bidder does not accept the correction of errors as outlined above, his bid will be rejected.

24.0 Evaluation and Comparison of Bids

24.1 Only such of the bids as have been determined to be substantially responsive to the requirements of the bid documents, in accordance with Clause 22 will be evaluated. Other non-responsive bids will be rejected.

24.2 Bidders shall note that no preference of any nature will be given to any Bidder notwithstanding any custom, usage or instructions to the contrary.

24.3 Evaluation of the bids will take into account, in addition to the bid amounts, the following factors.

- a) Arithmetical errors corrected in accordance with Clause 23.
- b) Such other factors as the Engineer considers may have a potentially significant impact on contract execution price and payments.

24.4 Offers, deviations and other factors which are in excess of the requirements of the bid documents or otherwise result in the accrual of unsolicited benefits to the Employer shall not be taken into account in bid evaluation.

24.5 Price adjustment provisions applying to the period of execution of the contract shall not be taken into account in bid evaluation except to the extent specifically stated in the contract.

F. AWARD OF CONTRACT

25.0 Award Criteria

25.1 Subject to clause 26, Engineer will award the contract after prior approval by the Employer to the bidder whose bid has been determined to be eligible and to be substantially responsive to the bid documents and who has offered the

lowest evaluated bid of the bill of quantities, provided further that the bidder has the capability and resources effectively to carry out the contract works.

26.0 Engineer's Right to accept any Bid, to reject any or all Bids

26.1 Notwithstanding Clause 25, the Employer/Engineer reserves the right to accept or reject any bid including the lowest and to annul the bidding process and reject all bids, at any time prior to award of contract, without thereby incurring any liability to the affected bidder or bidders or any obligations to inform the affected bidder or bidders of the grounds for the Employer's/Engineer's action.

27.0 Notification of Award

27.1 Prior to the expiration of the prescribed period of bid validity, the Engineer will notify the successful bidder by cable or telex or letter confirmed in writing by registered letter that his bid has been accepted.

27.2 The notification of award will constitute the formation of the Contract.

27.3 Upon the furnishing by the successful bidder of a performance security in accordance with the provisions of Clause 29, the Engineer will promptly notify the unsuccessful bidders that their bids have been unsuccessful.

28.0 Signing of Agreement

Upon the receipt of the notification of award by the successful bidder, the successful bidder shall fill the Agreement in accordance with form of Agreement included in the Bid Documents and submit the same to the Engineer within one week of the date of receipt of notification of award and get the same engrossed, have the correct amount to stamp duly adjudicated by Superintendent of Stamps duly signed and executed on behalf of the successful bidder, all at his own cost.

29.0 Performance Security

29.1 Within 15 days of receipt of the notification of award from the Engineer, the successful bidder shall furnish to the Engineer a security in the form of a bank guarantee from Nationalised/Scheduled bank for an amount of 5 percent of the contract sum. The validity of the performance security shall be upto the end of the Defect Liability Period with a further claim period of three months.

29.2 In cases, where the aggregate of expected contract payment would at any time exceed the Engineer's estimate of actual work performed by more than the

amount of performance security specified in Clause 29.1 such security shall be increased accordingly at the expense of the successful bidder.

- 29.3 Failure of the successful bidder to lodge the required bank guarantee shall constitute sufficient grounds for the annulment of the award and forfeiture of the bid security, in which event the Engineer may make the award to the next lowest evaluated bidder or, if there are no other bidders, call for new bids.

SPECIFIC CONDITIONS OF CONTRACT

The Conditions of Contract shall be GENERAL CONDITIONS OF CONTRACT in Volume I (hereinafter called the General Conditions) as modified or added to by the following specific condition of contract which shall be read and construed with the general conditions as if they were incorporated therewith.

Insofar as any of the Conditions of specific conditions of contract conflict or be inconsistent with any of the general Condition, the conditions of specific conditions of contract shall prevail.

30.0 Definitions

- a) "EMPLOYER/PRINCIPAL EMPLOYER" means Director Central Food Laboratory Mumbai/Ministry of Health & Family Welfare Nirman Bhavan New Delhi..
- b) "ENGINEER" Means The General Manager (PG-1) of HSCC (INDIA) Ltd. or any officer nominated by the Chairman-cum-Managing Director, HSCC (INDIA) Ltd. to act as Engineer from time to time.
- c) "MONTH" and "YEAR" and all dates shall be calculated according to the Gregorian Calendar.

31.0 Insurance of Works, etc.

All Insurances referred to in General Conditions shall be effected with an Indian Insurance Company incorporated and registered in India.

32.0 Performance guarantees, advance payment guarantee and any insurance policies entered into by the Contractor under the terms of the Contract, shall stipulate that the proceeds of any claim shall be payable to The LRS Institute of TB & Respiratory Diseases, New Delhi..

33.0 Certificates and Payments

- a) The contractor shall submit to the Engineer after the end of each month a detailed statement including measurements showing the estimated contract value of the permanent works executed upto the end of the month together with particulars of other amounts to which he is entitled under the Contract.
- b) The statement shall be submitted on a printed proforma (prepared at the cost of the contractor) approved by the engineer.

- c) The contractor shall be paid monthly on the certificate of the Engineer, the amount due to him which shall be the sum of the following amounts.
 - i) Subject to and in accordance with clause 21 of these specific conditions, the estimated contract value of the permanent works executed upto the end of the previous month less retention money named in the bid, and
 - ii) 75% of the value of materials delivered to the site for permanent works on the site provided the engineer is satisfied that the amounts for such materials are reasonable bearing in mind the requirements of works, less deductions, if any as per clauses 33(f) and 37 of these specific conditions and other contract conditions.

d) Retention Money

- I. Retention money @ 6% (Six) shall be deducted from each interim certificate subject to a maximum of 5% (Five) of the Contract price.
- e) The retention money shall subject to clause 60.6 (a) & 60.6 (b) of General Conditions of contract become due and shall be paid to the contractor when the Engineer shall issue the taking over certificate notwithstanding that at such time there may be outstanding claims by the contractor against the Employer, provided always that if at such time there shall remain to be executed by the contractor any works ordered during the Defect Liability Period pursuant to clause 49.1, 49.2, 49.3, 49.4 and 50.1 of the General conditions hereof the Employer shall be entitled to withhold payment until the completion of such works as much of the retention money as the Engineer may in his absolute discretion think fit.
- h) Payment upon each of the Engineer's certificates shall be made by the HSCC (INDIA) Ltd. acting for and on behalf of Employer within 30 days after such certificate has been issued by the Engineer.

However 75% of the estimated amount as determined by the Engineer/ or his representative of the payment due against the monthly running bill shall be paid within 10 (Ten) working days after certification by Engineer/his representative.

- i) The Engineer may at any time make any corrections or modifications to any certificate which shall have been issued by him and shall have power to withhold any certificate if the works or any part thereof are not being carried out to his satisfaction.
- j) The responsibility for making the payments or meeting other obligations to the contractor in respect of all works as certified by the Engineer shall be that of the Employer and not of the Engineer.
- k) After completion of work and prior to final payment, the contractor shall furnish to the Engineer, a release of claims against the Employer arising out of the contract, other than claims specifically identified, evaluated and excepted from the operation of the release by the contractor.

34.0 Settlement of Disputes - Arbitration

Sub Clause 67.1, 67.2, 67.3 and 67.4 of G.C.C. shall be followed.

35.0 Address

- a. The address of the Employer is as follows :

Govt. Medical Store Depot, Bellasis Road, Opposite Sahil Hotel, Mumbai. Central, Mumbai

- b. The address of the Engineer is as follows

The General Manager `(PG-1), HSCC (INDIA) Ltd., Plot - 6 (A), Block - E, Sector - 1, Noida, Uttar Pradesh - 201 301.

- c. The address of the Contractor is

36.0 The Following Shall be Read in Addition to Clause 34.1 to The General Conditions

36.1 Labour

36.1.1 Engagement of Labour

The Contractor shall make his own arrangements for the engagement of all labour, local or otherwise, and, save insofar as the Contract otherwise provides, for the transport, housing, feeding and payment thereof.

36.1.2 Supply of Water

The contractor shall provide at his own cost adequate quantity of drinking water on the site to the satisfaction of the Engineer's Representative for the use of the Contractor's and the Engineer's staff and work people, Sub-Contractors and site visitors.

36.1.3 Fair Wages :

The Contractor shall pay the labours engaged by him on the work not less than a fair wage, which expression shall mean, whether or time or piecework, the respective rates of wages as fixed by the public works department as fair wages for the area payable to the different categories of labourers or those notified under the Minimum wages act for corresponding employees of the Employer whichever may be higher.

36.1.4 The Contractor shall notwithstanding the provisions of any contract to the contrary, cause to be paid a fair wage to the labourers indirectly engaged on the works including any labour engaged by subcontractors in connection with the said works as if the labourer has been immediately employed by him.

36.1.5 Wage Records :

The contractor shall maintain records of wages and other remuneration paid to his employees in such form as may be convenient and to the requirements of the Employer/Engineer and the conciliation officer (Central) Ministry of Labour, Government of India, or such other authorised person appointed by the Central or State Government and the same shall include the following particulars of each worker:

- i) Name, works number and grade
- ii) Rate of daily or monthly wage.
- iii) Nature of work on which employed
- iv) Total number of days worked during each wage period.
- v) Total amount payable for the work during each wage period.
- vi) All deductions made from the wage with details in Each case of the ground for which the deduction is made.
- vii) Wage actually paid for each wage period.

36.1.6 The contractor shall provide a wage slip for each worker employed on the works.

36.1.7 The wage record and wage slips shall be preserved for at least 12 months after the last entry.

36.1.8 Inspection of Wage Records

The Contractor shall allow inspection of the aforesaid wage records and wage slip to the Engineer and to any of his workers or to his agent at a convenient time and place after due notice is received, or to the Employer or any other person authorised by him on his behalf.

36.1.9 The Employer shall have the right to deduct from the moneys due to the Contractor any sum required or estimated to be required for making good the loss suffered by a worker or workers by reason of non payment of the aforesaid fair wage, except on account of any deductions that may be permissible under any law for the time being in force.

36.2. Variation in Price (Deleted)

This is a Firm Price Contract. Escalation shall not be payable.

36.2.1 Subsequent Legislation

If, after the date thirty days prior to the latest date for submission of bids for the works, there occurs changes to any National or State Statute, Ordinance, Decree or other law or any regulation or bye-law of any local or other duly constituted authority or the introduction of any such statute ordinance, etc. which causes additional or reduced cost, the same shall be certified by the Engineer and shall be paid by or credited to the Employer and the Contract Price adjusted accordingly. Notwithstanding the foregoing such additional or reduced cost shall not be separately paid or credited if the same shall already have been taken into account in the indexing of any inputs to the price adjustments formula in accordance with the provisions of sub-clauses (1), (2), (3), (4) and (5) of this clause.

The following items are not to be included in the price adjustment calculations:

- a. Liquidated Damages.
- b. Retention money withheld and released.
- c. Advance payments in the form of loan and their repayments.
- d. Value of any additional or varied work valued at current price.

- e. Payment to "nominated" sub - contractors included as "provisional sums" or "prime cost" items in the Contract price.

37.0 Taxation

The contractor and his staff shall pay all taxes, duties, levies, etc. of the Government provisions of the Income-Tax Act or as per the advice of the Income Tax Authority. Deduction of Income-Tax/ other taxes shall be made from each certificate of payment as per the relevant provisions of the Income Tax Act or as per the advice of the Income Tax authority/ other competent authority.

38.0 Co-ordination Meeting

The Contractor shall be required to attend co-ordination meetings with the Engineer, the consultant and the other contractors during the period of contract as instructed by the Engineer. All costs incidental to such interaction shall be to the contractor's account and no claim will be entertained by the Employer/Engineer on this account.

39.0 Special Applications

39.1 Site Information

The proposed site for the Construction is located at General Medical Store Depot, Mumbai Central, Mumbai.

39.2 Special Instruction

Within a month of start of work, the contractor shall provide Consultant with telephone (Landline or Mobile) facility at site office including STD facility & pay at his cost all monthly bills limited to Rs 2000.00 (Rupees Two Thousand Only) per month.

The entire works will be liable to be inspected by Chief Technical Examiner i.e. CTE. /CVC and ISO inspector. The contractor will provide all necessary help required for in this connection. The contractor will have to comply with the procedures/observations/ suggestions of the CTE/ISO in respect of quality, specifications, and workmanship in his scope of work, if any. No extra payment will be made on this account however, any recovery arising out of the CTE's/ISO's observation will be borne by the contractor.

39.2.1 Contractor's Working Area

Suitable working area will be provided to the Contractor. The Contractor may have to carry out some cutting / filling work for making his working area. The cost of all such works shall be deemed to have been included in the rates and prices quoted for the works and no extra payment shall be made on this account.

39.2.2 Contractor's Temporary Structures

The Contractor may, at his own expense and subject to the approval of the Engineer and statutory authorities, construct offices, stores, workshop in the area allocated to him and remove the same as per the orders of the Engineer on completion of works. The Contractor shall furnish such details of his temporary works as may be called for by the Engineer and the Contractor shall satisfy the Engineer as to their safety and efficiency. Engineer may direct those temporary work which he considers unsafe or inefficient be removed and replaced in a satisfactory manner. The contractor shall immediately follow Engineer's directions/instructions.

The contractor shall make his own arrangement at his own expense for labour camp/ accommodation of his labour and staff and their conveyance to site as no workers/ staff shall unless with the specific approval of the Engineer be allowed to stay within the site. Gate passes shall be issued by the engineer to authorise the contractor's staff and workers to enter the site.

39.2.3 Procurement of Various Materials

The Employer will not supply any construction materials required for the works under this Contract. The Contractor must, therefore, make his own arrangements for timely procurement of various materials.

39.2.4 Water Supply & Power Supply

The contractor shall make his own arrangement for water supply at site for drinking as well as construction purposes at his own cost. The contractor shall also make his own arrangements for power supply at site for construction purposes and general use at his own cost.

Non-availability of power supply and/or water from whatever source shall not entail any additional claims or extension of contract period in this account.

39.2.5 Telecommunications

The Contractor shall apply to the P&T authorities for the necessary telephone and communication lines at his cost.

39.2.6 Temporary Fencing

The contractor shall at his own expense, erect and maintain in good condition temporary fences and gates along the boundary of the areas assigned to him for the purpose of execution of the works.

The Contractor shall, except when authorised by the Engineer, confine his men, materials and plant within the Site of which he is given possession. The Contractor shall not use any part of the Site for purposes not connected with the works unless prior written consent of the Engineer has been obtained. Access shall be made to such areas only by way of approved gateways.

39.2.7 Testing of Materials

All materials used in the works shall be subject to inspection and tests. The Contractor shall carry out sampling of such materials and making of concrete test cubes as and when ordered by the Engineer as per the appropriate Indian Standards and as directed by the Engineer. The contractor shall deliver the samples of materials and concrete test cubes to the Engineer in a manner as directed by the Engineer who will inspect the same and then order for testing of the materials and concrete cubes.

The Contractor shall arrange for testing of materials in and around Delhi. The delivery of the samples shall be undertaken by the contractor. The cost and charges for sampling of materials and concrete cubes and delivering the same to the office of the Engineer and/or other places including all incidentals in connection with the same as directed by the Engineer and the testing charges thereof shall be borne by the contractor and shall be deemed to be included in the rates and prices quoted in the Bill of quantities. The results of the tests carried out shall be binding on the contractor who shall comply with any rectification measures that the Engineer may deem fit and order to be executed by the contractor as a result of testing.

39.2.8 Approval of Samples prior to use

The contractor shall submit the samples of materials, he proposes to use in the works for prior approval of the Engineer. A sample room shall be maintained at site in which all approved samples shall be kept for comparison with materials being used at site. Any materials not confirming to the approved samples shall be rejected.

39.3 Drawings to be Supplied by Engineer

The Engineer shall supply to the contractor from time to time during the progress of the works such further drawings as will be necessary in his opinion

for the proper and adequate execution and maintenance of the works in accordance with the design and or any modification thereof as decided by the Engineer and the contractor shall carry out the work in accordance with the said drawings. Any further drawing/ detailing require shall be made by the contractor at his own expense.

39.4 "AS MADE" Drawings

The Contractor shall supply two complete sets of "As Made" Drawings on polyester tracing film 75 micron thick and also on computer floppy and three prints showing details of all the works as executed. The drawings and prints shall be delivered to the Engineer within one month of completion of the various sections of the work or at such other times as directed by the Engineer. The drawings shall be fully dimensioned with the Engineer's standard title block or as approved by the Engineer. The cost of making the "As Made" drawings shall be deemed to be included in the rates quoted in the Bill of Quantities.

39.5 Progress Photograph

The contractor shall supply to the Engineer a negative and Three prints of colour progress photographs of such portions of the work in progress or completed as directed by the Engineer. The negative and the photographs shall become the property of the Employer. The photographs shall be of approximate size 169mm x 115mm each. The photographs shall be mounted in albums and shall be suitably inscribed and captioned. The albums in a chronological order shall be handed over to the Engineer. No prints or the negatives may be supplied to any persons without the authority of the Engineer.

39.6 Programme of Work and Progress Reports

The Contractor shall submit to the Engineer within one weeks of the award of the contract six copies of a detailed schedule showing in an approved form the estimated dates of commencement and completion of different parts of the works including the expected dates for completion of the various sections of the works. The detailed schedule shall be such as it can be updated quarterly or as directed by the Engineer. Six copies of the revised schedule shall be supplied to the Engineer as and when it is revised.

The Contractor shall submit to the Engineer before the second day of every week a progress report for the preceding week showing the upto date progress and progress during the preceding week on all items of each section of the works in relation to and in consideration of the detailed schedule.

39.7 Metric Units

Metric units have been used in the specifications and on all the drawings.

If any materials described in the contract or ordered by the Engineer are described by dimensions in the metric units and the contractor can not in accordance with the contract, procure such materials in the measure specified in sufficient time to avoid delay in the performance of his other obligations under the contract, but can obtain such materials in other measure to dimensions approximating to those described in the Contract or ordered by the Engineer, then the contractor shall henceforth give notice to the Engineer of these facts stating the dimensions to which such materials are procurable in the other measure. As soon as practicable after the receipts of any such notice the Engineer shall give an order to the contractor which shall either :

- (a) Direct the contractor to supply such materials to the dimensions stated in his said notice to be procurable instead of the dimensions described in the contract or originally ordered by the Engineer, or
- (b) Direct the contractor to make some other variation whereby the need to supply such materials to the dimensions described in the contract or originally ordered by the Engineer will be avoided.

40.0 Rates/Prices

The quoted rates/prices for the items shall be complete in all respect including all labour, material, plant and machinery, tools and tackles, all taxes, duties, levies, octroi, statutory levies applicable from time to time etc. The contractor should quote his rates/prices accordingly for the complete items in all respects.

41.0 Compliance for Statutory Obligations

The contractor shall comply all the statutory obligations and obtain all required clearances to implement the project without any financial repercussions to HSCC/Client and ensure all follow up actions with the local authorities in this respect for smooth functioning of the project.

42.0 Unpriced Bids

The un priced copies of the purchase orders of major items/equipments and of sub contracts placed by the contractor shall be furnished to the Engineer.

ADDITIONAL SPECIFIC CONDITIONS OF CONTRACT

AND

SPECIFICATIONS

SPECIFIC CONDITIONS OF CONTRACT RELATING TO HVAC SYSTEM

1.0 General

- 1.1 The following additional specific conditions and specifications shall be read in conjunction with instructions to bidders and General conditions of Contract. If there are any provisions in these additional specific conditions and specifications which are at variance with the provisions in the above mentioned documents, the provisions in these additional specific conditions and specification shall take precedence.

2.0 Scope of Contract

- 2.1 The scope and general character of works to be carried out under this section comprises of Supply, installation, testing and commissioning of Heating, ventilation and air conditioning installation as illustrated in drawings, specifications, technical data and bill of quantities.

3.0 Stores and Materials

- 3.1 The contractor shall provide everything necessary for the proper execution of the work according to the intent and meaning of the drawings, Bill of Quantities and specifications taken together whether the same may or may not be particularly shown or described therein provided that the same can be reasonably inferred there from. In case of any discrepancy in the drawings or between the drawings, Bill of Quantities and specifications, the decision of the Engineer in this regard will be final and complied with.

4.0 Supply of Equipment

Equipment shall be strictly as per the list of approved makes/ manufacturers given in the bid documents.

- 4.1 The contractor shall submit manufacturers test certificates of equipment supplied.

4.2 The contractor shall submit the original "Excise Paid Certificates", and exit Gate passes form manufacturer's factory/works clearly bearing the batch numbers and date of despatch.

5.0 Working Drawings etc.

5.1 The Contractor shall within 60 days of signing of the contract prepare and submit to the Engineer for approval, 2 sets of detailed shop drawings of equipment, Equipment characteristics and capacity details of all equipment, accessories and devices etc. as per specifications and as required by the Engineer.

5.2 These drawings shall contain details of construction, size, arrangement, operating clearances, performance characteristics, and capacity of all items of equipment, as also details of all related items of work by other disciplines.

5.3 If the Engineer makes any amendment in the above drawings, the Contractor shall supply two fresh sets of drawings with the amendments duly incorporated, along with the drawings on which corrections were made. After final approval has been obtained from the Engineer, the Contractor shall submit a further six sets of shop drawings for the exclusive use of and retention by the Engineer.

5.4 The shop Drawings shall be submitted for approval sufficiently in advance of planned delivery and installation of any material, to allow Engineer ample time for scrutiny. No claims for extension of time shall be entertained because of any delay in the work due to failure to produce shop drawings in time.

5.5 Approval rendered on shop drawings shall not be considered as a guarantee of measurements or of building conditions. Where drawings are approved, said approval does not mean that drawings have been checked in detail nor does it in any way relieve the Contractor from his responsibility of furnishing materials or performing work as required by the Contract.

6.0 Completion Drawings

6.1 Following "AS BUILT" drawings shall be submitted by the contractor on completion of the work.

- a. Plant installation drawings giving complete details of the entire equipment including foundations.
- b. Ducting drawings showing all sizes, damper locations and sizes of all air outlets and intakes, for all floors.

- c. Electrical drawings showing cable sizes, equipment capacities, control components and control wiring.
- d. Schematic control drawings giving detailed sequence of operation and notes to explain the operation of the control circuit.
- e. Piping drawings showing all pipe sizes, valves and fittings.
- f. Any other drawings to be supplied as per instructions of the Engineer.

The Drawings shall be cross checked and approved by the Engineer before acceptance.

7.0 Operation and Service Manuals

- 7.1 The contractor shall submit 3 sets of operation and service manuals in respect of the air-conditioning plant including salient details of plant.

Following minimum details shall be furnished:

- i) Detailed equipment data as approved by the Engineer.
- ii) Manufacturer's maintenance and operating instruction.
- iii) Approved test readings.

The contractor shall also submit four (4) sets of technical literature on all automatic controls and complete technical literature on all equipment and materials. The contractor shall frame under glass, in the Air Conditioning plant Room all consolidated control diagrams and all piping diagrams.

8.0 Inspection at Contractor's Premises

- 8.1 The Engineer and his representatives shall at all reasonable time have free access to the contractor's premises/works. The contractor shall give every facility to the Engineer and his Representative and necessary help for inspection and examinations and test of the materials and workmanship.
- 8.2 The Engineer's Representative shall have full powers to inspect drawings of any portion of the work or examine the materials and workmanship of the plant at the contractor's works or at any other place from where the material or equipment is obtained. Acceptance of any material or equipment shall in no way, relieve the contractor of his responsibility for meeting the requirement of the specifications.

9.0 Sub - Contracting

The contractor may subcontract part of the works with the written approval of the Engineer to any of the approved subcontractors given in the list of approved subcontractors, makes and manufacturers. A single subcontractor shall be appointed for carrying out the entire work of supplying, installation, testing and commissioning of all the equipment covered under the package. However the overall responsibility of the contractor for compliance with the contract terms does not alter by subcontracting.

10.0 Material Submittals

The contractor shall submit material submittals for all equipment and machinery for the written approval of the Engineer before placing orders. The material submittals shall comprise of at least the following :

- a. Manufacturer's technical catalogues and brochures giving technical data about performance and other parameters.
- b. Manufacturers drawings/ sketches showing construction, dimensional and installation details.
- c. Rating charts and performance curves clarifying rating of equipment selected and proposed.

11.0 Samples and Prototypes

The contractor shall submit samples of items such as grilles/ diffusers, valves, controls and/ or any other parts or equipment as required by the Engineer for prior approval in writing before placing the order. The contractor shall also construct prototype or samples of work as laid down in the contract or as instructed by the Engineer. Such samples and prototypes after approval shall be retained by the Engineer and shall serve as the standards to be achieved in final construction.

12.0 Testing and Commissioning

12.1 Tests on the equipment as called for in the Specifications shall be carried out by the Contractor in accordance with the specifications, the relevant Indian Standard Specifications and the relevant Indian and International Standards.

12.2 The initial tests shall include but not be limited to the following :

- a. To operate and check the proper functioning of all electrically operated components viz., compressor motor, pumps, blowers, air handling units, rotating machine, fans, boilers, etc.
- b. To operate and check the proper functioning of all electrical panels, switch gears, safety and other controls.
- c. To adjust and balance air, water, steam and gas quantities to provide the designed flow rates by adjusting valves, dampers, diverters etc.
- d. To check the systems against leaks in different circuits, alignment of motor, `V' Belt adjustments etc.
- e. To check the vibration and noise levels of the equipment.
- f. Setting of all control and all such other tests which are essential for smooth functioning of the plant.

12.3 The Contractor shall pay for and arrange without any extra cost, all necessary balancing and testing equipment, instruments, materials, accessories, power, water, fuel and the requisite labour for testing. Any defects in materials and/or in workmanship detected in the course of testing shall be rectified by the Contractor entirely at his own cost, to the satisfaction of the Engineer. The installation shall be tested again after removal of defects and shall be commissioned only after approval by the Engineer. All tests shall be carried out in the presence of the Engineer or the Engineer's Representative.

13.0 Provisional Taking Over

13.1 After completion of the installation of the system plant the same shall be put to a continuous running test for a period of 2 (two) days. All adjustments should be made prior to this test so that proper conditions/working are achieved during this testing. The test readings shall include items as noted in the Testing Schedules.

The plant will be provisionally taken over after successful completion of the above test and the defects liability period shall commence after provisional taking over of the HVAC system.

13.2 Final Performance and capacity Test

In addition to the above testing, final performance and capacity tests shall be carried out on the equipment as per the "Testing Schedules" during the defects liability period as follows :

- a. Peak summer/ monsoon test during the period from 15th may to 31st July. The installations should be able to maintain the specified inside conditions within the tolerance limits permitted in the contract.

- b. Peak winter test during the period from 1st December to 15th February. The installations should be able to maintain the specified inside conditions within the tolerance limits permitted in the contract.

14.0 Operation of Plant

- 14.1 After provisional taking over of the plant user shall provide staff for operation. Staff will work under the supervision of the contractor for proper operation of the plant. This responsibility of the contractor shall continue till the completion of test liabilities with respect to the plant or the maintenance period, which ever ends later.
- 14.2 The user shall have the right to operate all equipments, if in operating condition, whether or not such equipments, have been accepted as complete and satisfactory. Repairs and alterations shall be made at such time as directed by the Engineer. In special circumstances user may have to use the plant to Air condition some areas even before the completion of whole work. The contractor shall Co-operate fully under such circumstances.

15.0 Guarantee and Defects Liability Period

- 15.1 The guarantee shall be valid for a period of 12 (Twelve) months after provisional taking over of the plant or till the completion of final testing and taking over whichever is later. The contractor shall guarantee that all equipments shall be free from any defect due to the defective materials and bad workmanship or any other cause and that the equipment shall work satisfactorily and that the performance and efficiencies of the equipment shall be not less than the guaranteed values. Any parts found defective during the guarantee period shall be replaced by the contractor at his own expense. The services of the contractor's personnel, if requisitioned during this period for such work, shall be made available free of any cost to the Employer.

If the defects are not remedied within a reasonable time mentioned in the written notice, the Employer may proceed to do so at the contractors risk and expenses without prejudice to any other rights. Joint inspection report shall also be deemed as written notice for this purpose.

16.0 Measurement of Works

- 16.1 All works shall be measured in accordance with the mode of measurement given in the specific sections of the specifications. In case the method of measurement for any item is not clarified in the specifications, the same shall be measured in accordance with the relevant IS standards.
- 16.2 The Engineer may from time to time intimate to the contractor that he requires the works to be measured and the contractor shall forthwith attend or send a qualified agent to assist the Engineer or the Engineer's Representative in taking such measurements and calculations and to furnish all particulars or give all assistance required by either of them. Should the contractor not attend or neglect or omit to send such agent, then the measurements of the works, carried out by the Engineer or his Representative shall be taken to be the correct measurements of the works, in accordance with the standard method of measurements, as in prevalent use.

The contractor or his agent may at the time of measurement take such notes and measurements as he may require. The contractor shall submit Running bills supported by detailed measurement sheets.

17.0 Variation in Quantities

17.1 The quantities for ancillary work given in the drawings and/or specifications are for the guidance of the bidder. The contractor shall, however, be paid on the basis of actual quantities of works carried out.

18.0 Maintenance

18.1 The contractor shall provide free maintenance for a period of twelve months after the installation is provisionally taken over. The contractor shall carry out all routine and special maintenance of the plant and attend to any defects that may arise in operation of the plant. Consumable items required during the maintenance, loss of which is not attributable to bad material and/or workmanship will be arranged by the Employer free of cost.

19.0 Performance Guarantee

19.1 The contractor shall submit a performance guarantee certificate from the approved subcontractor that the systems shall maintain the desired parameters within +/- 5 % of the specified parameters who shall also guarantee that the capacity of various components as well as the whole system covered under scope of work, technical schedules and bill of quantities etc. shall not be less than the specified capacities. The guarantee of the specific equipment supplier alone with regard to the performance of the system shall not be acceptable. However, this does not alter the overall responsibility of the contractor for compliance with the contract terms and conditions.

20.0 Painting

20.1 All equipment and ancillary items such as pipes, supports etc., will be painted in approved manner, using standard colour scheme as approved by the Engineer.

21.0 Safe Custody and Storage

21.1 Safe custody of all machinery and equipment dismantled, shifted & supplied by the contractor shall be his own responsibility till the final taking over by the Employer. He should, therefore, employ sufficient staff for watch and ward at his own expenses. The Employer may, however, allow the contractor to use the plant room/weather maker/rooms, etc. for temporary storage of his equipment if such spaces are ready and available.

22.0 Terms of Payment

For purposes of estimating the contract value of works executed for certificate of payment the following norms shall be followed.

- A) 80% of BOQ contract rates shall be paid on receipt of equipment at site and after inspections and passing on prorata basis.

- B) 10% of BOQ contract rates shall be paid on erection and installation of equipment on prorata basis.
 - C) 5% after successful completion of running tests and provisional taking over.
3. 5% after final performance -cum-seasonal test to be conducted in summer or monsoon only after all defects pointed out during previous tests have been removed.

23.0 Training of Personnel

The contractor shall arrange to train the Employer's personnel on the following aspects prior to provisional take over of the plant.

- a) Operation of plant.
- b) Gas charging and pumping down of the system.
- c) Adjustments of settings for controls and protective devices.
- d) Preventive maintenance.
- e) Disassembling and assembling of compressor including identification and replacement of worn out parts.

24 Miscellaneous Conditions

- (a) The quoted rates are deemed to include for all leads & lifts, shuttering etc, and no claim on this account shall be entertained. The quoted rates should be inclusive of associated civil & electrical works required for erection of HVAC and Clean room applications. When required by the engineer the work shall be carried out beyond office hours and at night and in such a case the Supplier shall at his own cost make suitable arrangement for providing lighting etc. The quoted rates are deemed to include for all expenditures associated with overtime/night work.
- (b) Water & electricity shall be arranged by the Supplier at their cost or shall be supplied by Principal Employer if available, subject to recovery.

ANNEXURE - A

FORM OF AGREEMENT

AGREEMENT

This Agreement made the _____ day of _____ 20_____ between Director Food & drug Testing Laboratory Mumbai Central, Mumbai. (hereinafter called "The Employer") represented by M/s HSCC (INDIA) Ltd. who enters into this Agreement of the one part and M/s (hereinafter called "The Contractor") of the other part.

Whereas The Employer is desirous that certain Works should be executed by the Contractor, viz _____ ("the works") and has accepted a Bid by the Contractor for the execution and completion of the Works and the remedying of any defects therein.

Now this Agreement witnesseth as follows :

1. In this Agreement words and expressions shall have the same meanings as are respectively assigned to them in the Conditions of Contract hereinafter referred to.
2. The following documents shall be deemed to form and be read and construed as part of this Agreement, viz :
 - (a) The Letter of Award;
 - (b) The said Bid;
 - (c) The General Conditions of Contract;
 - (d) Instructions to tenderers and Specific Conditions of Contract;
 - (e) The Specification;
 - (f) The Drawings;
 - (g) The Priced Bill of Quantities;
 - (h) Any other relevant documents referred to in this Agreement or in the aforementioned documents;
3. In consideration of the payments to be made by the HSCC (INDIA) Ltd. (HSCC) acting as Employer to the contractor as hereinafter mentioned, the Contractor hereby covenants with the Employer to execute and complete the Works and remedy any defects therein in conformity in all respects with the provisions of the Contract.

4. The Employer hereby covenants to pay the Contractor through HSCC in consideration of the execution and completion of the Works and the remedying of defects therein the Contract Price or such other sum as may become payable under the provisions of the Contract at the times and in the manner prescribed by the Contract.

In Witness whereof the parties hereto have caused this Agreement to be executed the day and year first before written.

Signed, Sealed, and Delivered by the Said _____

Binding Signature of [HSCC] for and on behalf of M/s LRS Institute of TB & Respiratory Diseases, New Delhi..

Binding Signature of Contractor _____

In the presence of

Witness (1) :

Witness (2) :

ANNEXURE - B

PROFORMA FOR PERFORMANCE BANK GUARANTEE (On a stamp paper of appropriate value from any Nationalised Bank or Scheduled Bank)

To,

M/s HSCC (INDIA) Ltd.,
Plot No. 6(A), Block E, Sector 1,
NOIDA - 201 301.

Dear Sir,

In consideration of the M/s Director Food & drug Testing Laboratory Mumbai Central, Mumbai (hereinafter called Employer) which expression shall include his successor and assigns represented by his Consultant M/s. HSCC (INDIA) Ltd., Plot - 6 (A), Block - E, Sector - I, Noida, Uttar Pradesh - 201 301 (hereinafter called HSCC) having awarded to _____ (hereinafter referred to as the said Contractor or 'Contractor' which expression shall wherever the subject or context so permits include its successors and assigns) a contract No _____ in terms inter alia, of the HSCC Letter No. _____ dated _____ and the General Conditions of Contract and upon the condition of the contractor's furnishing security for the performance of the contractor's obligations and discharge of the contractor's liability under and in connection with the said contract upto a sum of Rs. _____ (Rupees _____ only) amounting to _____ percent of the total contract value.

1. We, _____ (hereinafter called 'The Bank' which expression shall include its successors and assigns) hereby jointly and severally undertake to guarantee the payment to the Employer in rupees forthwith on demand in writing and without protest or demur or any and all moneys anyway payable by the contractor to the Employer under in respect of or in connection with the said contract inclusive of all the Employer's losses and damages and costs, (inclusive between attorney and client) charges and expenses and other moneys anyway payable in respect of the above as specified in any notice of demand made by the Employer to the Bank with reference to this guarantee upto an aggregate limit of Rs. _____ (Rupees _____ only).
2. We _____ Bank Ltd. further agree that The Employer shall be sole judge of and as to whether the said contractor has committed any breach or breaches of any of the terms and conditions of the said contract and the extent of loss, damage, cost, charges and expenses caused to or suffered by or that may be caused to or suffered by The Employer on account thereof and the decision of The Employer that the said Contractor has committed such breach or breaches and as to the amount or amounts of loss, damage, costs, charges and expenses caused to or suffered by The Employer from time to time shall be final and binding on us.

3. The Employer shall be at liberty without reference to the Bank and without affecting the full liability of the Bank hereunder to take any other security in respect of the Contractor's obligations and liabilities hereunder or to vary the contract or the work to be done thereunder vis-a-vis the Contractor or to grant time or indulgence to the Contractor or to reduce or to increase or otherwise vary the prices of the total contract value or to release or to forbear from enforcement of all or any of the security and/or any other security(ies) now or hereafter held by The Employer and no such dealing(s) reduction(s) increase(s) or other indulgence(s) or arrangements with the Contractor or release or forbearance whatsoever shall absolve the bank of the full liability to The Employer hereunder or prejudice the rights of The Employer against the bank.
4. This guarantee shall not be determined or affected by the liquidation or winding up, dissolution, or change of constitution or insolvency of the Contractor but shall in all respects and for all purposes be binding and operative until payment of all monies payable to The Employer in terms thereof.
5. The bank hereby waives all rights at any time inconsistent with the terms of this guarantee and the obligations of the Bank in terms hereof shall not be anyway affected or suspended by reason of any dispute or disputes having been raised by the Contractor stopping or preventing or purporting to stop or prevent any payment by the Bank to The Employer in terms hereof.
6. The amount stated in any notice of demand addressed by The Employer to the Bank as liable to be paid to The Employer by the Contractor or as suffered or incurred by The Employer on account of any losses or damages or costs, charges and/or expenses shall be conclusive evidence of the amount so liable to be paid to The Employer or suffered or incurred by The Employer as the case may be and shall be payable by the Bank to The Employer in terms hereof.
7. This guarantee shall be a continuing guarantee and shall remain valid and irrevocable for all claims of The Employer and liabilities of the contractor arising upto and until midnight of _____.
8. This guarantee shall be in addition to any other guarantee or security whatsoever that The Employer may now or at any time anyway may have in relation to the Contractor's obligations/or liabilities under and/or in connection with the said contract, and The Employer shall have full authority to have recourse to or enforce this security in preference to any other guarantee or security which The Employer may have or obtain and no forbearance on the part of The Employer in enforcing or requiring enforcement of any other security shall have the effect of releasing the Bank from its full liability hereunder.
9. It shall not be necessary for The Employer to proceed against the said Contractor before proceeding against the Bank and the Guarantee herein contained shall be enforceable against the Bank notwithstanding that any security which The Employer may have obtained or obtain from the contractor shall at the time when proceedings are taken against the said bank hereunder be outstanding or unrealised.
10. We, the said Bank undertake not to revoke this guarantee during its currency except with the consent of The Employer in writing and agree that any change in the constitution of the said contractor or the said bank shall not discharge our liability hereunder.
11. We _____ the said Bank further that we shall pay forthwith the amount stated in the notice of demand notwithstanding any dispute/difference pending between the parties before the arbitrator and/or that any dispute is being referred to arbitration.

12. Notwithstanding anything contained herein above, our liability under this guarantee shall be restricted to Rs. _____ (Rupees _____) and this guarantee shall remain in force till _____ and unless a claim is made on us within 3 months from that date, that is before _____ all the claims under this guarantee shall be forfeited and we shall be relieved of and discharged from our liabilities thereunder.

Dated _____ day of _____ 20

For and on behalf of Bank.

Issued
under
seal :

ANNEXURE - C

PROFORMA FOR BID SECURITY BANK GUARANTEE

(To cover payment of Bid Security and Conditions of Contract)

(On a stamp paper of appropriate value from any Nationalised Bank or Scheduled Bank)

To

M/s HSCC (INDIA) Ltd.,
Plot No. 6(A), Block E, Sector 1,
NOIDA - 201 301.

Dear Sir,

In consideration of your agreeing to accept Bank Guarantee for Rs.
(Rupees) in lieu of payment
from M/s having its /their registered office
at
(hereinafter called the Bidder) towards Bid security in respect of your tender no.
..... calling for tender for
at and for due fulfilment of the terms and conditions of the
said tender, we hereby undertake and agree to indemnify and keep you indemnified to the extent of
Rs (Rupees
.....).

In the event of any loss or damages, costs, charges or expenses caused to or suffered by you by
reason of any breach or non observance on the part of the Bidder of any terms and conditions of
the said tender, we shall on demand and without cavil or argument, and without reference to the
bidder, irrevocably and unconditionally pay you in full satisfaction of your demand the amounts
claimed by you, provided that our liability under this guarantee shall not at any time exceed Rs
.....
(Rupees).

This guarantee herein contained shall remain in full force and till you finalise the tender and select
the tender as per your choice and it shall in the event of the said bidder being selected and
entrusted with the said work, continue to be enforceable till the said bidder executes the
Agreement with you and commences the work as stipulated under the terms and conditions of the
said tender have been fully and properly carried out by the said bidder and accordingly discharges
the guarantee.

We also agree that your decision as to whether the bidder has committed any breach or non
observance of the terms and conditions of the said tender shall be final and binding on us.

We under take to pay the Consultant any money so demanded by the Consultant notwithstanding any dispute or disputes raised by the Contractor(s) in any suit or proceedings pending before any Court or Tribunal relating thereto, our liability under this present being absolute and unequivocal.

The payment so made by us under this bond shall be a valid discharge of our liability for payment thereunder and the contractor(s) shall have no claim against us for making such a payment.

This guarantee shall continue to be in full force and effect for a period of 120 days from the date of submission of bid. Notwithstanding the above limitations, we shall honour and discharge the claims preferred by you within thirty days of expiry of this guarantee.

We shall not revoke this guarantee during its currency except with your previous consent in writing. This guarantee shall not be affected by any change in Constitution of our bank or of the bidder firm. Your neglect or forbearance in the enforcement of the payment of any money, the payment whereof is intended to be hereby secured or the giving of time for the payment hereto shall in no way relieve us our liability under this guarantee.

Dated this day of

Yours faithfully,

For

Signature & seal of the Bank (Authorised Signatory)

ANNEXURE - D**APPENDIX TO TENDER**

Important Clause	Clause No.	Volume	Remarks
Amount of performance security	10.1	I	5% of the contract Price
Minimum amount of third party Insurance	23.2	I	Rs. 50,000=00 for any one incident, number of incidents 4 Total Limit is 2 Lakh.
Period of commencement from Engineer's order to commence	41.1	I	2 weeks.
Mobilisation advance	33(a)	II	5% of the contract price @ 12% interest per annum.
Amount of Liquidated damages	47.1	I	0.5 % (point five percent) of contract price per week of delay.
Limit of liquidated damages	47.1	I	10% of contract price
Defect Liability Period	49.1	I	12 months
Percentage of retention	33(f)	II	6% cash deduction
Limit of retention money	33(f) 60.5	II I	5% of the contract price.
Programme of work and progress reports	39.6	II	Programme updated quarterly, progress reported weekly.
Time of Completion	43.1 1.4	I II	18 (Eighteen) calendar months

**CENTRAL FOOD & DRUG TESTING LABORATORY
MUMBAI**

**TENDER
FOR**

**HVAC, CLEAN ROOM AND ALLIED WORKS FOR
MICROBIOLOGY LAB FOR FOOD & DRUG
TESTING LABORATORY MUMBAI**

VOLUME - IV

TECHNICAL SPECIFICATIONS

DECEMBER 2008

HSCC (INDIA) LTD.

(Consultants & Engineers for Mega Hospitals & Laboratories)
E - 6 (A), Sector - I, NOIDA (U.P.) - 201 301 (INDIA)

PHONE : 91-2542436, 2542440
91-2542443, 2542445

FAX : 91-11-91-2542447
E- mail : hsccltd @hsccltd.co.in

Tender No **HSCC/139/PM/-HVAC-F&D Mumbai/2008**

TECHNICAL SPECIFICATION

AIR HANDLING UNITS:

Air handling unit shall be designed with double skin cabinet type in aluminium construction with double skin panels duly powder coated from outside and plain galvanized from inside with sectionalized construction.

Prefilters shall be 10 micron HDPE washable type followed by 5 micron Microvee filters with efficiency of 95% ASHRAE STD 52-76 and 90% on bs2831 test dust no 2 in aluminium construction. Minipleat EU-8 filters shall be provided to remove particles to 0.3 microns from air/ gas with an efficiency of 50%.

The filter matrix shall comprise of specially treated glass fiber media with Minipleat seperetorless. It shall be housed in an aluminium frame provided with single turned flanges closed cell gasket. Single skin aluminium powder coated Plenum shall be provided for microvee filters.

1.0 AIR HANDLING UNITS:-

- | | | |
|-----------------------------|---|---|
| 1. MAKE | - | ACE / CROWN / HPS/ DAMCON |
| 2. MODEL TYPE | - | DOUBLE SKIN |
| 3. MATERIAL OF CONSTRUCTION | - | ALUMINIUM FRAME WORK WITH THERMAL BREAK FEATURES ALONGWITH DOUBLE SKIN GALVANISED PANEL |
| 4. INSULATION | - | 25mm THK INJECTED PUF |
| 5. CFM | - | AS PER BASIS OF DESIGN |
| 6. STATIC PRESSURE | - | AS PER REQUIREMENT |

2.0 BLOWER:-

- | | | |
|----------------------------|---|--|
| 1. MAKE | - | CROWN/KRUGER/NICOTRA (AMCA APPROVED, STANDS FOR AIR MOVEMENT AND CONTROL ASSOCIATION). |
| 2. TYPE | - | DIDW BACKWARD CURVED. |
| 3. MOC OF IMPELLER- | - | M.S POWDER COATED. |
| 4. MOC OF SCROLL AND BODY. | - | GSS. |

3.0 MOTORS:-

- | | | |
|-------------------|---|-----------------------------------|
| 1. MAKE | - | BHARAT BIJLEE / CROMPTON / OXFORD |
| 2. MODEL TYPE | - | TEFC |
| 3. RATED OUTPUT | - | AS PER REQUIRED CFM |
| 4. TYPE | - | INDUCTION |
| 5. SUPPLY DETAILS | - | 415 V +/- 10%, 3 PHASE, 50 HZ |

4.0 TYPE OF DRIVE

- | | | |
|----------------|---|----------------------|
| | - | BELT |
| 1. PULLEY SIZE | - | 2 GROOVE SPA SECTION |
| C) MAKE | - | FENNER |

5.0 COOLING COIL:-

- | | | |
|----------------------------------|---|----------------------|
| 1. DEW POINT OF COIL LEAVING AIR | - | 10° C ±0.5° C. |
| 2. COIL AIR FACE VELOCITY. | - | MAX 500. |
| 3. COIL FACE AREA | - | 8 Sq.Ft |
| 4. COIL DIMENSION (L X H X D) | - | 48" X 24" X 8" |
| 5. STATIC PR DROP AT RATED CFM | - | 5 mm. |
| 6. NO OF ROW DEEP. | - | 6. |
| 7. TUBE DIA & THICKNESS | - | 3 / 8" – 24 GUAGE. |
| 8. TUBE MATERIAL. | - | COPPER. |
| 9. TUBE EXPANSION. | - | BULLET EXPANSION. |
| 10. FIN PER INCH | - | 13 FPI. |
| 11. FIN THICKNESS | - | 0.27 mm. |
| 12. FIN MATERIAL | - | ALUMINIUM. |
| 13. COIL TEST PR. | - | 2 X DESIGN PRESSURE. |
| 14. END PLATE SUPPORT | - | 14 GUAGE GI. |

6.0 PREFILTERS:-

- | | | |
|----------------------|---|---|
| 1. TYPE: | - | FLANGE TYPE |
| 2. MAKE | - | ACE/ AIRPAC / CAMFILL /DYNA |
| 3. NO. OF FILTER | - | AS PER CFM |
| 4. SIZE | - | 610 x 610 x 75 |
| 5. FILTER MEDIA | - | NONWOVEN POLYESTER SANDWICHED IN 3 LAYERS OF HDPE MESH. |
| 6. FILTER EFFICIENCY | - | 90% DOWN TO 10 µ |
| 7. MATERIAL OF FRAME | - | ALUMINUM EXTRUDED ANNODISED |
| 8. FACE VELOCITY | - | 500 fpm (Max) |

7.0 MICROVEE FILTERS:-

- | | | |
|----------------------|---|---|
| 1. TYPE | - | FLANGE TYPE |
| 2. MAKE | - | AIRPAC / CAMFILL /DYNA |
| 3. NO OF FILTER | - | AS PER REQUIRED CFM |
| 4. SIZE | - | 610 x 610 x 150 |
| 5. FILTER MEDIA | - | NONWOVEN POLYESTER
SANDWICHED IN 2 LAYERS OF
HDPE MESH. |
| 6. FILTER EFFICIENCY | - | 95% DOWN TO 5 μ |
| 7. MATERIAL OF FRAME | - | ALUMINIUM EXTRUDED
ANNODISED |
| 8. FACE VELOCITY | - | 500 fpm (Max) |

7.0 EU-8 FILTER:-

- | | | |
|----------------------|---|---------------------------------|
| 1. TYPE | - | FLANGE TYPE |
| 2. MAKE | - | AIRPAC / CAMFILL/ DYNA |
| 3. NO OF FILTER | - | AS PER REQUIRED CFM |
| 4. SIZE | - | 610 X 610 X 300 |
| 5. FILTER MEDIA | - | GLASS MICROFIBRE |
| 6. FILTER EFFICIENCY | - | 50 % DOWN TO 0.3 μ |
| 7. MATERIAL OF FRAME | - | ALUMINIUM
EXTRUDED ANNODISED |
| 8. FACE VELOCITY | - | 500 fpm (Max) |

- | | | |
|------------------------|---|---|
| 9.0 ACCESSORIES | - | 1. GLASS INSPECTION WINDOW
FOR FAN SECTION.
2. PROVISION FOR FIXING DIFFERENTIAL
PRESSURE GUAGE / MANOMETER
ACROSS FILTERS AND COILS.
3. MARINE LIGHT IN EACH CHAMBER
4. LIMIT SWITCH- AUTOMATICALLY
TRIPS THE FAN WHEN THE DOOR IS
OPEN.
5. DAMPER- A.H.U. WILL BE SUPPLIED
ALUMINIUM POWDER COATED
OPPOSED BLADE VOLUME CONTROL
DAMPER TO FACILITATE THE AIR. |
|------------------------|---|---|

- | | | |
|-------------------------|---|--|
| 10.DOCUMENTATION | - | DQ, IQ, OQ AND PQ AS PER cGMP
REQUIREMENTS. |
|-------------------------|---|--|

CONDENSING UNIT:

The compressor(s) shall be scroll/ Reciprocative type and designed for continuous operation even at high ambient temperature of 46 deg c. The condenser shall be air cooled, made of copper tubes with extended aluminum fins. Cabinets shall be fabricated out of heavy gauge steel, properly formed for close fit and structural rigidity. All access panels shall be so constructed as to be quickly and easily removable. All outside surface shall be finished with powder coating for protection against humid weather. The condenser fan shall be directly driven and designed to achieve low condensing temperature and operate continuously and silently.

MAKE – ACE/ VOLTAS/ CRUIZE/BLUE STAR

EVAPORATING UNIT:

The cooling coils shall be made of Copper Tubing having extended aluminum fins. The tubes shall be mechanically expanded for positive bonding between tubes and fins. The cooling coil circuit shall be fed with liquid refrigerant through the expansion device and distributor. The blower shall be statically and dynamically balanced and designed for silent operation at required airflow rates against required static pressure. The filters shall be washable synthetic media type arranged for convenient cleaning and replacement. The drain pan shall be fabricated out of heavy steel sheet. Insulated with expanded polyethylene sheet. The casing shall be of heavy gauge GI, duly powder coated for weather protection.

SHEET METAL WORKS:

Ductwork for all system unless other specified shall be galvanized in steel accordance with the following schedule:

Lager Dimensions of duct	Galvanized Steel Thickness
Up to 750 mm	0.63 mm
From 751 to 1500 mm	0.83 mm
From 1500 to 2250 mm	1.00 mm

Ducts shall be built with curves and bends, where indicated, to effect easy flow of air. Vanes shall be installed where shown or necessary. Vertical ducts shall have full sized bends where horizontal branches are taken off. Dissimilar metal in ductwork shall be jointed with approved type insulators, or asbestos cloth flexible connection between metal to prevent galvanic action. The complete ductwork shall be produced so that it is fully air tight, silicon sealant shall be used after fabrication to ensure ductwork air tightness. All duct turns and curves having an inner radius smaller than the duct shall be equipped with approved single thickness vanes. Provisions shall be made in the ductwork to permit measuring and reading of air quantities and pressures without the necessity of puncturing of metal.

THERMAL INSULATION:

All supply air ducts shall be insulated with 13 mm thick closed cell elastomeric nitrile foam material. Return air duct shall be insulated with 9 mm thick closed cell elastomeric nitrile foam. All the joints shall be sealed with nitrile tape.

MAKE – ARMAFLEX / SUPERLON

DAMPERS:

Dampers shall be provided and installed in each duct branch of every conventional duct system, manual volume control dampers of multi-blade type. Each damper shall be equipped with a locking quadrant of heavy construction, approved operation and locking device mounted outside the duct in an accessible position. Dampers shall be separate and independent from registers, hereinafter specified to be set behind supply air grilles. Volume control and modulating dampers shall be of opposed blade type. All dampers located in outside air intake shall have galvanized blades and powder-coated frames. Dampers other than those located outside air intake shall have galvanized blades and powder-coated frames. Fire dampers shall be installed where necessary. Dampers and frames shall have suitable eye and standard fusible links rated at 65° C, normally holding them open, but releasing when operated every damper shall have indication device clearly showing the damper position at all times. Conveniently located access doors, of ample size for re-setting the dampers shall be provided. A balancing damper shall be installed in each branch duct, where indicated on the drawing. Each damper shall be complete with spindle, bearing, operating arm, and locking device (quadrant). The dampers shall be permanently set with fans running and locked in position after completion of the balancing of the system.

DIFFUSERS, GRILLES & REGISTRS

All grills (SA & RA) diffusers (SA & RA) will be made from heavy gauge Galvanized sheets duly powder coated. All the supply air grills/diffusers will be provided with opposed blade dampers fabricated from galvanized steel sheets. The damper shall be operational from the front face of the grill/diffuser.

TESTING

After completion the system shall be tested for leakages.

The entire air distribution system shall be balanced to supply the air quantities as required in zones and rooms and maintain the specified room conditions. The final balancing of air quantity through each grill or diffuser shall be recorded and submitted for approval.

TECHNICAL SPECIFICATION FOR MODULAR PANELS

1. FLUSHED DOORS:

Flushed doors shall be designed double skin type. Door frame should be made from 1.2 mm thick SS 304 Door shutter should be made out of 0.8 mm thick SS 304 steel sheet. The infill material should be EPS having density 16 kg/m³. All the door accessories shall be in SS 304 construction.

Door Accessories		MAKE
• LOCK	-	PAG
• SS304 HINGES	-	YAMAHA
• 'D' HANDLE	-	KORSA
• DOOR CLOSURE	-	MAGNUM

2. GLAZED PANELS:

Glazing shall be 4 mm thick glass on both sides. Silica gel should be filled beneath bottom side of frame in order to prevent condensation.

3. FALSE CEILING:

False ceiling panels shall be designed double skin type made out of 0.6 mm thick SS 304 on one side and galvanized colour coated sheet from other side. The thickness of the panel should be 50 mm. The infill material shall be EPS having density 16 Kg/m³. All AC inlet, Outlet and Light fixture cutouts shall be sealed with silicon sealant.

4. ALUMINIUM EXTRUDED COVING:

All the joints between floor to partition, partition to partition and partition to ceiling shall be properly coved so that there should not be any dust deposition in the joints. The coving shall be made out of extruded aluminium. The thickness of aluminium should be 1.2 mm. The fixing arrangement of coving on floor and partition shall be clip in type.

5. AIR TIGHT CLEANROOM LIGHT FIXTURES:

The box shall be made out of CRCA sheets duly colour coated. The light module shall be 3 x 36 W PLL. The size shall be 600 x 600 mm. The diffuser panel shall be made out of transparent acrylic having thickness 3 mm with proper gasketing. The fitting shall be airtight.

6. WALL PAINTINGS

Wall paintings shall be epoxy base or polyurethane base with non fungal and non shedding of any particles.

7. CLEANROOM FLOORING:

The material to be used for flooring shall be solvent less epoxy resin comprising of a three component system viz base, hardener and hard wearing quartz filters.

The finished floor shall provide joint less flooring making it dust free and is easy to clean because of smooth surface. It shall have chemical resistance to most of the normally used chemical. It shall provide a tough floor topping to withstand foot and light vehicular traffic. The colour of the flooring shall be as decided by client/consultant from the available colour shades.

8. LAMINAR AIR FLOW STATION:

Horizontal Laminar air flow unit fabricated in SS 304 construction comprising of HEPA filters having efficiency 99.97% down to 0.3 micron, prefilter having efficiency 90% down to 5 micron with Custom built drive type motor (ebm NADI- Germany) with blower which is Dynamically & Statically balanced blower for less vibration & noise level.

9. DYNAMIC PASS BOX:

Dynamic pass box fabricated in SS 304 construction having Ebm make motor and blower. Dynamic pass box shall have UV light, hour meter, magnehelic gauge, Electromagnetic interlocking.

**CENTRAL FOOD & DRUG TESTING LABORATORY
MUMBAI**

**TENDER
FOR**

**HVAC, CLEAN ROOM AND ALLIED WORKS FOR
MICROBIOLOGY LAB FOR FOOD & DRUG
TESTING LABORATORY MUMBAI**

VOLUME - V

BILL OF QUANTITIES

Air conditioning Works

DECEMBER 2008

HSCC (INDIA) LTD.

(Consultants & Engineers for Mega Hospitals & Laboratories)
E - 6 (A), Sector - I, NOIDA (U.P.) - 201 301 (INDIA)

PHONE : 91-2542436, 2542440
91-2542443, 2542445

FAX : 91-11-91-2542447
E- mail : hsccltd @hsccltd.co.in

Tender No **HSCC/139/PM/-HVAC-F&D Mumbai/2008**

HVAC work, Clean room and allied items for Microbiology lab at Food & Drug Lab, Mumbai.

A. Air Handling Units

Sr. No.	Description	Unit	Qty	Rate in Rs in Figures	Rate in Rs in Words	Amount in Rs
1	SYSTEM-1, Air Handling Unit:					
a	Supply, installation testing & Commissioning of Double skin air handling unit comprising retron air plenum section, fan section, cooling and dehumidifying section (prefilters, Microvee filters), mixing section with all necessary control and accessories for air side and Refrigerant side. Unit shall be horizontal or vertical draw-through type arranged for horizontal discharge having 6 row DX coil designed at 500 fpm CAPACITY: 3000 cfm STATIC PRESSURE: 5" MOTOR HP: 5	No	1			
b	Supply, installation testing & commissioning of CONDENSING UNIT of Kriloskar or equivalent compressor interconnecting copper piping for compression cycle along with air cooled condenser as per standard technical specifications. CONDENSING UNIT: 7.5 TR	No	1			
2	HEPA filters					
a	Box type separatorless minipleat HEPA filters conforming to following specification for clean room application: Overall size: 450 x 450 x 68 mm Rated capacity: 400 cfm Initial Pr. Drop: Less than 18 mm w. g. Efficiency: 99.97% down to 0.3 μ particle size	Nos	6			

Sr. No.	Description	Unit	Qty	Rate in Rs in Figures	Rate in Rs in Words	Amount in Rs
b	<p>Overall size: 305 x 305 x 68 mm</p> <p>Rated capacity: 100 CFM</p> <p>Initial Pr. Drop: Less than 18 mm w. g.</p> <p>Efficiency: 99.97% down to 0.3 μ particle size</p> <p>Material of construction: 100% micro glass fiber paper media machine plated, separatorless, casing fabricated out of 6 mm thick extruded aluminium section with suitable sealing adhesive an all sides, 6 mm thick neoprene rubber gasket on flange joints.</p>	Nos	6			
3	Filter Housing					
a	<p>The filter Housing for the above filter is Fabricated out of 3 mm thick CRCA sheet duly powder coated with stainless steel hardware.</p> <p>Size: 450 x 450 x 68</p>	Nos	6			
b	<p>Size: 305 x 305 x 68</p>	Nos	6			
4	Sheet Metal Work:					
	<p>Ducts shall be made of GSS with curves & bends where indicated for easy flow of air an ensured to be air tight by applying silicon sealant after fabrication hangers shall be provided to GI ducts & shall be suspended by means of MS black painted rods. Hangers shall be not more than 2.5 m apart.</p>					
a	a. 22 gauge (0.8 mm)	Sq.ft	480			
b	b. 24 gauge (0.63 mm)	Sq.ft	645			

Sr. No.	Description	Unit	Qty	Rate in Rs in Figures	Rate in Rs in Words	Amount in Rs
5	Thermal Insulation:					
a	Thermal Insulation with 13 mm thick Nitrile rubber for supply air and return air duct. Joints will be lapped with Nitrile tape for better thermal insulation.	Sq.ft	528			
b	Thermal Insulation with 9 mm thick Nitrile rubber for supply air and return air duct. Joints will be lapped with Nitrile tape for better thermal insulation.	Sq.ft	710			
6	Volume Control Dampers: All dampers shall be opposed blade louvered dampers in galvanized construction and tight fitting. Damper shall be provided with operating and locking device mounted outside the duct in an accessible position	Sq.ft	6			
7	Fire Dampers: Dampers and frames shall have suitable eye and standard fusible links rated at 65 deg. Centigrade normally holding them open, but releasing when operated.	Sq.ft	6			
8	SS 304 Perforated sheets duly mirror finished.	Sq.ft	8			
9	Aluminium collar dampers	Sq.ft	8			
10	Electrical Panel for AHU and Condensing Unit 1	No	1			
11	Cabling Work:					
a	a. 4C x 1.5 sq mm Copper Armoured	Rmt	20			
b	b. Earthing with 16 gauge Copper Wire	Rmt	20			
12	Magnehelic Guage Magnehelic guages with SS 304 enclosure along with PVC tubing and SS Nozzels.	Nos	9			

Sr. No.	Description	Unit	Qty	Rate in Rs in Figures	Rate in Rs in Words	Amount in Rs
2	SYSTEM-2, Air Handling Unit:					
a	Supply installation testing & commissioning of Double skin air handling unit comprising retron air plenum section, fan section, cooling and dehumidifying section (prefilters, Microvee filters), mixing section with all necessary control and accessories for air side and Refrigerant side. Unit shall be horizontal or vertical draw-through type arranged for horizontal discharge having 6 row DX coil designed at 500 fpm CAPACITY: 1600 cfm STATIC PRESSURE: 5" MOTOR HP: 3	No	1			
b	Supply installation testing & commissioning of Condensing unit of Kriloskar or equivalent compressor interconnecting copper piping for compression cycle along with air cooled condenser as per standard technical specifications. CONDENSING UNIT: 4 TR	No	1			
2	HEPA filters					
a	Box type separatorless minipleat HEPA filters conforming to following specification for clean room application: Overall size: 450 x 450 x 68 mm Rated capacity: 400 CFM Initial Pr. Drop: Less than 18 mm w. g. Efficiency: 99.97% down to 0.3 μ particle size	No	2			

Sr. No.	Description	Unit	Qty	Rate in Rs in Figures	Rate in Rs in Words	Amount in Rs
b	<p>Overall size: 305 x 305 x 68 mm</p> <p>Rated capacity: 500 CFM</p> <p>Initial Pr. Drop: Less than 18 mm w. g.</p> <p>Efficiency: 99.97% down to 0.3 μ particle size</p> <p>Material of construction: 100% micro glass fiber paper media machine plated, separatorless, casing fabricated out of 6 mm thick extruded aluminium section with suitable sealing adhesive an all sides, 6 mm thick neoprene rubber gasket on flange joints.</p>	Nos	4			
3	Filter Housing					
a	<p>The filter Housing for the above filter is Fabricated out of 3 mm thick CRCA sheet duly powder coated with stainless steel hardware.</p> <p>Size: 450 x 450 x 68 mm</p>	Nos	2			
b	305 x 305 x 68 mm	Nos	4			
4	Sheet Metal Work:					
	<p>Ducts shall be made of GSS with curves & bends where indicated for easy flow of air an ensured to be air tight by applying silicon sealant after fabrication hangers shall be provided to GI ducts & shall be suspended by means of MS black painted rods. Hangers shall be not more than 2.5 m apart.</p>					
a	a. 22 gauge (0.8 mm)	Sq.ft	225			
b	b. 24 gauge (0.63 mm)	Sq.ft	380			

Sr. No.	Description	Unit	Qty	Rate in Rs in Figures	Rate in Rs in Words	Amount in Rs
5	Thermal Insulation:					
a	Thermal Insulation with 13 mm thick Nitrile rubber for supply air and return air duct. Joints will be lapped with Nitrile tape for better thermal insulation.	Sq.ft	247			
b	Thermal Insulation with 9 mm thick Nitrile rubber for supply air and return air duct. Joints will be lapped with Nitrile tape for better thermal insulation.	Sq.ft	418			
6	Volume Control Dampers: All dampers shall be opposed blade louvered dampers in galvanized construction and tight fitting. Damper shall be provided with operating and locking device mounted outside the duct in an accessible position	Sq.ft	3			
7	Fire Damper: Dampers and frames shall have suitable eye and standard fusible links rated at 65 deg. Centigrade normally holding them open, but releasing when operated.	Sq.ft	3			
8	SS 304 Perforated sheets duly mirror finished.	Sq.ft	4			
9	Aluminium collar dampers	Sq.ft	8			
10	Electrical Panel for AHU and Condensing Unit 1	No	1			
11	Cabling Work:					
a	a. 4C x 1.5 sq mm Copper Armoured	Rmt	20			
b	b. Earthing with 16 gauge Copper Wire	Rmt	20			
12	Magnehellic Guage Magnehellic guages with SS 304 enclosure along with PVC tubing and SS Nozzels.	Nos	5			

Sr. No.	Description	Unit	Qty	Rate in Rs in Figures	Rate in Rs in Words	Amount in Rs
3	SYSTEM-3, AIR HANDLING UNIT:					
a	Supply installation testing & commissioning of Double skin air handling unit comprising retron air plenum section, fan section, cooling and dehumidifying section (prefilters, Microvee filters), mixing section with all necessary control and accessories for air side and Refrigerant side. Unit shall be horizontal or vertical draw-through type arranged for horizontal discharge having 6 row DX coil designed at 500 fpm CAPACITY: 1400 cfm STATIC PRESSURE: 5" MOTOR HP: 3	No	1			
b	Supply installation testing & commissioning of condensing unit of Kriloskar or equivalent compressor interconnecting copper piping for compression cycle along with air cooled condenser as per our standard specifications. CONDENSING UNIT: 4 TR	No	1			
2	HEPA filters					
a	Box type separatorless minipleat HEPA filters conforming to following specification for clean room application: Overall size: 450 x 450 x 68 mm Rated capacity: 300 CFM Initial Pr. Drop: Less than 18 mm w. g. Efficiency: 99.97% down to 0.3 μ particle size	Nos	4			

Sr. No.	Description	Unit	Qty	Rate in Rs in Figures	Rate in Rs in Words	Amount in Rs
b	<p>Overall size: 305 x 305 x 68 mm</p> <p>Rated capacity: 100 CFM</p> <p>Initial Pr. Drop: Less than 18 mm w. g.</p> <p>Efficiency: 99.97% down to 0.3 μ particle size</p> <p>Material of construction: 100% micro glass fiber paper media machine plated, separatorless, casing fabricated out of 6 mm thick extruded aluminium section with suitable sealing adhesive an all sides, 6 mm thick neoprene rubber gasket on flange joints.</p>	Nos	1			
3	Filter Housing					
a	<p>The filter Housing for the above filter is Fabricated out of 3 mm thick CRCA sheet duly powder coated with stainless steel hardware.</p> <p>Size: 450 x 450 x 68 mm</p>	Nos	4			
b	305 x 305 x 68 mm	Nos	1			
4	Sheet Metal Work:					
	Ducts shall be made of GSS with curves & bends where indicated for easy flow of air an ensured to be air tight by applying silicon sealant after fabrication hangers shall be provided to GI ducts & shall be suspended by means of MS black painted rods. Hangers shall be not more than 2.5 m apart.					
a	a. 22 gauge (0.8 mm)	Sq.ft	226			
b	b. 24 gauge (0.63 mm)	Sq.ft	418			

Sr. No.	Description	Unit	Qty	Rate in Rs in Figures	Rate in Rs in Words	Amount in Rs
5	Thermal Insulation:					
a	Thermal Insulation with 13 mm thick Nitrile rubber for supply air and return air duct. Joints will be lapped with Nitrile tape for better thermal insulation.	Sq.ft	249			
b	Thermal Insulation with 9 mm thick Nitrile rubber for supply air and return air duct. Joints will be lapped with Nitrile tape for better thermal insulation.	Sq.ft	459			
6	Volume Control Damper: All dampers shall be opposed blade louvered dampers in galvanized construction and tight fitting. Damper shall be provided with operating and locking device mounted outside the duct in an accessible position	Sq.ft	3			
7	Fire Damper: Dampers and frames shall have suitable eye and standard fusible links rated at 65 deg. Centigrade normally holding them open, but releasing when operated.	Sq.ft	3			
8	SS 304 Perforated sheets duly mirror finished.	Sq.ft	4			
9	Aluminium collar dampers	Sq.ft	8			
10	Electrical Panel for AHU and Condensing Unit 1	No	1			
11	Cabling Work:					
a	a. 4C x 1.5 sq mm Copper Armoured	Rmt	20			
b	b. Earthing with 16 gauge Copper Wire	Rmt	20			
12	Magnehelic Guage Magnehelic guages with SS 304 enclosure along with PVC tubing and SS Nozzels.	Nos	2			

Sr. No.	Description	Unit	Qty	Rate in Rs in Figures	Rate in Rs in Words	Amount in Rs
4	SYSTEM-4, Air Handling Unit:					
a	Supply installation testing & commissioning of Double skin air handling unit comprising retron air plenum section, fan section, cooling and dehumidifying section (prefilters, Microvee filters, EU -8 Filter), mixing section with all necessary control and accessories for air side and Refrigerant side. Unit shall be horizontal or vertical draw-through type arranged for horizontal discharge having 6 row DX coil designed at 500 fpm CAPACITY: 1600 cfm STATIC PRESSURE: 5" MOTOR HP: 3	No	1			
b	Supply installation testing & commissioning of CONDENSING UNIT of Kriloskar or equivalent compressor interconnecting copper piping for compression cycle along with air cooled condenser as per our standard specifications. CONDENSING UNIT: 4 TR	No	1			
2	Sheet Metal Work: Ducts shall be made of GSS with curves & bends where indicated for easy flow of air and ensured to be air tight by applying silicon sealant after fabrication hangers shall be provided to GI ducts & shall be suspended by means of MS black painted rods. Hangers shall be not more than 2.5 m apart.					
a	a. 22 gauge (0.8 mm)	Sq.ft	257			
b	b. 24 gauge (0.63 mm)	Sq.ft	397			
3	Thermal Insulation:					

Sr. No.	Description	Unit	Qty	Rate in Rs in Figures	Rate in Rs in Words	Amount in Rs
a	Thermal Insulation with 13 mm thick Nitrile rubber for supply air and return air duct. Joints will be lapped with Nitrile tape for better thermal insulation.	Sq.ft	283			
b	Thermal Insulation with 9 mm thick Nitrile rubber for supply air and return air duct. Joints will be lapped with Nitrile tape for better thermal insulation.	Sq.ft	437			
4	Volume Control Dampers: All dampers shall be opposed blade louvered dampers in galvanized construction and tight fitting. Damper shall be provided with operating and locking device mounted outside the duct in an accessible position	Sq.ft	3			
5	Fire Damper: Dampers and frames shall have suitable eye and standard fusible links rated at 65 deg. Centigrade normally holding them open, but releasing when operated.	Sq.ft	3			
6	SS 304 Perforated sheets duly mirror finished.	Sq.ft	8			
7	Aluminium collar dampers	Sq.ft	8			
8	Electrical Panel for AHU and Condensing Unit 1	No	1			
9	Cabling Work:					
a	a. 4C x 1.5 sq mm Copper Armoured	Rmt	20			
b	b. Earthing with 16 gauge Copper Wire	Rmt	20			
10	Magnehellic Guage Magnehellic guages with SS 304 enclosure along with PVC tubing and SS Nozzels.	Nos	3			

Sr. No.	Description	Unit	Qty	Rate in Rs in Figures	Rate in Rs in Words	Amount in Rs
B. Cleanroom and allied items						
1	Epoxy Paint on Walls: special putty & followed by applying two coats of epoxy/PU primer. Finally after drying the primer two coats of epoxy/PU paint shall be applied either with the help of spraying machine or special roller meant for application in clean rooms	Sq.m	397			
2	Glazed Windows: Flushed windows Fabricated out of 18 gauge Galvanized steel duly powder coated with 4 mm Clear glass on both the sides. Silica gel will be filled to prevent condensation due to temperature difference.	Sq.m	11			
3	Flushed Doors: Door complete with air tight door frame made from 1.2 mm thick SS304 and shutters made from 0.6 mm thick SS 304 in double skin construction duly insulated/infill with EPS including Handles, vision panels, Lock and door Bottom gasket seal etc. Size : 900 x 2100	Nos	20			
4	Aluminium covings: All the floor to wall, wall to wall & wall to ceiling joints shall be properly coved (rounded) so that there is not any dust deposition in the joints. The material of coving shall be aluminum extrusion with radius not less than 50 mm. The three way corner covings shall be provided wherever required.	Rmt	610			

Sr. No.	Description	Unit	Qty	Rate in Rs in Figures	Rate in Rs in Words	Amount in Rs
5	<p>Air tight cleanroom light fixtures: Cleanroom light fitting complete with CRCA powder coated box, light modules : 3 x 36 W PLL, diffuser panels suitable for 600 x 600 mm opening to be provided in false ceiling.</p>	Nos	28			
6	<p>False ceiling: 50 mm thick Non-walkable false ceiling made out of 0.6 mm thick SS 304 from room side, powder coated GI from outer side duly flushed with walls & insulated with EPS having density 16 Kg/m3. All cutouts for lighting, filters etc.to be sealed with silicon sealant after fitment.</p>	Sq.m	139			
7	<p>Cleanroom flooring: Self leveling joint less type epoxy flooring to be carried out on existing floors before lying the epoxy coat floor surface will be properly cleaned, leveled & prepared. The thickness of the epoxy coating shall be between 2-3 mm with minimum thickness of not less than 2mm anywhere.</p>	Sq.m	139			
8	<p>Laminar Air Flow Station Class 100 Horizontal Laminar Air Flow station in SS-304 construction designed to provide a Laminar Air Flow Work Space Comprising of Hepa filter having efficiency of 99.97% down to 0.3 microns, Pre Filter 90% down to 5 microns, suitable motor blower Assemblies, canopy, white lights, magnehellic gauges (0-50 mm wg.) etc. Size: 4' x 2'</p>	Nos	4			

Sr. No.	Description	Unit	Qty	Rate in Rs in Figures	Rate in Rs in Words	Amount in Rs
9	<p>Cross over bench : The cross over bench fabricated out of 1.2 mm thk 304 grade stainless steel having two compartments for keeping dirty and clean room shoes as per current good manufacturing practices. Size: 1800 (L) x 450 (w) x 500 (H)</p>	No	1			
10	<p>Electrical Switch and Sockets: Electrical switches & Sockets, Telephone sockets along with backing box for cleanrooms</p>	Sets	12			
11	<p>Dynamic Pass box: PASS BOX WITH UV, Electromagnetic Locks, Mini pleat Hepa, EBM make fan (German) 1.5' x 1.5' in SS 304 construction.</p>	Nos	2			
12	<p>Storage cabinet: Storage cabinet fabricated in 1 mm thk SS 304 having provision of see through on the doors with U.V germicidal light fixture. Size: 0.9 m x 1.8 m x 0.35 m</p>	No	1			

Sr. No.	Description	Unit	Qty	Rate in Rs in Figures	Rate in Rs in Words	Amount in Rs
---------	-------------	------	-----	-----------------------	---------------------	--------------

Summary of Cost

Sr. No.	Description	Amount (Rs.)
1	SYSTEM-1, Air Handling Unit	
2	SYSTEM-2, Air Handling Unit	
3	SYSTEM-3, Air Handling Unit	
4	SYSTEM-4, Air Handling Unit	
5	Cleanroom and allied items	
	Sub Total	

FORM OF BID

Name of Contract : “HVAC, Clean room and allied works for Microbiology lab for Food & drug Testing Laboratory Mumbai.”..

1. Having examined the Conditions of Contract, Specifications, Drawings, and Bill of Quantities and Addenda Nos. _____ for the execution of the above-named works we, the undersigned, offer to execute and complete such works and remedy any defects therein in conformity with the Conditions of Contract, Specifications, Drawings, Bill of Quantities and Addenda for the sum(s) of

(In Figures) _____

(In words) _____

as specified in the Appendix to Bid or such other sums as may be ascertained in accordance with the said Conditions.

2. We acknowledge that the Appendix forms part of our Bid.
3. We undertake, if our Bid is accepted, to commence the works within 07 (seven) days after the receipt of the Engineer's notice to commence, and to complete the whole of the works comprised in the Contract within the time stated in the Appendix to Bid.
4. We agree to abide by this Bid for the period of 120 days from the date fixed for receiving the same, and it shall remain binding upon us and may be accepted at any time before the expiration of that period.
5. We agree to treat the tender documents, drawings and other records connected with the works as secret and confidential documents and shall not communicate information described therein to any person other than the person authorised by you, or use the information in any manner prejudicial to the safety of the works.
6. Unless and until a formal Agreement is prepared and executed this Bid, together with your written acceptance thereof, shall constitute a binding contract between us.

7. We understand that you are not bound to accept the lowest or any Bid you may receive.

Dated this _____ day of _____ 20 ____

Signature _____ in the capacity of _____ duly authorised to
sign Bid for and on behalf of
_____.

Address _____

Witness _____

Address _____

Occupation _____