

To,

Subject : Construction of Test Research Laboratory (Animal Facility Building) at NIMR campus, Papankalan, Dwarka , New Delhi

References : Tender Notice No. NIMR/HSCC/263/PG-III/2009
HSCC letter no. HSCC/263/PG-III/Tender/2009 dated 3/09/09

Dear Sir,

This is in continuation of Clarification/Amendments-I issued vide HSCC letter no. HSCC/263/PG-III/Tender/2009 dated 3/09/09 referred above in respect of the above mentioned works. The following Clarifications/Amendments –II may please be noted for compliance.

- A. Technical Clarifications/Amendments Page No. 2
Civil, Public Health, Fire Fighting works
- B. Technical Clarifications/Amendments Page No. 3
HVAC works

In accordance with tender clause 6.0 and 7.0 of Volume –III (Instruction to bidders, Specific Conditions of Contract), the above Clarifications/Amendments shall be part of the tender documents. Bidders are requested to submit the same along with the other tender documents duly signed and stamped.

All other terms and conditions of the tender documents shall remain unchanged.

Thanking you,

Yours faithfully

(S.Mukhopadhyay)
Dy.General Manager (Civil)

Encl: As above (2 Pages)

GENERAL CLARIFICATIONS/AMENDMENTS -II

Sl. No.	Reference	Clause No./Page No.	Existing Clause	Bidders Queries	Clarifications/Amendments
1	Bill of Quantities	Item No. 3.24 NS 24 Page BOQ, C-12	Ball Valve	Material for Ball Valve is not mentioned.	Providing & Fixing full way lever operated forged brass ball valve of brass body with forged brass hard chrome plated steel ball tested to a pressure not less than 10kg/sqcm with threaded / flanged joints complete with nuts , bolts, gaskets, washers etc.
2.	Tender Drawings	Volume VI	Tender Drawings enclosed	The level of the proposed basement is shown as 80cm below the level of the existing basement and both the basements have common structural wall, which needs to be clarified, since it shall pose some practical problems for the proposed construction.	Suitable decision shall be taken during execution.

Clarifications regarding HVAC System for Animal House (NIMR), Pappankalan.				
S. No.	Reference	Item/Page No.	Bidder's query	Clarification
1	Volume-IV, Technical Specifications	Clause 8.0, Specs -AC- Page-6/7	Clause 8.0 specs-AC - page 53/54 items to be provided by other agencies to AC contractors.	The clause 8.0 specs - AC do not appear on page 53/54, this clause is on page no. 6/7. Major civil works, 3 phase electrical connections for AC load are included in the contract and part of civil and electrical works (not the part of HVAC works).
2	Volume-IV, Technical Specifications	Specs -AC- Page-85	Specs - AC- page 85 : List of approved makes and manufacturers.	The approved sub-contractors for HVAC works are Voltas/ ETA / Blue Star / Suvidha.
Note. All other items of BOQ, specifications & tender documents shall remain unchanged.				