



NOTES

1. ALL DIMENSIONS ARE IN mm & LVS IN m.
2. READ IN CONNECTION WITH RELEVANT ARCH DRS
3. FINISHED FLOOR LVL TO BE COVERED WITH 100MM DRS. THE SLAB LVLN TO BE WORKED OUT SUITABLE CONSIDERING FLOOR FINISH THICKNESS.
4. CLEAR COVER OF R/F TO BE AS BELOW:-

CORNER	= 50mm
COLUMN	= 40mm
BELM	= 30mm
SLAB	= 25mm
5. CONC. MIX. TO BE M-25 FOR ALL RCC WORK AS PER IS:46-2000
6. ALL R/F BARS TO BE #400 Mpa. HYSD OR NAT STEEL AS PER IS:1786.
7. ALL LVL LENGTHS = 50xSMALLER PER #.
8. ALL LVS TO PLANNED SUITABLE PER SITE REQUIREMENT.
9. DEVELOPMENT LENGTH = 50xBAR #.

REV	DATE	DESCRIPTION
0	14.03.13	FOR INDEX

REVISION

PROJECT

PROPOSED
100 BEDDED HOSPITAL
AT SHAHJAHANPUR

TITLE

SECOND FLOOR BEAM FRAMING PLAN &
THIRD FLOOR BEAM FRAMING PLAN

HSCC / SJP / D&E / ST-T-103

Drawing No. REV. 02

HSCC/	1:125	MARCH.-201
JOB NO.	SCALE	DATE

HSCC/	1:125	MARCH.-201
JOB NO.	SCALE	DATE

APPROVED	REVIEWED	PREPARED
----------	----------	----------

APPROVED	REVIEWED	PREPARED
----------	----------	----------

APPROVED	REVIEWED	PREPARED
----------	----------	----------

HSCC INDIA LTD.
(A GOVERNMENT OF INDIA ENTERPRISE)

GOVERNMENT OF INDIA ENTERPRISES