



This drawing with all its contents is the sole intellectual property of the Hospital Services Consultancy Corporation (India) Ltd. Copying of this drawing or part thereof or its use in any form whatsoever without the written permission of HSCC is prohibited.

NOTES

1. DRAWINGS TO BE READ NOT MEASURED
2. PARTITION WALL IN TOILETS UP TO LINTEL HEIGHT

NOTES

NOTES
BASED ON THIS DRAWING EXECUTING AGENCY WILL PREPARE SHOP DRAWING AFTER
INCORPORATING THE CHANGES AS PER SITE CONDITION FOR THE APPROVAL OF
HSGC BEFORE START OF WORK.
THE NUMBER & LOCATION OF FIXTURES & WET POINT TO BE FINALIZED BEFORE
EXECUTION WITH CLINT OFFICER'S INCHARGE.

LEGEND:

NO.	DESCRIPTION	SIMBAL
1.	FIRE HOSE CABINET (FHC) size 1.2MX0.6MX2.1M(H)	
2.	SPRINKLER (PENDENT TYPE) SPRINKLER (SIDE WALL)	
3.	SPRINKLER PIPE	—SP—
4.	INSPECTION TEST VALVE ASSEMBLY	
5.	NON RETURN VALVE	
6.	SLUICE VALVE	
7.	FIRE LINE	—F—

FIRE EXTINGNISHER

WATER TYPE FIRE EXTINGUISHER	
CARBON DIOXIDE TYPE FIRE EXTINGUISHER	
MANUAL CALL BOX	

NOTES ON FIRE FIGHTING

1. Every FHC shall be consisting of as per IS the following.
 - (a) 63mm dia. single headed Hydrant Valve.
 - (b) 2nos. 63mm dia. 15mts long RRL Hose reel.
 - (c) 20mm dia 36.5mt first aid hose reel with 5mm bore nozzle.
 - (d) 63mm dia.mole and female INST type coupling.
 - (e) 20mm dia branch pipe with 20mm nozzle.
- f) 2 NOS FIRE EXTINGUISHERS

LEGEND FOR VERTICAL PIPE

- ① 150Ø MS FIRE RISER
- ② SPRINKLER RISER
- ③ 50Ø SPRINKLER DRAIN PIPE

		DESCRIPTION		
REVISION				

PROJECT

**PROPOSED
100 BEDDED HOSPITAL
JAUNPUR**

TITLE	FIRE-FIGHTING
--------------	----------------------

TENDER DRAWING

SECOND FLOOR PLAN

HSSC/D&E/TD/SHAHJAHANPUR/FIRE-04		
Drawing No.	Rev.	
Job No.	1:150 Scale	MARCH-201 Date
BY: R.TYAGI App by	R.SUR Rev. by	S.BHATT Prep. by

HSCC (INDIA) LIMITED
(A GOVERNMENT OF INDIA ENTERPRISES)

HSCC
NEW DELHI INDIA